


POTENTIAL PHASING - NOMINAL DELIVERY RATES

PHASE 1 - 400 GPM (645 AFY)
 PHASE 2 - 1,000 GPM (1600 AFY)
 PHASE 3 - 2,000 GPM (3000 AFY)

OPTION A - CAPACITY FOR POTENTIAL FUTURE DELIVERY UP TO 3,000 AFY
OPTION B - CAPACITY FOR POTENTIAL FUTURE DELIVERY UP TO 6,300 AFY

Unless otherwise noted, individual project components are designed for Option A (3,000 AFY). Note that additional piping, storage, and pumps will be required for more than 3,000 AFY.

* PRV STATIONS INSTALLED ON EXISTING OR EXTENDED WATERLINES
 ** SOUTHLAND PRV STATION INSTALLED BETWEEN DEDICATED PROJECT MAIN AND EXISTING WATER MAIN



AECOM

AECOM Technical Services, Inc.
 1194 Pacific Street, Suite 204
 San Luis Obispo, California 93401
 T 805.542.9840 F 805.542.9990
 www.aecom.com

NCSD SUPPLEMENTAL WATER PROJECT
 PHASING TECHNICAL FEASIBILITY STUDY

**POTENTIAL PHASING
 PROJECT COMPONENTS**

AECOM
 PROJECT NO.
 60270503

FIGURE
 2

DATE: 11/15/2011 10:00 AM
 DRAWN BY: J. BROWN
 CHECKED BY: J. BROWN
 PROJECT NO.: 60270503
 SHEET NO.: 2/4