


NIPOMO

COMMUNITY SERVICES DISTRICT



Water and Sewer System Master Plan

FINAL REPORT

BOYLE
ENGINEERING CORPORATION

November 6, 1995

VT-N04-100-01

NIPOMO COMMUNITY SERVICES DISTRICT

Water and Sewer System Master Plan

Nipomo Community Services District

Client Representatives Doug Jones, General Manager
Lee Douglas, Maintenance
Supervisor
Lisa Souza Bognuda, Asst.
Administrator

Boyle Engineering Corporation

Project Manager Christine M. Ferrara, P.E.
Project Engineer Jeffrey A. Lodge
Quality Control Jay T. Spurgin, PE

VT-N04-100-01

November 6, 1995



BOYLE

973 Higuera St. Suite C, San Luis Obispo, CA 93401
Copy of document found at www.NoNewWipTax.com

TABLE OF CONTENTS

Executive Summary.....	i
1.1 Overview	1
1.2 Purpose and Scope.....	2
2.0 Water Demands and Sewer Loading.....	4
2.1 Historic Demand.....	4
2.2 Unaccounted For Water	4
2.3 Determination of Water and Sewer Duty Factors.....	5
2.4 Projected Demand.....	10
2.5 Fire Flow Requirements	13
2.6 Peaking Factors.....	14
3.0 Existing Water System	17
3.1 Overview	17
3.2 Sources of Supply	18
3.3 Storage Facilities.....	21
3.4 Distribution and Transmission Pipelines.....	21
4.0 Existing Sewer System	22
4.1 Overview	22
4.2 Lift Stations	22
4.3 Collection System	24
5.0 Computer Modeling	25
5.1 Model Development.....	25
5.2 Model Calibration	26
6.0 Design Criteria	28
6.1 Water System Design Criteria.....	28
6.2 Sewer System Design Criteria	30
7.0 Ability of Water System to Meet Existing Demands.....	32
7.1 Sources of Supply	32
7.2 Storage Facilities.....	33
7.3 Distribution System Assessment	35
8.0 Ability of Sewer System to Meet Existing Needs	37
8.1 Lift Stations	37
8.2 Collection System Assessment.....	38

TABLE OF CONTENTS (continued)

9.0	Ability of Water System to Meet Future Demands	39
9.1	Sources of Supply	39
9.2	Distribution and Transmission Pipelines	39
9.3	Storage Facilities	40
10.0	Ability of Sewer System to Meet Future Needs	41
10.1	Lift Stations	41
10.2	Collection System Capacity	42
11.0	Recommended Improvements	43
11.1	Estimated Costs and Priorities	43
11.2	Additional Recommendations	45

LIST OF TABLES

1.	Water Duty Factors Used for Existing System Assessment	8
2.	Sewer Duty Factors and Existing Flows	9
3.	Future Land Use and Water Demand	11
4.	Projected Sewage Loading	12
5.	Fire Flow Criteria	14
6.	Existing Well Data	20
7.	Existing Sewage Lift Stations	23
8.	Projected Lift Station Flows	41
9.	Recommended Water System Improvements	46
10.	Recommended Sewer System Improvements	47

LIST OF FIGURES

		Follows <u>Page</u>
1.	Vicinity Map	3
2.	Average Monthly Well Production	4
3.	Unaccounted for Water	5
4.	Population Trends	10
5.	Existing Water System Schematic	17
6.	Existing Sewer System Schematic	22

LIST OF PLATES

(folded exhibits at end of report)

1. Improvements To Meet Existing Water System Demands
2. Master Planned Water System Improvements
3. Proposed Lift Station Tributary Areas
4. Master Planned Sewer System Improvements

APPENDIX MATERIALS

- A. Water Production Records 1988 to 1995
- B. Input Files for Water and Sewer Models
- C. Hydrant Tests/Calibration Results

Executive Summary

In April of 1995, the Nipomo Community Services District Board of Directors authorized the preparation of this Water and Sewer System Master Plan. The purpose of this document is to identify improvements to the water distribution and wastewater collection systems to meet existing and projected demands. A facility improvement program is recommended herein, including budget guidelines and priorities associated with the recommended improvements.

Overall, the extent of deficiencies noted in the water system is average for a system of this size and age. The wastewater collection system is considered well designed to meet current needs.

Recommended Improvements to Meet Existing Needs

Water demand is projected to increase from 1,717 AFY to 2,580 AFY with an associated increase in service area population from an estimated 9,650 to 15,000.

Overall, \$3.6 million in water system improvements are recommended to reliably meet the needs of existing customers.

Water System: The existing water system was found inadequate in several aspects with regard to meeting existing needs. Regarding water supply, an additional 540 gpm rate of supply is recommended to reliably meet summertime demands. Also, it was noted that the existing well pumps and motors are evidently operating at very low efficiencies. It is recommended that the District embark on a pump and motor replacement program to improve pumping efficiency and save on energy costs.

With regard to storage volume, the District currently has 2 million gallons (MG) of storage at two locations. By the criteria stated herein, an additional 1.0 MG is needed to reliably meet the needs of existing customers.

The water distribution system consists of the central business district and the outlying residential rural areas. These two areas are separated by Highway 101 and Nipomo Creek. Currently, a single 12-inch diameter waterline at Tefft Street connects these two areas. Two additional connections are recommended to improve reliability and distribution. Further, recommendations are made to connect the Black Lake water system to the main distribution system.

Other distribution system improvements are recommended to meet fire flow requirements throughout the service area, noteworthy among which is a recommendation to construct a parallel 12-inch diameter line from the Twin Tanks to the main distribution system.

Overall, \$3.6 million in water system improvements are recommended to reliably meet the needs of existing customers. Note that some of the recommended improvements will be provided by developers.

Sewer System: The existing wastewater collection was found to be very well designed to handle existing needs. Two areas of note are the gravity collector in Division Street and the excess capacity of existing lift stations.

The existing wastewater collection was found to be very well designed to handle existing needs.

Regarding Division Street, an existing 8-inch diameter gravity collector transports local flow plus flow from four lift stations to the frontage road main trunk line. To address this situation, a gravity relief line which would in effect eliminate the Nipomo Palms lift station is recommended. The two existing County Service Area No. 1 lift stations could also be routed through the proposed relief line at an estimated cost of \$202,000.

Regarding the lift station capacities, it was noted that half of the District's lift stations appear over-sized to meet existing (and projected) needs. The District is advised to evaluate wet well volumes, pump and motor sizes, and on/off levels in the Bracken, North Oakglen, and Gardenia lift stations.

Recommendations for the Master Planned System

Water System: The projected 50 percent increase in water demand coupled with expansion of the service area to the west will require the installation of distribution mains, a total of 2.53 MG additional storage, and additional supplies to reliably meet projected demands. An estimated \$1.9 million in system improvements are recommended to meet projected water demands.

Wastewater flow is projected to increase from 0.35 MGD to 1.13 MGD.

Sewer System: Facilities to meet projected community sewerage needs include additional gravity collectors, one new lift station near Amado Street, and greater capacity in the Frontage Road trunk line. An additional \$1.5 million in sewer system improvements are recommended in addition to the Nipomo Palms lift station relief line mentioned above.

1.0 Introduction

1.1 Overview

The Nipomo Community Services District is located along Highway 101 in the southern portion of San Luis Obispo County, California, as shown on **Figure 1**. The District is situated approximately halfway between the cities of San Francisco and Los Angeles.

The District provides water and sewer service to an unincorporated area of San Luis Obispo County. Land use is regulated by the County. The District currently provides water service to approximately 9,650 people. Approximately 40 percent of the service area is currently sewerred.

Nipomo has sustained a fairly brisk rate of development in recent years, a trend which is expected to continue. In order to plan for the orderly expansion of water and sewer facilities, the District selected Boyle Engineering Corporation to prepare this water and sewer system master plan. The result of this master plan is a plan for sewer collection and water distribution and storage facility upgrades to meet the needs of existing and future customers.

The District receives its supply of water exclusively from wells that pump water from the Nipomo subunit of the Santa Maria Ground Water Basin. This master plan quantifies projected water needs, but is not intended to be a water resource management planning document.

The District currently operates two separate water and sewer systems; one serving the main Nipomo area and one serving the Black Lake development. This master plan defines facilities needed to intertie the two water systems. The sewer systems are to remain separate.

Wastewater is treated and disposed at two locations, the main Nipomo wastewater treatment plant located south of the service area, and at the Black Lake development located to the northwest. Both treatment and disposal facilities are to remain in service. This master plan quantifies projected wastewater flows to both plants, but is not intended to define necessary treatment or disposal upgrades.

This master plan reflects a hydraulic planning effort, the purpose of which was not to provide extensive maps of the existing systems. The District's existing set of atlas maps are a good source of information that clearly shows the layout of the existing systems.

1.2 Purpose and Scope

The purpose of this study is to identify improvements to the sewer collection and water distribution systems required to meet existing and projected demands, and to develop a sewer and water facilities improvement program to aid the District in conducting long-term planning. Specific tasks which were undertaken to accomplish this include:

a. Collection and Review of Data Water data was collected which included distribution system record drawings, water consumption records, water production records, well and storage characteristics, land use plans and topographic mapping.

Sewer data was collected which included records of existing collector diameter, slope, and manhole locations throughout the service area. Additionally, information was reviewed on lift stations, including wet well depth and volume, number and type of pumps in place, and force main diameter and location.

Population and land use information was obtained from the County of San Luis Obispo Department of Planning and Building. District water usage records were also referenced to estimate the number of water service connections in recent years.

b. Development of Design Parameters Water duty factors for both residential and non-residential land uses were developed using historic water consumption data. Peaking factors for maximum day demand and peak hour demand were estimated. Fire flow requirements were established by comparison with water systems of similar complexity, climate and population.

Sewer duty factors for both residential and non-residential land uses were developed using a ratio of historic water consumption data.


c. Estimated Demands Existing land use information obtained from the San Luis Obispo County Department of Planning and Building, along with District records, were used to approximate existing and future demand distribution. Existing and future sewer loading was based on similar available information.

d. Development of Computer Models Computer models were developed to simulate the District's sewer and water system performance under both existing and future demands. The District's sewer and water systems were reviewed through as-built and record drawings. Data input files were compiled for use with hydraulic and sewer network software, BoyleNET and BoyleSWAN.

The water model was calibrated using results of fire hydrant flow tests performed by District staff.

e. Identification of Existing Deficiencies and Future Needs Hydraulic analyses were performed to analyze the adequacy of the existing sewage collection and water distribution pipelines under both existing and projected demands. Upgrades were recommended where deficiencies were found. Recommendations for existing and future lift stations, conveyance systems, and storage facilities were made.

f. Prioritization and Cost Estimation for Recommended Improvements The cost and priority of recommended improvements to meet existing and projected water and sewer demands were established and a capital improvement plan was prepared.



N.T.S.

NIPOMO COMMUNITY SERVICES DISTRICT
1995 WATER AND SEWER MASTER PLAN
VICINITY MAP
<i>BOYLE ENGINEERING CORPORATION</i>
VT-N04-100-01 NOV. 1995 FIGURE 1

FIGURE 2
AVERAGE MONTHLY WELL PRODUCTION
 For Years 1988 - 1994





FIGURE 3
Nipomo Community Services District
Unaccounted for Water



2.0 Water Demands and Sewer Loading

2.1 Historic Demand

Historic water production and metered consumption data for January 1988 to March 1995 was obtained from District staff. This data is included in **Appendix A**. Water production represents the total metered production from each of the District's wells. Consumption, on the other hand, represents the sum of all metered water sales throughout the service area. From this data, average annual and peak monthly water demands were estimated.

Current average annual water demand is estimated to be 1,717 acre-feet per year (AFY) based on 1993/94 production records. Peak monthly production is estimated to be 220 AF. These estimates include both the main Nipomo system as well as the Black Lake development.

Water demand increases during the hot Summer months as illustrated in **Figure 2**. Typically, summertime demand is up to 1.5 times higher than average annual demand. The peak monthly water demand was July 1994 at which time monthly water use was 1.52 times average annual demand.

The District provided records of treated wastewater volumes at the main treatment plant for 1993 to 1995, with the explanation that some operational problems have plagued the meter. Temporary flow metering information was not made available during the course of this master plan development. Therefore, sewage flows were estimated based on both metered water production and available records of treated wastewater as described in Section 2.3.

2.2 Unaccounted For Water

Both water production and consumption records for the 1988 to 1995 period were reviewed. The difference between metered water production and metered water consumption is known as "unaccounted for water." There is typically unaccounted for water in every domestic water system, comprised of:

- Distribution system and lateral leakage
- Metering inaccuracies
- Hydrant flows
- Unmetered connections to the system

- Other factors

For Nipomo, unaccounted for water has ranged from 4 to 31 percent in the past seven years, as shown in **Figure 3**. Unaccounted for water is typically 15 percent for systems of this size, as discussed in AWWA Manual M32.

Nipomo sustained an average unaccounted for water level of approximately 8 percent from 1988 to 1993, which is considered fair for a system of this size. Significant increases since 1992 may be attributed to widespread failure of service laterals. The District is actively replacing service laterals and is demonstrating a favorable decrease in the amount of unaccounted for water.

2.3 Determination of Water and Sewer Duty Factors

Water Duty Factors

The District's monthly water production and consumption records (**Appendix A**) were used as the basis for estimating water "duty factors." Duty factors are estimates of water demand per residence or per land use category.

The District provided Assessor's Parcel Maps which indicated individual lots receiving water and/or sewer service. This provided both an accurate count of the number of lots receiving service as well as a basis for distributing water demand throughout the service area. Metered consumption data for large users was also provided and was considered in estimating water duty factors for Nipomo.

First, overall water production was compared to estimates of current service area population. Statistics for the South County Planning Area, as published by the County of San Luis Obispo, were referenced. Current water service area population is estimated to be 9,650 based on estimated occupancy rates indicated in **Table 1**. This equates to a gross per capita consumption rate of 160 gallons per capita per day. "Gross" per capita consumption refers to total community water demand, including non-residential water uses.

The District provides water service to businesses, schools, irrigation meters, and other land uses in addition to residences. To estimate the water demand associated with non-residential land uses, water

consumption records for specific users were referenced. Acreages for non-residential users were also estimated based on the Assessor's Parcel Maps provided by the District.

Table 1 indicates the estimated number of residential dwelling units in both the main and Black Lake systems. Similarly, non-residential land uses are also tabulated. Average annual and "summertime demands" (i.e. May through August) are both listed in **Table 1**.

Sewer Duty Factors

As was previously mentioned, the District maintains records of sewage flow at the main wastewater treatment plant, however, the accuracy of the metered data is questionable due to reported operational problems with the flow meter. Records indicate that:

- Average monthly flow in 1993 was measured at 0.228 MGD
- Average monthly flow in 1994 was measured at 0.273 MGD
- Average monthly flow for the first eight months of 1995 was measured at 0.31 MGD

Metered flow data for the Black Lake wastewater treatment plant is not available.

The District currently operates eight sewage lift stations. Records of monthly electrical use is available at each lift station, however, accurate records of pump capacity are not. The District asked PG&E to conduct pump efficiency tests at each lift station earlier this year, however, PG&E declined to use their flow measurement device on wastewater facilities.

It was determined that the best available data upon which to estimate sewage loading duty factors was water consumption data. Estimates of the ratio of water use that flows to the sewage collection system were made for each land use category. This was compared to available metered flow data for the main treatment plant.

The number of residential units and non-residential development within each of the seven lift station tributary areas were estimated based on the District's Assessor's Parcel Map information. These are tabulated in **Table 2**. Nominal lift station capacities were compared to PG&E

records to estimate the average flows handled at each lift station. Estimates of sewer duty factors were iteratively derived to arrive at the sewage duty factors listed in **Table 2**.

Using this method, average annual flows to the main Nipomo wastewater treatment plant are estimated to be 0.35 MGD. This compares to meter records indicating a 0.31 MGD average monthly flow rate for the first eight months of 1995. The Black Lake treatment plant is estimated to treat an average of 69,000 gpd.

It should be noted that the District's sewage collection system handles sanitary flows only. A separate storm drain system is maintained by the County.

**TABLE 1
WATER DUTY FACTORS USED FOR EXISTING SYSTEM ASSESSMENT**

MAIN NIPOMO WATER SYSTEM:

User	Est. No. of Units (dwelling units) (1)	Est. Occupancy Rate (persons/unit)	Est. per Capita Consumption (gpcd) (2)	Avg. Annual Demand (gpd) (3)	Summertime Demand (gpd) (3)
Residential Unit - Large Lots	690	4.50	120	372,600	469,500
Residential Unit - Small Lots	1,086	3.50	93	353,500	445,400
Residential Multi-Family	999	2.10	89	186,800	235,400
RESIDENTIAL SUBTOTAL =	2,775			912,900	1,150,300
EST. MAIN SERVICE AREA POPULATION =		9,005			
	Est. No. of Acres (acres)		Est. Consumption Rate (gal/acre/day)	Avg. Annual Demand (gpd) (3)	Summertime Demand (gpd) (3)
Commercial Service Acreage	30	N/A	1,000	30,300	38,200
Commercial Retail Acreage	152	N/A	1,200	182,300	229,700
Office/Professional Acreage	34	N/A	900	31,000	39,100
Public Facility Acreage	9	N/A	2,200	19,400	24,400
NON-RESID. SUBTOTAL =	226			263,000	331,400
Large Users:					
Nipomo Regional Park				34,400	64,630
Nursery-675 Grande				13,240	17,180
Bar K Mobile Home Park				12,840	16,170
Vons Mobile Home Park				5,720	9,230
Nipomo Recreation Assoc				5,140	8,880
Church-312 Oakglen				4,380	4,510
Swap Meet				4,150	5,430
Buena Vista Mobile Homes				3,880	5,400
Landscape mtr-479 Socios				3,560	5,530
Laundromat-277 Tefft				3,310	4,000
Jockos Restaurant				3,290	3,430
9 units-475 Amado				2,850	3,660
Commercial-Frontage/Sandydale				2,660	3,760
Bank of Santa Maria				2,440	3,520
St. Joseph's Church				2,120	2,510
Grande Apts Landscape Meter				1,830	2,670
Miscellaneous Irrigation Meters				21,480	21,480
LARGE USER SUBTOTAL =				127,290	181,990
TOTAL WATER DEMAND MAIN NIPOMO WATER SYSTEM =				1,303,190	1,663,690
				gpd	gpd
				905 gpm	1,155
				1,460 AFY	

BLACK LAKE WATER SYSTEM:

User	Est. No. of Units (dwelling units) (1)	Est. Occupancy Rate (persons/unit)	Est. per Capita Consumption (gpcd) (2)	Avg. Annual Demand (gpd) (3)	Summertime Demand (gpd) (4)
Black Lake Residences	321	2.00	245	157,100	223,750
Black Lake Irrigation Usage	N/A	N/A	N/A	73,300	87,250
TOTAL BLACK LAKE WATER DEMAND =				230,400	311,000
EST. BLACK LAKE POPULATION =		642		gpd	gpd
				160 gpm	216
				258 AFY	
TOTAL EST. SERVICE AREA POPULATION =		9,647			

(1) Source: Assessor's Parcel Maps provided by District and 1994 Public Water System Statistics.

(2) Est. per capita and non-residential consumption based on metered production data and occupancy rate data provided by District.

(3) Average annual and summertime (May to August) water production data from well production records provided by the District.

Average annual demand = no. of units x occupancy x consumption rate.

**TABLE 2
SEWER DUTY FACTORS AND EXISTING FLOWS**

<u>Land Use</u>	<u>% of Water Going to Sewer</u>	<u>Water Use gpd, or gpd/acre</u>	<u>Sewer Flow at % stated</u>
Res-Lg lot	0.55	540	297 gpd/lot
Res-Sm lot	0.6	325	195 gpd/lot
All acreages	0.8	1200	960 gpd/acre
RMF	0.9	1000	800 gpd/acre
		900	720 gpd/acre
		2200	1760 gpd/acre
		1870	1683 gpd/acre

MAIN NIPOMO SEWER SYSTEM:


<u>TRIBUTARY AREA</u>	<u>NO. OF LARGE LOTS</u>	<u>NO. OF SMALL LOTS</u>	<u>Commercial Retail (acres)</u>	<u>Commercial Service (acres)</u>	<u>Office/ Professional (acres)</u>	<u>Public Facility (acres)</u>	<u>RMF (acres)</u>	<u>Est. Flow (gpd) (1)</u>	<u>Flow based on run time (gpd) (2)</u>	<u>Diff. (3)</u>
Teffl Street Lift Station	1	368	5.06	0	1.77	6.93	16.98	118,963	129,464	8%
Black Lake Mobile Home Park LS	0	156	0	0	0	0	0	30,420	27,615	-10%
Bracken Lift Station	0	16	0	0	0	0	0	3,120	2,772	-13%
Gardenia Way Lift Station	0	21	0	0	0	0	0	4,095	2,198	-86%
North Oakglen Lift Station	1	18	0	0	0	1.89	0	7,133	7,350	3%
La Mirada Lift Station	0	83	0	0	0	0	0	16,185	13,224	-22%
Nipomo Palms Lift Station	0	92	5.1	0	0	0	0	22,836	20,580	-11%
Gravity flow to Treatment Plant	23	121	21.97	0	0	0	7.66	64,409	64,409	N/A
CSA-1 (4)										
Galaxy Park	-							53,382	53,382	N/A
People's Self Help Lift Station								24,570	24,570	N/A
Totals	25	875	32.13	0.00	1.77	8.82	24.64	345,114	345,564	
								0.35	0.35	
								MGD	MGD	

(1) Estimated flow is average dry weather flow based upon number of tributary residential units at the sewer duty factors stated above and based upon the approximate number of acres of non-residential land use at the sewer duty factors stated above.

(2) Tributary area flow based on lift station run time is the total number of hours of operation for each lift station per month during January thru June 1994 times the nominal lift station flow capacity for each station.

(3) "Difference" is the percentage difference between calculated tributary area flow based on duty factors as compared to actual run time records for 1994. The large difference associated with Gardenia Way lift station represents a relatively small difference in average flow.

(4) Galaxy Park and Peoples Self Help Housing lift station flow estimates based on nominal lift station capacity times estimated station run time.



TWIN TANKS
0.5 MG EACH

BLACK LAKE
DEVELOPMENT

STANDPIPE
TANK-1.0 MG

HERMRECK WELL

SAVAGE WELL

BLACK LAKE
WELLS #3 & #4

OMIYA WELL

CHURCH
WELL

EUREKA
WELL

BELLINGTON
WELL

OLYMPIC
WELL

VIA
CONCHA
WELL

DANA WELLS
#1 & #2

FUTURE WATER SYSTEM
SERVICE BOUNDARY

LEGEND

- NIPOMO CSD WELLS
- ◐ NIPOMO CSD WELLS (STANDBY)
- NIPOMO CSD TANKS

NIPOMO COMMUNITY SERVICES DISTRICT

1995 WATER AND SEWER MASTER PLAN

EXISTING WATER
SYSTEM SCHEMATIC

BOYLE ENGINEERING CORPORATION

VT-N04-100-01 NOV. 1995 FIGURE 5



2.4 Projected Demand

This master plan is based on extending water and sewer service to the future service area boundaries illustrated in **Figures 5 and 6** respectively. Water service area population trends are illustrated in **Figure 4**. From 1988 to 1994, approximately 200 new connections per year have been added to the water system. Many factors affect the pace at which development will continue within Nipomo. **Figure 4** population projections are based on a sustained building rate of approximately 61 residential units per year. At this rate, the projected ultimate service area population of 15,000 would be reached in the year 2020.


The County Land Use Element and Local Coastal Plan was referenced to determine land use zoning within the service area boundaries. Future areas to be served were tabulated in terms of additional residential units and non-residential land use acreages. The water and sewer duty factors shown in **Tables 1 and 2** were used to estimate water demands and sewage loadings within the study area. Areas currently zoned agriculture are presumed to be converted to residential zoning for the purposes of projecting water and sewer needs.

Projected water demand is summarized in **Table 3**.

Based on the total number of acres for residential land uses along with occupancy rates as shown in **Table 1**, projected water demand is estimated to be 2,580 AFY. The distribution pipelines proposed in this master plan have been sized and laid out to accommodate this projected water usage.

Regarding sewer needs, **Table 4** tabulates the projected sewage loading throughout the service area illustrated in **Figure 6**. At full build-out and at 100% occupancy, average annual wastewater flows to the main Nipomo wastewater treatment plant are projected to be 1.13 MGD. Average annual flows to the Black Lake plant are projected to be 120,000 gpd based on 553 occupied units.

FIGURE 4
Nipomo Community Services District
Population Trends



**TABLE 3
FUTURE LAND USE AND WATER DEMAND**

MAIN NIPOMO WATER SYSTEM:

User	Est. No. of Units (dwelling units) (1)	Est. Occupancy Rate (persons/unit)	Est. per Capita Consumption (gpcd) (2)	Avg. Annual Demand (gpd) (3)	Summertime Demand (gpd) (3)
Residential Unit - Large Lots	1,405	4.50	120	758,700	956,000
Residential Unit - Small Lots	1,469	3.50	93	478,100	602,400
Residential Multi-Family	1,197	2.10	89	223,800	282,000
RESIDENTIAL SUBTOTAL =	4,071			1,460,600	1,840,400
EST. MAIN SERVICE AREA POPULATION =		13,978			
	Est. No. of Acres (acres)		Est. Consumption Rate (gal/acre/day)	Avg. Annual Demand (gpd) (3)	Summertime Demand (gpd) (3)
Commercial Service Acreage	82	N/A	1,000	81,900	103,200
Commercial Retail Acreage	199	N/A	1,200	239,400	301,600
Office/Professional Acreage	36	N/A	900	32,600	41,100
Public Facility Acreage	9	N/A	2,200	19,400	24,400
NON-RESID. SUBTOTAL =	326			373,300	470,300

Large Users:

Nipomo Regional Park				34,400	64,630
Nursery-675 Grande				13,240	17,180
Bar K Mobile Home Park				12,840	16,170
Vons Mobile Home Park				5,720	9,230
Nipomo Recreation Assoc				5,140	8,880
Church-312 Oakglen				4,380	4,510
Swap Meet				4,150	5,430
Buena Vista Mobile Homes				3,880	5,400
Landscape mtr-479 Socios				3,560	5,530
Laundromat-277 Tefft				3,310	4,000
Jockos Restaurant				3,290	3,430
9 units-475 Amado				2,850	3,660
Commercial-Frontage/Sandydale				2,660	3,760
Bank of Santa Maria				2,440	3,520
St. Joseph's Church				2,120	2,510
Grande Apts Landscape Meter				1,830	2,670
Miscellaneous Irrigation Meters				21,480	21,480
LARGE USER SUBTOTAL =				127,290	181,990

**TOTAL WATER DEMAND
MAIN NIPOMO WATER SYSTEM =**

1,961,190
gpd
1,362 gpm
2,197 AFY

2,492,690
gpd
1,731 gpm

BLACK LAKE WATER SYSTEM:

User	Est. No. of Units (dwelling units) (1)	Est. Occupancy Rate (persons/unit)	Est. per Capita Consumption (gpcd) (2)	Avg. Annual Demand (gpd) (3)	Summertime Demand (gpd) (4)
Black Lake Residences	553	2.00	245	270,970	401,036
Black Lake Irrigation Usage	N/A	N/A	N/A	73,300	87,250
TOTAL BLACK LAKE WATER DEMAND =				344,270	488,286
EST. BLACK LAKE POPULATION =		1,106		gpd	gpd
				239 gpm	339 gpm
				386 AFY	

COMBINED SYSTEMS:

Population	15,084	Avg. Annual Demand	2,582	AFY	Summertime Average	2,070
-------------------	---------------	---------------------------	--------------	------------	---------------------------	--------------

(1) Source: Exist. no. of units (Table 1) plus infill in developed areas and zoning as defined by SLO County in undeveloped areas.
 (2) Per capita consumption estimated to remain at existing levels.
 (3) Average annual estimated at duty factors stated above. Summertime (May to August) demand estimated to be 1.27 times average annual demand; 1.48 for Black Lake.

**TABLE 4
PROJECTED SEWAGE LOADING**

<u>Land Use</u>	<u>% of Water Going to Sewer</u>		<u>Water Use gpd, or gpd/acre</u>	<u>Sewer Flow at % stated</u>	
Res-Lg lot	55%	Res. Lg. lot	540	297	gpd/lot
Res-Sm lot	60%	Res. Sm lot	325	195	gpd/lot
All acreages	80%	Comm. retail	1200	960	gpd/acre
RMF	90%	Comm. Service	1000	800	gpd/acre
		Office/Prof.	900	720	gpd/acre
		Public Facility	2200	1760	gpd/acre
		Resid. Multi Family	1870	1683	gpd/acre


MAIN NIPOMO SEWER SYSTEM:

<u>TRIBUTARY AREA</u>	<u>NO. OF LARGE LOTS</u>	<u>NO. OF SMALL LOTS</u>	<u>Commercial Retail (acres)</u>	<u>Commercial Service (acres)</u>	<u>Office/ Professional (acres)</u>	<u>Public Facility (acres)</u>	<u>Resid. Multi Fam (acres)</u>	<u>Est. Flow (gpd) (1)</u>
Tefft Street Lift Station	23	625	47.74	0	12.4	12.55	24.63	247,005
Black Lake Mobile Home Park LS	12	156	0	0	0	0	0	33,984
Bracken Lift Station	19	18	0	0	0	0	0	9,153
Gardenia Way Lift Station	19	24	0	0	6.7	0	0	15,147
North Oakglen Lift Station	39	32	0	15.67	11.84	1.89	0	42,210
La Mirada Lift Station	0	83	0	0	0	0	0	16,185
Nipomo Palms Lift Station	0	92	5.1	0	0	0	0	22,836
Gravity flow to Treatment Plant	357	637	93.97	55	0	0	98.66	530,500
Proposed Amado Street LS	0	229	0	0	0	0	0	44,655
CSA-1								
Galaxy Park (2)	50	275	5	0	0	10	0	144,257
People's Self Help Lift Station	-	-	-	-	-	-	-	24,570
Future Totals	519	2171	152	71	31	24	123	1,130,502

**1.13
MGD**

(1) Estimated flow is average dry weather flow based upon number of tributary residential units at the sewer duty factors stated above and based upon the approximate number of acres of non-residential land use at the sewer duty factors stated above.

(2) Galaxy Park flows include new development listed above plus existing lift station flows.



**BLACK LAKE
WASTE WATER
TREATMENT PLANT**

**BLACK LAKE
DEVELOPMENT**

**FUTURE NIPOMO CSD
SEWER SERVICE
AREA BOUNDARY**

**NORTH OAKGLEN
LIFT STATION**

**TEFFT ST.
LIFT STATION**

**WOODGREEN
LIFT STATION**

**BRACKEN LANE
LIFT STATION**

**NIPOMO PALMS
LIFT STATION**

**BLACK LAKE
MOBILE HOME PARK
LIFT STATION**

**GARDENIA ST.
LIFT STATION**

**NIPOMO CSD
WASTE WATER
TREATMENT PLANT**

**SELF HELP HOUSING
LIFT STATION (CSA-1)**

**LA MIRADA
LIFT STATION**

**MAIN
(SOUTHLAND ST.)
LIFT STATION**

**GALAXY PARK
LIFT STATION
(CSA-1)**

LEGEND

- **SEWAGE LIFT STATION**
- **SEWAGE LIFT STATION TRIBUTARY AREA**
- **SEWAGE TREATMENT PLANT**

NIPOMO COMMUNITY SERVICES DISTRICT
 1995 WATER AND SEWER MASTER PLAN
 EXISTING SEWER SYSTEM SCHEMATIC
 BOYLE ENGINEERING CORPORATION
 VT-N04-100-01 NOV. 1995 FIGURE 6

N.T.S.

2.5 Fire Flow Requirements

It is often the case that meeting fire flow requirements governs the sizing of a community's water distribution system. Thus, it is important to establish realistic fire flow requirements for both existing and future development. The California Department of Forestry provides fire protection services to Nipomo. CDF was contacted for information regarding fire flow requirements throughout Nipomo. CDF reportedly uses the Uniform Fire Code and the Insurance Services Organization guidelines to establish flow requirements.

ISO guidelines state recommended flows based on such factors as structure size, construction type, proximity to adjacent structures, storage of combustible materials, and other factors. Neither ISO guidelines nor CDF records are reduced to specific flow requirements per land use categories.

Planning the water system, however, requires establishment of fire protection guidelines throughout the service area. To establish such planning guidelines for Nipomo, fire flow criteria for neighboring communities was referenced.

Table 5 summarizes recommended fire flow requirements for various types of developments. Water system improvements proposed herein are based on meeting a 1,000 gpm residential fire demand at a minimum residual pressure of 20 psi. Similarly, the system's ability to meet a 3,000 gpm commercial and public facility fire demand at 20 psi minimum pressure was assessed.

**TABLE 5
FIRE FLOW CRITERIA**

ZONING	REQ. FLOW AT 20 PSI MINIMUM PRESSURE (gpm)	DURATION (hours)	NUMBER OF HYDRANTS FLOWING
Residential Rural	1,000	2	1
Residential Suburban	1,000	2	1
Res. Single Family	1,000	2	1
Summit Station	1,000	2	1
Res. Multiple Family	1,500	2	1
Commercial Retail	3,000	3	2
Commercial Service	3,000	3	2
Office & Professional	1,500	2	1
Public Facility	3,000	3	2

2.6 Peaking Factors

Water

In the preceding sections, water demand and sewage loading were described principally in terms of average annual flows. However, both water demand and sewage flow rates vary throughout the year and throughout the day.

Water demand fluctuates according to the time of year, time of day, level of tourism, and other factors. Seasonal demands are typically the highest in the months of July and August, and the lowest in the months of January and February as shown in **Figure 2**. It is not uncommon for the District to experience a “hot spell” within the summer months resulting in many consecutive days of high water use. Sizing the system to accommodate these “hot spells” is essential in maintaining system reliability.

For Nipomo, average annual water demand is approximately 1,065 gpm, including Black Lake. Average summertime demand is estimated to be 1,370 gpm. For purposes of assessing distribution system needs, the average summertime demands were simulated as the base demand condition.

Two demand conditions typically of interest when sizing components of water systems are the demand during the maximum usage day of the year (referred to as the maximum day demand) and the demand during the maximum usage hour of the day (referred to as the peak hour demand). The District's distribution system should also be capable of supplying the maximum day demand plus fire flow conditions at the minimum pressures stated in **Table 4**.

Purveyors typically do not keep daily or hourly water demand records. Nipomo is typical in this regard.

Based on system assessments in communities with similar populations, land use, and climate, maximum day demand is typically twice the average annual demand. Similarly, peak hourly demand has been found to be twice the maximum day demand.

These typical peaking factors were used to assess Nipomo's water system. For existing water demands, peaking factors are as follows:

Average Annual Demand	1,065 gpm (Main system)
Average Summertime Demand	1,370 gpm (Main system)
Maximum Day Demand	2.0 times Summertime Demand (2,740 gpm)
Peak Hourly Demand	4.0 times Summertime Demand (5,480 gpm)

Sewer

Regarding sewage flows, three flow conditions are of interest in sizing components of the wastewater collection system:

1. **Average Dry Weather Flow** - ADWF refers to the average annual flow conditions in the system which generally occur during the summer at mid-day (i.e. not peak morning or evening flow conditions).
2. **Peak Dry Weather Flow** - PDWF refers to the peak anticipated daily flow which generally occurs in the morning or evening hours at which times residential flows reach their maximum. PDWF conditions do not include an inflow/infiltration component as would be expected during periods of rainfall.
3. **Peak Wet Weather Flow** - PWWF is the maximum anticipated flow rate for a given system. PWWF refers to the peak anticipated daily flow which coincides with the occurrence of inflow and infiltration into the system. Inflow and infiltration is comprised of rainfall and runoff that enters the system through manholes, infiltration into gravity collectors resulting from high ground water, and illegal storm drain connections to the sanitary sewer system.

The District maintains records of monthly high flows as measured at the main treatment plant. For the 1993/95 period, the highest monthly flow recorded at the plant was 0.606 MGD, which is 1.93 times the average recorded monthly flow rate. This was compared to peaking factors referenced in other wastewater collection system assessments.

In general, small collection systems experience wider flow variations than large systems. For example, smaller tributary areas such as residential lift station tributary areas experience high flows in the mornings and early evenings. The collection system must be sized to handle peak flows, particularly peak flows that coincide with incidents of inflow and infiltration.

Sewage loading peaking factors for Nipomo are estimated to be:

Peak Dry Weather Flow	2.0 times ADWF (as compared to peak monthly flow of 1.93)
Peak Wet Weather Flow	3.0 times ADWF

3.0 Existing Water System

3.1 Overview

A schematic of the District water system is shown on **Figure 5**. The water system is a single pressure zone system consisting of:

- Two storage sites (Twin Tanks and the Standpipe) each location with 1 million gallon capacity,
- 6 active wells, and
- A distribution system comprised of 6-, 8-, 10-, 12-, and 16-inch diameter pipes.

The Black Lake development is currently served by a separate water system consisting of:

- One 400,000 gallon storage tank accompanied by a 3,000 gallon hydropneumatic tank and pumping system,
- 2 active wells, and
- A distribution system comprised of 6- and 8-inch diameter pipes.

A significant feature of the existing water distribution system is the fact that the main zone and the Black Lake system currently are not intertied. Further, the central business district and the outlying residential rural areas of the District are separated by Highway 101 and Nipomo Creek. A single 10-inch diameter waterline along Tefft Street connects the two areas of the system.

Also, a new 16-inch diameter pipeline was recently constructed to allow water to be pumped from the Via Concha well to residential areas along Camino Caballo.

As is shown in **Figure 5**, the Twin Tanks are located at the easternmost portion of the District's water system near North Dana Foothill Road. The main downtown area of Nipomo is served by a 10-inch diameter pipe from the Twin Tanks in addition to the Church Well and the Savage Well, which is currently off-line.

The Standpipe is located off of Hetrick Avenue north of Cherokee Place. This area of the system is also supplied by the Bevington, Eureka, Olympic, Omiya, and Via Concha wells as shown in **Figure 5**.

Regarding existing water system operations, it was noted that the Standpipe plays a key role in the hydraulic operations of the system. It fills first because it is closest to the District's largest wells and its water level can drop relatively rapidly at an average rate of emptying. Further, the Standpipe directly influences the available pressure in the Summit Station area. For example, if the Standpipe drops up to one-third, static pressures in Summit Station drop below 40 psi. Operationally, this means that operators try to keep the Standpipe full rather than allowing the tank level to fluctuate throughout the day to meet daytime demands.

3.2 Sources of Supply

Ground water is currently the sole source of water to the District. Historic production from each of the District's wells is tabulated in **Appendix A**.

There are currently six active wells used by the District for water delivery to the main system. The District has three wells that are on standby, and one that is not in operation due to water quality concerns. The Black Lake development area has two wells that support that system. **Table 6** lists data for existing wells.

PG&E tests performed in 1994 and 1995 indicate the flow rate, pumping water level, and motor efficiency for test conditions at each well. In general, pumps with efficiencies greater than approximately 65 percent are considered to be in "good" condition by PG&E. PG&E's pump tests indicate that all of the well pumps operate at efficiencies less than 65 percent.

Pumps with efficiencies in the 40 percent to 65 percent range are considered by PG&E to be in "fair to poor" condition. Pumps with efficiencies in this range included Black Lake #3, Bevington, Eureka, Olympic, and Omiya. Pumps with efficiencies of less than 40 percent were considered in "poor" condition. The Church Well pump fell into this category. PG&E test data was unavailable for the Black Lake #4 and Savage wells.

Upgrading the low efficiency pumps can result in a significant savings in power costs. For example, a PG&E test report indicated that Eureka Well had an efficiency of 62.5 percent. In addition, the

test report stated that improving this efficiency by approximately 6.5 percent could result in an annual power saving of over \$8,200.

Recommendations for well pump and motor replacements are included in Section 11.

Further, the Church and Savage Wells are located near Nipomo Creek but not so close that the provisions of the Surface Water Treatment Rule apply.

**TABLE 6
EXISTING WELL DATA**

WELL	FLOW RANGE (1) (gpm)	MEDIAN FLOW (1) (gpm)	TYPICAL DEPTH TO GROUND WATER (feet)(1)	DATE DRILLED	PUMP MODEL	MOTOR TYPE	WELL STATUS
Bevington	392-410	401	317	6/85	Peerless Turbine	General Electric 100 HP	Active
Church	158	158	77	6/85	N/A	N/A 30 HP	Active
Eureka	780-820	800	148	6/79	Anderson Turbine	General Electric 200 HP	Active
Olympic	140-150	145	287	6/85	N/A	N/A 40 HP	Active
Omiya	120	120	312	6/88	N/A Submersible	N/A 30 HP	Active
Savage	125	125	74	6/88	N/A	N/A	Off-Line
Via Concha	703	703	286	N/A	Peerless Turbine	US Motors 150 HP	Active
Dana #1	N/A	N/A	N/A	N/A	N/A	N/A	Stand By
Dana #2	N/A	N/A	N/A	N/A	N/A	N/A	Stand By
Hermreck	N/A	N/A	N/A	N/A	N/A	N/A	Stand By
Black Lake #3	350	350	285	N/A	Peerless	N/A 50 HP	Active
Black Lake #4	400	400	N/A	N/A	N/A	N/A	N/A

N/A = Not Available

(1) Based on PG&E' pump tests performed 1990 and 1995

3.3 Storage Facilities

Two storage facilities currently serve the District's water system: the Twin Tanks, and the Standpipe. These reservoirs provide daily regulatory, fire, and emergency storage.

The Twin Tanks consists of two 0.5 million gallon tanks, with diameters of 30 feet and heights of 24 feet. The reservoirs have a high water elevation of approximately 548 feet. A 10-inch diameter inlet/outlet line along Tefft Street connects the Twin Tanks to the distribution system.

The Standpipe is a 1.0 million gallon welded steel tank, with a diameter of 44 feet and a height of 90 feet. The reservoir has a high water elevation of approximately 548 feet. A 16-inch diameter inlet/outlet line along Hetrick Avenue connects the Standpipe to the distribution system.

3.4 Distribution and Transmission Pipelines

Plate 1 illustrates the existing water distribution and transmission system. The main distribution pipelines in the District are 8-inch diameter, with some 10-inch and 16-inch diameter pipelines. Pipelines extended from the east along Tefft Street, loop along Juniper Street, Division Street, Orchard and Pomeroy Roads. The 10-inch diameter pipeline extends to Hetrick Avenue which ties into the Standpipe. In addition, the 10-inch loops via Osage Road and Ridge Road back to Hetrick Avenue. The system also relies on an 8-inch diameter loop in the northern part of the system to provide water service to residences.

Overall, the water system is well-looped without numerous lengthy dead end pipes. One notable feature is that the main zone and the Black Lake system are not intertied. Also, the central business district and the outlying residential rural areas of the District are separated by Highway 101 and Nipomo Creek. A single 10-inch diameter waterline along Tefft Street connects the two areas of the system.

The material of existing pipelines within the District consist of asbestos cement, cast iron, ductile iron, polyvinyl chloride, and steel. The majority of the pipelines are asbestos cement and polyvinyl chloride.

4.0 Existing Sewer System

4.1 Overview

Approximately 40% of the water service area is connected to the Nipomo community sewer system. The sewage collection system consists primarily of a 10- to 12-inch diameter gravity line which extends along both sides of Highway 101 from Juniper Street south to the main wastewater treatment plant. **Figure 6** illustrates principal features of the sewage collection system.

The District operates seven sewer lift stations in addition to the lift station at the main treatment plant. Wastewater from two areas operated by the County of San Luis Obispo is also introduced into the District's sewer system.

As was previously mentioned, the Black Lake development is on a separate sewage collection and treatment system which is operated by the District.

4.2 Lift Stations

The District's sewer system includes eight lift stations that pump sewage to the main wastewater treatment plant. There is an additional lift station located at the treatment plant headworks plus two lift stations that are operated by the County of San Luis Obispo.

The lift stations and capacities are as listed in **Table 7**. The location of each lift station is shown in **Figure 6**.

LIFT STATION	CAPACITY (gpm)	HEAD (ft)	FORCE MAIN DIA. (in.)	ESTIMATED ADWF/PWWF (gpm)
Main Plant	630	21	6	45/135
Tefft Street	315	65	6	83/250
Black Lake Mobile Home Park	175	54	4	21/65
Nipomo Palms	175	58	4	16/50
North Oak Glen	175	29	4	5/15
Bracken	110	70	4	2/6
La Mirada	190	41	4	11/35
Gardenia	110	55	4	2/6
Woodgreen ² (Black Lake)	175	60	4	N/A
Peoples Self Help Housing (CSA 1) ³	210	-	-	171/515
Galaxy Park ³ (CSA 1)	310	115	6	37/110

1 Information provided by District staff.

2 Part of separate Black Lake sewage system.

3 Peoples Self Help Housing and Galaxy Park Pump Stations are operated by the County and pump to the District's sewage collection system.

All lift stations are equipped with two pumps with each pump capable of pumping the full capacity of the lift station.

4.3 Collection System

The District's sewer system is comprised of approximately 55,000 feet of pipe, including 12-inch diameter gravity collectors. All of the sewer system is polyvinyl chloride sewer pipe and is reportedly in good condition.

The majority of the lift station tributary areas (**Figure 6**) are comprised of 6- and 8-inch diameter PVC gravity collectors. The main collection system is comprised of larger diameter PVC, which takes flow by gravity to the treatment plant in the southern part of the District service area.

Force mains within the system are 4-inch and 6-inch diameter.

The District's sewer system also has approximately 200 sewer access manholes. The sewer system is currently without an operating flow metering in place.

5.0 Computer Modeling

5.1 Model Development

Hydraulic network computer models of the District's water and sewer systems were developed as part of this master plan to aid in analyzing the systems' needs and capabilities. Node and pipe maps for each of the models were submitted to the District in June 1995. Computer diskettes containing model input files will be transmitted with the final report. Background information on each of the models follow.

Water Computer Model

The Boyle developed computer software, BoyleNET, was used to model the District's water system. BoyleNET uses the Hazen-Williams formula as the basis for calculating headloss. Input to the model primarily consists of pipes and "nodes". Pipes are described by the length, size, and Hazen-Williams 'C' factor (or friction coefficient). Nodes are described by elevation and demand. Other water system facilities such as tanks and wells were modeled. Pump curves were available for each well with the exception of the Olympic Well, which was modeled as a fixed supply into the network.

An AutoCAD base map of the District, including streets and lot boundaries, was provided by the District. This was used in laying out the pipeline network and in estimating the demand area for each water system node.

The input file for the District's existing water system is included in **Appendix B**.

The computer model is a tool by which the hydraulic performance of the system can be simulated under various conditions. The District's existing system model was used to assess system adequacy to meet existing and projected demands.

Sewer Computer Model

Similar to the water system, a computer model was also prepared for the sewer system. Using Boyle developed software, BoyleSWAN, the characteristics of the existing sewage collection system were simulated on the computer.

Sewage collectors were described in terms of diameter, length, and roughness coefficient (Mannings 'n' value). Manholes were described in terms of invert elevation.

Sewage loading was estimated for each manhole based on the number of residential units or land use acreage tributary to each reach. The sewage duty factors listed in **Table 2** formed the basis for estimated loading.

Each lift station tributary area was assessed separately. The main gravity collection system to the treatment plant was assessed with fixed flows input to simulate the operation of lift stations.

Appendix B contains input files for the existing sewage collection system.

5.2 Model Calibration

After the computer models were developed, a series of calibration runs were performed to determine how closely the computer models simulate actual field conditions.

For the water system, the District's operations staff conducted a series of fire hydrant tests during June 1995. Fifteen fire hydrants were tested at various locations throughout the system. For each test, the static pressure was measured with a pressure gauge at a water service or other hydrant close to the test hydrant. Then the test hydrant was fit with a pitot measuring device and opened to full flow. At full flow, the pitot measurement and the residual pressure (taken at the same location as the static pressure) were read simultaneously. District staff was also asked to record tank levels and well status at the time of each hydrant test.

The existing demands, as estimated in Section 2.0, were used to simulate demand conditions. The demands were adjusted based on the

time of day and weather during which the tests were taken. Static conditions were first modeled and compared to field measured pressures. The assumed demands were then adjusted to achieve reasonable agreement with the field measurements. Once agreement was achieved, the field measured fire flow was modeled. If the model-computed residual was within five pounds per square inch (psi) of the field measured pressure, then the model was considered in reasonable agreement with the field measurement. Overall agreement with the field measurement is an indication that the computer model is calibrated and is modeling the actual conditions of the system with a reasonable degree of accuracy.

The results of the fire hydrant tests and calibration runs are included in **Appendix C**. Agreement within 5 psi was achieved at the majority of the sites tested. There were several locations where computer simulated pressures varied from field measurements. In these cases, hydrant tests were re-run.

The results of the water calibration exercise confirmed that the computer model is simulating existing water system performance within a reasonable degree of accuracy. Estimates of roughness coefficients and pipe size and layouts simulated in the model are considered representative of the Nipomo system.

Regarding the sewer system computer model, no flow metering was authorized to compare actual rates of flow to estimates. Lift station run time estimates were compared to estimated tributary area flows to achieve a reasonable degree of accuracy for each lift station.

Sewer model "calibration" consisted of an interview with District operations staff to confirm areas of projected capacity problems to staff observation. Computer projections of capacity problems were confirmed by staff observations.

The District may consider temporary flow metering during the rainy season to confirm the peaking factors estimated herein.

6.0 Design Criteria

This section summarizes the criteria that was used as a basis for analyzing the water and sewer systems' adequacy to meet existing and projected demands.

6.1 Water System Design Criteria

Design criteria for the water system is:

Supply facilities should be sized to meet maximum day demand with the second largest well out of service.

Storage capacity is required to provide daily regulatory storage, fire storage, and emergency storage. The following criteria was used to estimate these volume requirements:

- **Regulatory storage** is the volume of storage recommended to meet peak daily demands in excess of what supply is capable of producing. Supply facilities are sized to supply the maximum day demand (MDD) as stated above. For Nipomo, recommended regulatory storage volume is "maximum daytime demand" (i.e. 1.5 x MDD) less the available rate of supply over a 14-hour demand period, as follows:

$$\text{Regulatory Storage Volume} = (1.5 - 1.0) \times (\text{MDD}) \times 14 \text{ hrs.}$$

- **Emergency storage** is the volume of storage recommended to ensure ongoing supply in the event of a water supply emergency. Emergency planning guidelines suggest that water facilities should be capable of sustaining basic sanitary needs for 72-hours. Thus, emergency storage for Nipomo has been estimated as the volume of water needed to provide a minimum of 50 gpcd for 72 hours.
- **Fire storage** is the volume of storage recommended to meet fire flow requirements for the duration indicated by the fire protection agency. The fire flow requirements listed on **Table 5** form the basis for the fire storage requirements in the District water service area. The highest requirement governs the fire storage requirements in that particular zone.

To analyze the adequacy of the **distribution pipelines** the following criteria was used:

- During **average day demand**, a minimum pressure of 40 psi and flow velocities less than 5 feet per second (fps) should be maintained. Maximum desirable static pressure is 100 psi.
- During **peak hour demand** conditions, a minimum system pressure of 30 psi and flow velocities in pipelines of less than 10 feet per second should be maintained.
- During **fire flow** conditions, the system should be sized to accommodate a minimum residual pressure of 20 psi at the flowing hydrant, and flow velocities in pipelines of less than 10 feet per second, at maximum day demand conditions.

The resistance of flow in a pipeline is represented by the **Hazen Williams 'C' coefficient**. 'C' values characterize the friction losses associated with the interior pipe wall and are a function of pipeline material, condition, and age. For pipelines with identical diameters and lengths, the lower the 'C' value, the higher the headloss. 'C' values were estimated based on the following criteria:

- All existing pipes: C = 125
- All proposed pipes: C = 135

These estimates of friction coefficients were used in calibrating the water computer model and found to be reasonable estimates for Nipomo.

Other design criteria utilized in assessing the District's water system is:

- Provide fixed emergency power generators for critical wells, particularly if seeking credit for emergency storage volume.
- Minimum new distribution main diameter 8-inches; 6-inch minimum in cul-de-sac streets that do not serve a fire hydrant.
- Replace all 4-inch diameter waterlines with 6-inch diameter lines or larger. Replace all existing steel pipelines with PVC or other material.
- Establish a goal of limiting unaccounted for water to 15% of production.

6.2 Sewer System Design Criteria

Regarding flow velocities, 2 feet per second minimum velocity should be maintained under peak dry weather flow conditions; 10 feet per second maximum at peak wet weather flow conditions.

Permissible flow depth in terms of depth (d) relative to pipe diameter (D):

- $d/D = 0.5$ maximum at average dry weather flow
- $d/D = 0.75$ maximum at peak dry weather flow
- $d/D = 0.9$ maximum at peak wet weather flow

Pipeline **roughness coefficient** 'n' estimated to be 0.011 for existing collectors.

Limit proposed collector and **manhole depth** to reasonable construction limitations (approximately 15 feet deep). Consider installation of a lift station at greater depths.

Lift stations must have sufficient capacity to handle the peak wet weather flow condition. Small lift stations (100 gpm and less) to be equipped with two pumps. Larger lift stations to be equipped with three pumps. In all cases, lift stations should be capable of handling peak wet weather flow with one pump out of service.

Force mains should be sized to maintain 3 to 7 feet per second flow velocity.

Wet well volumes should be sized to minimize pump start/stops while avoiding septic conditions associated with infrequent purging.

Other design criteria used in assessing the District's sewer system are:

- Provide fixed emergency power generators for lift stations, particularly if alarm system is lacking or if consequences of an overflow would be significant.
- Minimum new gravity collector diameter to be 8-inches.
- Eliminate the need for lift stations where practical.
- Provide telemetric controls among lift stations to a control center.

These criteria were applied to the assessment of the existing water and sewer systems and in making recommendations for future system upgrades.

7.0 Ability of Water System to Meet Existing Demands

7.1 Sources of Supply

The design criteria stated in Section 6.0 indicated that sources of supply should be sized to meet maximum day demands with the second largest well out of service. Sources of supply must keep up with maximum demand during a 24-hour period and should have some redundancy, thus the second largest well out of service criteria.

For Nipomo, current maximum day demand, including Black Lake, is estimated to be 2,740 gpm.

The active wells listed in **Table 6** have a total estimated capacity of 2,900 gpm, including Black Lake Wells #3 and #4. Thus, the District needs nearly all active wells to be operable to meet estimated maximum day demand.

The two largest wells are the Eureka Well (800 gpm) and the Via Concha Well (700 gpm). By the supply source criteria stated herein, the District should have an estimated 540 gpm additional well capacity to reliably meet the needs of existing customers.

Another item of note in examining the existing system performance is the fact that the pump curves and pumping water levels given for the District wells indicate that the majority of the well pumps are operating at low efficiencies. The Eureka, Omiya, and Church wells in particular may be operating at low efficiencies. The District is encouraged to re-evaluate proper pump and motor sizing for all of the active wells.

7.2 Storage Facilities

By the criteria stated in Section 6.0, recommended storage volume to meet existing needs, including the Black Lake development, is:

Storage Component	Criteria	Volume Recommended
Regulatory	(1.5 - 1.0) x MDD over 14 hours	1.15 MG
Emergency	50 gpcd for 3 days Population 9,005	1.35 MG
Fire	3,000 gpm for 3 hours	0.54 MG
TOTAL		3.04 MG

The District currently has a total of 2.0 MG of storage in place. Thus, an additional 1.04 MG of storage is recommended to reliably meet the needs of existing customers.

An option to providing additional above-grade storage is to, in a sense, utilize the ground water basin as emergency storage. To do so reliably, natural gas driven engines or fixed emergency power generators should be maintained at key wells to ensure their availability during a prolonged power outage. At least 940 gpm of well capacity would need to be powered in such a way for reliable emergency back-up.

Further, it was noted in our existing system assessment that the Standpipe plays a key role in the hydraulic operations of the system. It fills first because it is closest to the District's largest wells and its water level can drop relatively rapidly at an average rate of emptying. Further, the Standpipe directly influences the available pressure in the Summit Station area. For example, if the Standpipe drops up to one-third, static pressures in Summit Station drop below 40 psi. Operationally, this means that operators try to keep the Standpipe full rather than allowing the tank level to fluctuate throughout the day to meet daytime demands.

This operational sequence at the Standpipe means that the District cannot make full use of the 1.0 MG volume without significantly dropping system pressures to 40 psi and below.

There is no suitable terrain in the vicinity of Summit Station upon which to construct an elevated storage tank of more conventional proportions (1.5 diameter to 1 height). The District could operate the Summit Station area as a separate hydraulic grade zone and provide a booster station with hydropneumatic tank to serve the residences. Approximately 50 residences lie at elevations that pose water pressure problems under the current configuration. The advantages of serving a portion of Summit Station by a separate booster station are that:

- Fluctuations in water pressure could be minimized,
- Overall pressure could be raised to a hydraulic grade of approximately 570 feet such that minimum static pressure would be raised to 50 psi,
- The existing Black Lake hydropneumatic tank could possibly be relocated to service Summit Station, and
- Fluctuations in the elevation of the Standpipe would not significantly influence water pressure at Summit Station.

Disadvantages of installing a separate booster station are:

- Capital and operations cost associated with the operations of a booster station,
- Unacceptable high pressures (100 + psi) in some areas of the boosted zone,
- Increased system complexity (i.e. operation of a two-zone water system), and
- Level fluctuations at the Standpipe would continue to affect other areas in the eastern service area.

Considering these advantages and disadvantages, it is our opinion that construction of a booster station is not warranted to serve the existing 50 properties. The District may wish to re-evaluate this position as additional properties develop in Summit Station.

7.3 Distribution System Assessment

The BoyleNET hydraulic network computer model was used to simulate the ability of the existing distribution system to meet existing needs.

Following the design criteria stated in Section 6.0, a series of modeling runs were made with results as follows:

1. **Average Day Demand** - Average daily demands were modeled with both tank facilities assumed to be three quarters full (540 feet hydraulic grade line) and the Eureka and Bevington wells operating. Average system pressures were approximately 95 psi, with the lowest pressure of 47 psi in the Summit Station area. Pressures exceeded 100 psi in the vicinity of the wells along Willow Road. No deficiencies were noted with regard to meeting average day demand.
2. **Peak Hour Demand** - Peak hourly demands were simulated throughout the system with tanks set at three-fourths full (540 feet HGL) and the Eureka, Bevington, Omiya, Via Concha, and Church wells operating. Average system pressures dropped to approximately 65 psi, with the lowest pressure of 25 psi along Grande Avenue and north of Juniper Street in the vicinity of Trevino Drive. Flow velocities were favorable throughout the system.
3. **Fire Flow Conditions** - A series of maximum day demand plus fire flows were conducted. Overall, the existing system is found to be well laid-out to meet residential fire flow requirements. The exception to this is some of the high elevation areas in Summit Station. A flow of 1,000 gpm at 13 psi is projected at Poppy Lane. Twenty psi minimum is recommended.

Commercial, public facility, and multi-family zoning fire flows presented a different case. Meeting the 3,000 gpm recommended flow in some areas posed a problem. This rate of flow cannot be sustained at the commercial retail property at the intersection of Grande Avenue and Orchard Road. Similarly, improvements would be needed to meet firefighting needs at the school along

Price Street and at the residential multi-family property along Grande Avenue.

In addition to the specific demand conditions stated above, overall system reliability was also assessed. Specifically, the central business district and the outlying residential rural areas of the District are separated by Highway 101 and Nipomo Creek. A single 10-inch diameter waterline along Tefft Street connects the two areas of the system. Additional highway/creek crossings are recommended to improve system reliability as well as to improve distribution.

The Black Lake system inertie is discussed in Section 9.

Recommended improvements to meet existing demands are illustrated on **Plate 1**. A listing of the recommended facilities as well as priorities are included in Section 12.0.

It has been noted that some development throughout the service area consists of structures that lie at a significantly higher elevation than the District's distribution system. For example, a home that rests 15 feet higher than the District's water main will have a static water pressure that is 6 to 7 pounds less than pressure in the main. This has resulted in some pressure complaints and concerns regarding fire fighting.

The District has no control or authority governing building pad elevations. It is therefore recommended that the District continue enforcing its policy of meeting water pressure and fire flow requirements at the main and that owners of structures that lie at higher elevations be alerted to the need to provide private water pumps.

8.0 Ability of Sewer System to Meet Existing Needs

8.1 Lift Stations

Table 7 lists features of the existing lift stations, including estimated average dry weather and peak wet weather flows. Each of the eight lift stations currently operated by the District appear adequate to meet existing sewage flows.

Some of the lift stations appear over-sized to meet existing needs. For example, the Bracken, North Oak Glen, Nipomo Palms, and Gardenia lift stations all appear to have capacities that are far in excess of estimated flows. Operationally, this means that:

1. The wet wells are not permitted to fill and the relatively large pumps run for short periods, or
2. The wet wells are permitted to fill and conditions become septic in the wet well between pump starts. Odor and quality problems result.

In either case, the District should re-evaluate wet well volumes, pump and motor sizes, and on/off levels in the stations listed above.

Section 6.0 listed criteria for lift station design as follows:

- Small stations (up to 100 gpm) should be equipped with two pumps.
- Larger stations should be equipped with three pumps.

In both cases, lift stations should be capable of handling peak wet weather flows with one pump out of service.

The system was also evaluated for the possibility of eliminating one or more existing lift stations. There is an opportunity to eliminate the Nipomo Palms lift station by constructing a gravity line to the southeast. This is discussed as a future system improvement in Section 10.

8.2 Collection System Assessment

The BoyleSWAN sewer model was used to assess the existing collector system capacity. Results of the computer simulations are:

Tributary Area	Results
La Mirada LS	No capacity problems noted
Bracken LS	No capacity problems noted
North Oak Glen LS	No capacity problems noted
Nipomo Palms LS	No capacity problems noted
Gardenia LS	No capacity problems noted
Black Lake Mobile Home Park LS	No capacity problems noted
Tefft Street LS	No capacity problems noted
Main Gravity Zone to the Treatment Plant	Division Street 8" inadequate; Frontage Road 12" from Division Street south inadequate

Overall, the existing collector system has adequate capacity to handle average and peak wastewater flows. The exception to this is an area along Division Street and the Fronage Road as noted above. Capacity problems in this area are proposed to be addressed by routing the CSA 1 lift stations flow through the Nipomo Palms lift station tributary area and constructing new gravity collectors to eliminate the need for the Nipomo Palms lift station. This is illustrated in **Plate 4**.

Regarding the Black Lake collection system, the system was assessed for the projected flows indicated in **Table 4** and found to have adequate collection capacity to handle projected flows. The Black Lake collection and treatment system has been sized for and is intended to serve the Black Lake development only.

9.0 Ability of Water System to Meet Future Demands

9.1 Sources of Supply

Future water demand for build-out within the service area boundary illustrated in **Figure 5 and Plate 2** is estimated to be 2,580 AFY, 50 percent higher than current annual demand. Future maximum day demand is estimated to be 4,140 gpm.

Nipomo's current active wells have an estimated combined capacity of 2,900 gpm, including Black Lake Wells #3 and #4. With the second largest well out of service, available supply is 2,200 gpm.

A new 540 gpm well is recommended to reliably meet the needs of existing consumers, including Black Lake residents. Supplies totaling an additional 1,400 gpm in addition to the recommended 540 gpm are recommended to reliably meet the future needs of the District.

9.2 Distribution and Transmission Pipelines

The water system improvements discussed in Section 8 address the majority of the future distribution system needs. One noteworthy additional system improvements to meet future demands is to construct a new 10-inch diameter transmission main along the Frontage Road from Sandydale Road northwest to Summit Station Road.

Plate 2 illustrates the system improvements recommended to meet future water demands. Recommended facilities to tie in the Black Lake system to the main system are also shown. Further, facilities shown are based on continuing to serve Summit Station off of the main pressure zone and do not reflect facilities needed to install a booster station.

District staff indicated that older, steel waterlines in the area northeast of Highway 101 are in need of replacement. **Plate 2** indicates approximately 4,300' of older, steel lines to be replaced in coming years.

9.3 Storage Facilities

By the criteria stated in Section 6.0, recommended storage volume to meet future water demands, including the Black Lake development, is:

Storage Component	Criteria	Volume Recommended
Regulatory	(1.5 - 1.0) x MDD over 14 hours	1.74 MG
Emergency	50 gpcd for 3 days Population 15,000	2.25 MG
Fire	3,000 gpm for 3 hours	0.54 MG
TOTAL		4.53 MG

The District currently has a total of 2.0 MG of storage in place. Thus, an additional 2.53 MG of storage is recommended to reliably meet the needs of existing and future customers. Additional above-grade storage is recommended to be installed adjacent to the existing Twin Tanks.

An option to providing additional above-grade storage is to, in a sense, utilize the ground water basin as emergency storage. To do so reliably, natural gas driven engines or fixed emergency power generators should be maintained at key wells to ensure their availability during a prolonged power outage. At least 1,550 gpm of well capacity would need to be powered in such a way for reliable emergency back-up.

10.0 Ability of Sewer System to Meet Future Needs

10.1 Lift Stations

As was described in Section 2.0, average daily sewage flow is projected to increase from 0.35 MGD in the main Nipomo system to 1.13 MGD at build-out. Estimated capacities and projected tributary flows to each lift station are listed in **Table 8**.

Lift Station	Current Estimated Capacity (gpm) ¹	Projected Flows - ADWF/PWWF (gpm) ²
La Mirada	190	11 / 33
Bracken	110	6 / 18
North Oakglen	175	30 / 90
Nipomo Palms	175	16 / 48
Gardenia	110	11 / 33
Black Lake Mobile Home Park	175	24 / 72
Tefft Street	315	170 / 510
Proposed Amado Street	N/A	35 / 100
Galaxy Park (CSA 1)	310	100 / 300
Peoples Self Help Housing (CSA 1)	210	17 / 50
Main Gravity Zone to the Treatment Plant	630	370 / 1,110 ³

1 Refer to Table 7

2 Refer to Table 4.

3 Gravity flow only. Excludes allowance for tributary lift station flows.

The tributary areas that correspond to the lift station flows listed above are illustrated on **Plate 3**.

One new lift station is proposed to serve the area shown in **Plate 4**. The proposed Amado Street Lift Station is proposed to serve the residential suburban and agricultural area (based on future conversion to residential zoning) east of Highway 101.

Regarding the Nipomo Palms Lift Station, it is possible to eliminate the lift station by constructing approximately 2,700 feet of 12-inch gravity collector southeast of the lift station to Story Street. The sewer system master plan illustrated in **Plate 4** includes the construction of the replacement gravity lines. Concurrent with the elimination of the Nipomo Palms lift station, the flow from the two CSA 1 lift stations is proposed to be routed through the Beverly Drive residential area. Routing lift station flows in this manner will relieve flows in the Division Street 8-inch collector and along the Frontage Road.

Regarding the Tefft Street Lift Station, District staff has observed that the existing wet well volume is inadequate, particularly to handle flows during power outages. Increased wet well volume or provisions for fixed, emergency power generation are recommended.

10.2 Collection System Capacity

The BoyleSWAN computer model was used to simulate projected wastewater flows throughout the existing collection system. Proposed lift stations and recommendations for capacity upgrades at the Tefft Street Lift Station were simulated.

Again, the only deficiencies noted in the existing collection system was in the gravity collectors that comprise the main zone. Particularly the gravity collectors south of Division Street to the wastewater treatment plant were found to lack capacity for projected flows.

Improvements needed to meet projected community sewer needs are illustrated in **Plate 4**. Local collectors which will be needed as development occurs will follow future street patterns and therefore cannot be accurately illustrated in a master plan.

Further, a question arose regarding sewerage the area between Story Street and Southland Street. There is a depression there which precludes sewerage south toward Southland Street. It appears that the

lower elevation areas will need to be served with a small lift station. Bear in mind that 1"=1,000' scale, 20 foot contour interval mapping was used as the basis for this master plan and that design-level facility plans are not presented herein. More detailed topographic mapping is needed to make specific sewerage recommendations in this area.

11.0 Recommended Improvements

11.1 Estimated Costs and Priorities

Sections 7.0 through 10.0 discussed improvements needed to meet existing and projected water and sewer needs. Recommended improvements are summarized herein and budgetary cost estimates are provided for recommended facilities.

Boyle recommends that the District embark on a capital improvement program as described herein. Recommended improvements are illustrated on **Plates 1, 2, and 4**.

Cost Estimates

Opinions of probable construction cost are included for recommended pipeline construction and other improvements. The actual costs of specific projects may vary depending on many factors such as site conditions, the extent of existing utilities, environmental impact mitigation, and market conditions that are both unknown and not within the control of the District or Boyle.

Pipeline construction costs include materials, excavation, installation, backfill, valves and fittings (water), manholes (sewer), pavement replacement, and traffic control. A 25 percent contingency for design engineering, and permitting is included in these estimates. Right-of-way acquisition costs are *not* included in the estimates.

Pipeline costs, including contingencies, are based on the following unit costs:

Type	Diameter (inches)	Unit Cost (\$/LF)
PVC Waterline - Class 150	8	54
	10	62
	12	67
Gravity Sewer Line	8	60
	10	66
	12	72
	15	85
	18	115
	21	130
Sewer Force Main	4	50
	6	58

The estimated cost to construct additional water storage is \$0.50 per gallon which includes site grading, foundation, tank fabrication, erection, perimeter road, and fence. Sites which require mass grading may more than double this cost. Also, site acquisition costs are not included.

For the proposed Amado Street sewer lift station, a capital cost of \$50,000 is estimated for this station (approximate capacity = 100 gpm).

The unit costs stated above were utilized in **Tables 9 and 10** to estimate the capital cost of recommended system improvements.

Priorities for System Improvements

Improvements recommended to correct water system deficiencies, in particular, are fairly extensive. Over 5 miles of new distribution lines are recommended as well as replacement of inefficient well pumps and construction of additional storage. Priorities have been assigned as follows:

Priority 1: Two additional Nipomo Creek crossings are recommended as first priority system upgrades because of the current lack of redundancy in the distribution system. A \$100,000 budget for well pump replacement is also recommended as a top priority, so that the District can benefit from energy savings.

Priority 2: Paralleling the existing Twin Tank inlet/outlet line is in the second group of priorities. Providing additional storage, augmenting well supply, and completing well pump replacement are also second priority projects.

Priority 3: The final group of projects includes various distribution system upgrades needed to strengthen fire fighting capabilities.

Tables 9 and 10 list recommended water and sewer system improvements to meet existing and projected needs. In all, an estimated \$3.8 million in water and sewer improvements are recommended to meet existing systems deficiencies.

Future water and sewer system improvements are estimated to cost an additional \$3.4 million.

Note that some system improvements will be installed by developers and that not all recommended improvements will need to be financed by the District.

11.2 Additional Recommendations

During the course of working with District staff to compile information for this Master Plan, it was noted that the water meters throughout the Black Lake development have a different unit rating than the rest of the Nipomo system. Black Lake water meters measure in units of gallons while the rest of the system is measured in hundreds of cubic feet.

This difference in meter type has several disadvantages:

- Necessitates additional accounting to bill customers in Black Lake

- Opens up possibility for error in both meter reading and tabulating water usage
- Adds a level of complexity to the water rate structure

We recommend that the Black Lake water meters be replaced with “standard” water meters and that the District consider installing an automatic meter reading system throughout that development.

Estimated Unit Costs:
 8-inch dia waterline \$54 per LF Additional Storage \$0.50
 10-inch dia waterline \$62 per LF per gallon
 12-inch dia waterline \$67 per LF

**TABLE 9
 RECOMMENDED WATER SYSTEM IMPROVEMENTS**

IMPROVEMENTS TO MEET EXISTING NEEDS:				IMPROVEMENTS TO MEET FUTURE NEEDS:			
Improvement	Length (feet)	Diameter (inches)	Estimated Capital Cost	Improvement	Length (feet)	Diameter (inches)	Estimated Capital Cost
Priority 1				Provide additional 1.53 MG storage	-	-	\$765,000
Highway 101 Crossing / Thompson & Sea 10" (Tefft St. Crossing Under Construction)	6,500	10	\$403,000	Black Lake system interties - (3) at \$25,000 each	-	-	\$75,000
Creek/Highway Crossing South of Knotts Street Budget for Well Pump Replacement	3,850	10	\$239,000	Frontage Road main Frontage Road - Juniper to Tefft	5,150	10	\$319,300
Replace Steel Line on W. Dana Street	1,050	8	\$57,000	Connect to proposed Frontage Rd 10"	1,400	8	\$75,600
Replace Steel Line on E. Price Street	1,200	8	\$65,000	Leaf Street - Thompson to Cedarwood	1,000	8	\$54,000
Replace Steel Line at Bennett Street	1,400	8	\$76,000		1,750	8	\$94,500
Replace Steel Line in W. Price/Mallagh	630	8	\$34,000	Cedarwood Bennett Street to new 10"	1,470	8	\$79,380
				Extend Honey Grove to Southland	1,700	8	\$91,800
Subtotal Priority 1 =	14,630		\$974,000	Twilight Lane	1,100	8	\$59,400
Priority 2				Inga Lane	650	8	\$35,100
Install Parallel Inlet/Outlet Line to Twin Tanks	9,800	12	\$657,000	Camino Caballo	1,700	8	\$91,800
Install Additional 1.0 MG Storage Tank	-	-	\$500,000	Hill Street main	1,000	10	\$62,000
Budget for Well Pump Replacement	-	-	\$75,000		1,200	8	\$64,800
Pursue Additional Well Capacity	-	-	\$200,000				
Subtotal Priority 2 =			\$1,432,000	TOTALS =	18,820		\$1,905,500
Priority 3				TO MEET FUTURE NEEDS			
Upgrade on Frontage Road	1,300	10	\$81,000				
Grande Avenue							
Upgrade Frontage Rd. from Summit Station Rd	1,910	8	\$103,000				
Frontage Road Upgrade	4,500	10	\$279,000				
Black Hawk Way	1,100	8	\$59,000				
Upgrade s/ of Grande Stancpipe Tank to Frontage Rd.	150	8	\$8,000				
Loop Along Pomeroy	3,000	8	\$162,000				
Upgrade Along Hill St Loop to Serve Nipomo	5,300	10	\$329,000				
Elementary School Bonita Homes to Orchard (Fir Place)	890	10	\$55,000				
Poppy Lane Upgrade	700	8	\$38,000				
	800	8	\$43,000				
Subtotal Priority 3 =	20,650		\$1,219,000				
TOTALS = TO MEET EXISTING SYSTEM NEEDS	35,280		\$3,625,000				

**TABLE 10
RECOMMENDED SEWER SYSTEM IMPROVEMENTS**

Improvement	Length (feet)	Diameter (Inches)	Estimated Capital Cost
Improvements to Meet Existing Needs:			
Nipomo Palms Lift Station Elimination	2,600	12	\$187,000
Tie CSA 1 Lift Stations over to Nipomo Palms	-	-	\$15,000
Subtotal Existing Needs =	2,600		\$202,000
Improvements to Meet Future Needs:			
Gravity Line Upgrades:			
Oakglen Ave. Upgrade (Freeway Crossing)	1,320	15	\$112,000
	880	15	\$75,000
Frontage Road Upgrade	850	12	\$61,000
	1,050	15	\$89,000
	1,300	18	\$150,000
	1,110	21	\$144,000
Lift Stations:			
Proposed Amado Street Lift Station			
100 gpm Lift Station	-	-	\$50,000
4-inch dia force main	700	4	\$35,000
Tefft Street Lift Station Upgrade	-	-	\$100,000
New Gravity Collectors:			
Orchard Road Collector	2,600	8	\$156,000
Hill Street Collector	1,500	8	\$90,000
Railroad Collector N/ of Tefft Street	1,900	8	\$114,000
Frontage Road N/ of Juniper Street	2,800	8	\$168,000
Story Street	2,800	8	\$168,000
Tie over Pradera Place Septic System	-	-	\$1,500
Southland Street	3,500	8	\$210,000
Camino Caballo	2,500	8	\$150,000
Subtotal Future Needs =	24,810		\$1,495,500
TOTALS TO MEET SEWER SYSTEM NEEDS =			\$1,697,500

Estimated Unit Costs:	
8-inch gravity collector	\$60 per LF
10-inch gravity collector	\$66 per LF
12-inch gravity collector	\$72 per LF
15-inch gravity collector	\$85 per LF
18-inch gravity collector	\$115 per LF
21-inch gravity collector	\$130 per LF
4-inch dia force main	\$50 per LF

APPENDIX A

Water Production Records 1988-1995

NIPOMO CSD
 WATER AND SEMI-MASTER PLAN
 VT-N04-10001, WATERUSE.XLS, CMF 4-28-95

**WATER PRODUCTION RECORDS
 (GALLONS)**

Year	Month	Production (gallons)										UAW	TOTAL CONSUMPTION (gal)	TOTAL PRODUCTION (gal)	Gross Water Usage per Conn. (gal/conn/day)				
		Eureka	Berington	Onyia	Olympic	Savage	Church	Silver	Via Coombs	SUBTOTAL	BLAKE #3					BLAKE #4	SUBTOTAL		
1988	JAN														38	12,056,264	12,056,264	1,333	306
	FEB														67	21,850,300	21,850,300	1,345	580
	MAR														68	21,494,528	21,494,528	1,350	539
	APR														96	31,321,752	31,321,752	1,383	755
	MAY														91	28,600,528	28,600,528	1,386	692
	JUN														105	34,308,516	34,308,516	1,383	827
	JUL														132	43,089,776	43,089,776	1,420	979
	AUG														129	38,366,416	38,366,416	1,432	945
	SEP														119	35,901,008	35,901,008	1,458	884
	OCT														97	28,617,060	28,617,060	1,475	688
	NOV														72	23,582,000	23,582,000	1,479	531
	DEC														60	18,569,848	18,569,848	1,482	428
1989	JAN													1,075	330,494,824	330,494,824	6%		
	FEB													49	14,992,912	14,992,912	1,485	344	
	MAR													57	18,288,600	18,288,600	1,470	453	
	APR													71	20,738,056	20,738,056	1,480	503	
	MAY													96	30,151,132	30,151,132	1,490	700	
	JUN													106	33,104,236	33,104,236	1,514	734	
	JUL													131	41,262,672	41,262,672	1,497	950	
	AUG													179	53,844,316	53,844,316	1,514	1,246	
	SEP													139	41,349,440	41,349,440	1,504	969	
	OCT													125	37,769,512	37,769,512	1,526	889	
	NOV													87	26,693,128	26,693,128	1,542	593	
	DEC													72	21,995,688	21,995,688	1,554	678	
1990	JAN													1,208	369,651,878	369,651,878	6%		
	FEB													62	19,257,260	19,257,260	1,553	422	
	MAR													60	18,930,384	18,930,384	1,593	435	
	APR													70	20,525,868	20,525,868	1,617	456	
	MAY													95	29,862,404	29,862,404	1,644	628	
	JUN													111	34,753,376	34,753,376	1,649	707	
	JUL													126	39,617,820	39,617,820	1,687	809	
	AUG													150	41,838,916	41,838,916	1,678	942	
	SEP													160	49,454,768	49,454,768	1,702	989	
	OCT													124	39,231,652	39,231,652	1,704	787	
	NOV													106	35,028,840	35,028,840	1,708	650	
	DEC													126	40,847,068	40,847,068	1,735	786	
1991	JAN													1,269	395,516,298	395,516,298	4%		
	FEB													77	18,534,892	18,534,892	1,739	467	
	MAR													86	25,163,664	25,163,664	1,749	571	
	APR													58	15,526,236	15,526,236	1,755	347	
	MAY													113	25,127,564	25,127,564	1,742	708	
	JUN													149	42,053,292	42,053,292	1,767	895	
	JUL													173	40,240,156	40,240,156	1,757	1,072	
	AUG													168	42,287,904	42,287,904	1,763	1,004	
	SEP													142	45,759,292	45,759,292	1,773	843	
	OCT													146	39,467,396	39,467,396	1,773	684	
	NOV													136	35,761,890	35,761,890	1,779	604	
	DEC													119	33,575,476	33,575,476	1,789	718	
1992	JAN													90	24,171,620	24,171,620	1,803	527	
	FEB													1,458	366,743,172	366,743,172	1,790	445	
	MAR													76	21,380,000	21,380,000	1,791	449	
	APR													69	22,502,832	22,502,832	1,802	449	
	MAY													64	20,876,000	20,876,000	1,823	374	
	JUN													138	64,512,000	64,512,000	1,823	824	
	JUL													164	34,110,000	34,110,000	1,849	931	
	AUG													159	39,562,000	39,562,000	1,875	921	
	SEP													156	47,493,000	47,493,000	1,917	857	
	OCT													169	50,797,000	50,797,000	1,917	928	
	NOV													145	48,481,000	48,481,000	1,917	822	
	DEC													130	51,007,000	51,007,000	1,917	710	
1993	JAN													110	16,488,000	16,488,000	1,917	621	
	FEB													106	30,353,000	30,353,000	1,917	581	

WATERUSE.XLS

Year	Subtotal	286,212,300	124,750,260	27,470,732	33,535,344	6,980,740	4,216,520	935,748	0	484,101,644	0	0	0	484,101,644	1,486	446,796,000	1,371	6%	
1993																			
JAN	133,144	14,302,508	2,395,644	417,394	1,334,432	417,394	1,095,072	0	0	19,678,394	507,000	2,057,000	2,564,000	22,242,384	66	15,600,000	48	2,516	285
FEB	1,468,324	13,334,596	2,153,482	506,396	858,704	506,396	858,704	0	0	18,321,512	263,000	1,224,000	1,467,000	18,808,512	61	17,500,000	54	2,516	281
MAR	9,925,960	11,729,388	2,107,684	2,307,560	18,700	18,700	867,216	0	0	26,756,708	0	0	0	26,756,708	52	21,700,000	67	2,516	343
APR	31,052,472	5,275,384	1,267,960	3,024,912	3,740	3,740	513,876	0	0	41,142,244	606,000	6,451,000	7,057,000	48,199,244	148	31,800,000	97	2,516	639
MAY	36,654,992	11,424,204	962,872	2,914,208	536,316	536,316	822,052	0	0	53,334,644	1,891,000	7,185,000	9,075,000	62,410,644	192	43,800,000	134	2,516	800
JUN	33,656,260	12,840,168	3,609,488	2,809,488	904,332	270,776	2,675,596	0	0	56,395,460	2,204,000	7,289,000	9,493,000	65,888,460	202	42,700,000	131	2,516	873
JUL	34,260,644	13,213,420	3,081,012	2,321,044	270,776	270,776	1,539,384	0	0	54,686,280	2,379,000	7,431,000	9,810,000	64,496,280	198	50,100,000	154	2,516	827
AUG	36,238,356	12,551,440	1,475,056	1,649,056	368,016	0	1,832,600	0	0	53,307,716	2,024,000	7,047,000	9,071,000	62,378,716	191	49,900,000	153	2,516	800
SEP	35,247,256	6,902,052	2,028,584	1,303,108	0	0	1,832,600	0	0	48,710,588	1,273,000	6,895,000	8,168,000	56,878,588	175	12,100,000	37	2,516	754
OCT	29,114,404	7,846,520	2,178,176	790,636	178,772	0	526,592	0	0	40,635,100	1,919,000	4,837,000	6,756,000	47,391,100	145	45,900,000	141	2,516	608
NOV	25,171,696	5,149,232	1,263,372	937,992	103,972	103,972	1,031,492	0	0	33,657,756	5,857,000	0	5,857,000	39,514,756	121	21,200,000	85	2,516	524
DEC	23,463,264	0	35,904	1,396,524	82,280	82,280	1,226,720	0	0	26,204,692	1,702,000	2,807,000	4,509,000	30,713,692	94	26,300,000	81	2,516	394
1994	296,396,772	115,972,912	22,474,652	20,868,878	3,390,694	0	13,615,096	0	0	472,831,094	20,625,000	53,223,000	73,846,000	546,679,094	1,679	378,400,000	1,161	31%	421
JAN	24,838,088	0	598,640	2,034,000	10,472	10,472	1,319,256	0	0	28,710,456	66,000	4,865,000	4,933,000	33,643,456	103	22,900,000	70	2,514	432
FEB	14,186,568	0	1,662,520	2,661,000	0	0	1,136,212	0	0	20,146,300	0	2,700,000	2,700,000	22,846,300	70	20,400,000	83	2,514	325
MAR	14,233,692	11,851,312	1,659,000	866,932	0	0	866,932	0	0	29,125,936	1,454,000	4,176,000	5,632,000	34,757,936	107	20,400,000	83	2,514	446
APR	27,530,688	6,283,200	882,000	375,000	0	0	679,932	0	0	35,751,020	213,000	6,897,000	6,910,000	42,661,020	131	30,800,000	94	2,514	566
MAY	26,087,400	13,740,012	2,098,000	2,899,000	0	0	3,225,376	0	0	41,559,988	646,000	6,861,000	7,507,000	49,066,988	151	30,500,000	94	2,514	630
JUN	31,530,444	16,473,204	5,697,000	915,000	0	0	1,413,720	0	2,822,204	54,603,380	1,963,000	7,412,000	9,375,000	63,978,380	196	56,600,000	174	2,514	848
JUL	37,110,524	16,473,204	5,697,000	915,000	0	0	580,448	0	0	60,770,176	2,683,000	7,721,000	10,404,000	71,174,176	218	46,300,000	142	2,514	913
AUG	34,790,976	16,693,812	3,696,000	2,358,000	0	0	1,284,316	0	0	59,123,104	2,521,000	7,750,000	10,278,000	69,402,104	213	69,500,000	213	2,514	891
SEP	34,541,892	12,693,916	635,000	1,063,000	0	0	217,668	0	0	48,893,808	2,035,000	7,079,000	9,114,000	58,007,808	178	46,300,000	142	2,514	769
OCT	30,566,272	3,452,768	2,594,000	3,067,000	0	0	248,336	0	248,336	40,146,044	460,000	6,857,000	7,417,000	47,563,044	146	37,400,000	115	2,514	610
NOV	25,684,540	1,712,172	485,000	526,000	0	0	154,836	0	154,836	28,762,546	285,000	4,896,000	4,951,000	33,713,546	103	34,800,000	107	2,514	447
DEC	3,312,892	17,339,388	1,666,000	4,860,000	0	0	728,552	0	0	27,926,832	5,000	4,875,000	4,860,000	32,806,832	101	29,900,000	92	2,514	411
1995	306,614,176	105,375,996	25,165,160	23,676,000	10,472	11,452,412	0	0	3,225,376	475,519,592	12,313,000	71,799,000	84,102,000	559,021,592	1,719	452,000,000	1,367	19%	421
JAN	10,422,632	1,735,360	684,000	4,795,000	0	0	1,217,744	0	1,309,000	20,163,736	0	2,085,000	2,085,000	22,248,736	68	0	0	0	0
FEB	16,923,500	61,336	0	5,536,000	0	0	32,164	0	32,164	22,553,000	0	3,340,000	3,340,000	25,893,000	79	0	0	0	0
MAR	9,975,328	11,402,512	1,273,000	1,791,000	0	0	0	0	10,472	24,452,312	507,000	2,696,000	3,205,000	27,657,312	85	0	0	0	0
APR																			
MAY																			
JUN																			

75,799,048

Year	Subtotal	450,047,104	1,391	394,372,024	1,210	12%
1994						
1995						
1996						
1997						
1998						
1999						
2000						
2001						
2002						
2003						
2004						
2005						
2006						
2007						
2008						
2009						
2010						
2011						
2012						
2013						
2014						
2015						
2016						
2017						
2018						
2019						
2020						
2021						
2022						
2023						
2024						
2025						

Source: Jan 88 thru Jun 91 - Data sheets provided by Nipomo CSD titled "SLO County Engineering Dept. Water Usage."
 Jul 91 thru Mar 95 - Production records provided on Nipomo CSD data forms. Consumption data taken from Dept. of Water Resources "Public Water System Statistics" form.
 No. of service connections taken from above references. Water usage per connection based on production records.

APPENDIX B

Input Files for Water and Sewer Models

* FILE NAME NIPLOOP.DTA 11/3/95
 * EXISTING NIPOMO CSD WATER DISTRIBUTION SYSTEM, CURRENT DEMANDS. UPGRADES
 * RECOMMENDED TO CORRECT EXISTING DEFICIENCIES INCLUDED.
 * THIS IS THE FINAL FILE FOR THE EXISTING SYSTEM

NEW c:\engr\net\nip.wrk
 OUTPUT c:\engr\net\niploop.out
 TITLE

NIPOMO WATER MASTER PLAN VT-N04-100-01 CMF/JAL 8/26/95

BASE MODEL

UNITS 0 0 0 0 0 0 0
 FACTORS 2.0 1.000
 LIMITS 50 1.000 0.50 5.00 0.0 15.0 20.0 125.0 1918.0 50
 LINES 80

UNKNOWN

101	541.6										* TWIN TANKS
199	540										* STANDPIPE
178	-15	1									* EUREKA WELL PUMP
181	-10.2	2									* BEVINGTON WELL PUMP
185	23	3									* OMIYA WELL PUMP
169	-65	5									* VIA CONCHA WELL PUMP
244	222	4									* CHURCH WELL PUMP

CHECK VALVES

BOOSTER PUMPS

PRV

PUMP CURVE

1	0	990	400	910	650	840	850	740	1020	680	* EUREKA
2	0	875	200	875	300	830	416	677	450	600	* BEVINGTON
3	0	952	40	924	80	826	100	749	120	630	* OMIYA
4	0	774	100	608	200	440	225	391	250	340	* CHURCH
5	0	936	200	888	400	856	700	696	800	576	* VIA CONCHA

PIPES

101	101	102	5610	10	125
102	102	103	1560	10	125
103	103	104	510	10	125
104	104	105	520	10	125
105	105	106	350	10	125
106	106	107	430	10	125
107	107	108	500	10	125
108	108	109	830	10	125
109	109	110	860	10	125
110	110	111	1080	10	125
111	111	112	1030	10	125
112	112	113	830	10	125
113	113	114	320	10	125
114	114	115	200	10	125
115	115	116	60	10	125
116	116	117	250	10	125
117	117	120	360	10	125
118	120	121	30	10	125
119	121	122	260	10	125
120	122	123	340	10	125
121	123	124	25	10	125
122	124	125	440	10	125
123	125	126	10	10	125
124	126	127	320	10	125
125	127	130	190	10	125
126	130	131	30	10	125
127	131	701	330	10	125
128	118	700	200	10	125
129	701	132	120	10	125
130	118	134	700	10	125
131	134	135	1150	10	125
132	135	136	870	10	125
133	136	702	420	10	125
134	137	138	800	10	125
135	138	139	710	10	125
136	139	140	710	10	125
137	109	141	1340	10	125
138	141	142	490	10	125
139	142	143	620	10	125
140	143	144	530	10	125
141	144	145	270	10	125
142	145	146	510	10	125
143	146	147	340	10	125
144	147	150	250	10	125
145	150	151	470	10	125
146	151	140	440	10	125

147	140	152	760	10	125	225	229	240	370	6	125
148	152	153	700	10	125	226	230	231	430	6	125
149	153	154	540	10	125	227	231	241	270	6	125
150	154	155	160	10	125	228	231	232	430	6	125
151	155	168	700	10	125	229	232	242	270	6	125
152	156	157	650	10	125	230	232	233	450	6	125
153	157	158	630	10	125	231	233	247	290	6	125
154	158	159	25	10	125	232	233	234	70	6	125
155	159	160	650	10	125	233	234	235	520	6	125
156	160	161	40	10	125	234	235	236	550	6	125
157	161	162	510	10	125	235	236	237	70	6	125
158	162	163	80	10	125	236	237	255	200	6	125
159	163	164	370	10	125	237	255	256	600	6	125
160	164	165	240	10	125	238	255	257	150	6	125
161	165	166	150	10	125	239	257	258	520	8	125
162	166	167	510	10	125	240	240	258	370	8	125
163	167	170	370	10	125	241	258	250	370	8	125
164	170	171	2160	16	125	242	241	242	420	6	125
165	171	172	3650	16	125	243	242	218	150	6	125
166	172	173	1800	16	125	244	244	243	89	8	125
167	173	169	1700	12	125	245	243	218	750	8	125
168	174	175	900	10	125	246	242	245	380	6	125
169	174	176	900	10	125	247	246	247	80	8	125
170	178	177	198	10	125	248	247	249	880	8	125
171	177	176	5974	10	125	249	246	248	280	8	125
172	176	175	10	10	125	250	248	249	520	8	125
173	175	179	1130	10	125	251	249	219	650	8	125
174	181	180	335.2	8	125	252	219	250	500	8	125
175	180	179	200	10	125	253	250	254	350	8	125
176	179	182	5110	10	125	254	248	251	430	8	125
177	185	184	357	8	125	255	251	252	490	8	125
178	184	183	250	8	125	256	252	253	590	8	125
179	183	182	10	8	125	257	253	254	460	8	125
180	183	187	1260	8	125	258	102	259	1320	8	125
181	183	186	1260	8	125	259	259	265	370	6	125
182	393	395	1350	8	125	260	259	265	370	6	125
183	190	191	40	8	125	261	260	103	370	6	125
184	191	192	870	8	125	262	260	261	300	6	125
185	192	193	1130	10	125	263	261	262	200	6	125
186	193	198	3516	10	125	264	262	104	370	8	125
187	194	195	3480	8	125	265	262	270	370	8	125
188	194	196	950	10	125	266	262	263	450	6	125
189	196	197	500	10	125	267	263	271	370	6	125
190	200	201	500	10	125	268	263	264	430	6	125
191	201	203	1800	10	125	269	264	272	370	6	125
192	202	203	540	10	125	270	265	266	520	6	125
193	203	204	650	10	125	271	265	267	480	6	125
194	204	205	330	8	125	272	267	270	620	6	125
195	205	206	60	8	125	273	270	273	480	8	125
196	206	207	900	8	125	274	270	271	450	6	125
197	207	208	20	8	125	275	271	274	480	6	125
198	208	209	810	8	125	276	271	272	430	6	125
199	209	210	80	8	125	277	272	275	480	6	125
200	210	211	370	8	125	278	273	276	470	6	125
201	211	212	330	8	125	279	273	274	450	6	125
202	212	213	1470	8	125	280	274	277	470	6	125
203	213	214	1450	8	125	281	274	275	430	6	125
204	214	215	1070	8	125	282	275	278	470	6	125
205	215	216	960	8	125	283	276	279	480	8	125
206	216	217	130	8	125	284	276	277	450	6	125
207	217	196	1400	8	125	285	277	278	430	6	125
208	202	220	150	10	125	286	278	281	480	6	125
209	220	221	910	10	125	287	279	283	450	8	125
210	221	154	100	10	125	288	279	280	450	6	125
211	107	222	440	8	125	289	280	282	480	6	125
212	222	223	20	6	125	290	280	281	430	6	125
213	222	230	830	6	125	291	281	282	910	6	125
214	223	230	430	6	125	292	113	284	780	6	125
215	223	224	430	6	125	293	284	285	580	6	125
216	224	225	430	6	125	294	284	268	340	6	125
217	224	231	440	6	125	295	268	285	240	6	125
218	225	226	450	6	125	296	285	286	300	6	125
219	225	232	440	6	125	297	286	287	110	6	125
220	226	227	520	6	125	298	287	290	1980	6	125
221	226	234	370	6	125	299	290	291	250	6	125
222	227	228	520	6	125	300	291	292	530	6	125
223	227	235	370	6	125	301	292	293	360	6	125
224	228	229	370	6	125	302	293	294	200	6	125

303	294	295	510	6	125	381	360	362	260	6	125
304	295	296	530	6	125	382	362	363	400	6	125
305	296	297	860	6	125	383	362	364	660	6	125
306	297	298	1000	6	125	384	357	356	260	6	125
307	298	299	200	6	125	385	356	361	280	6	125
308	299	300	300	8	125	386	361	363	260	6	125
309	300	301	540	8	125	387	363	364	260	6	125
310	301	118	480	8	125	388	150	357	150	6	125
311	299	302	770	6	125	389	145	364	150	6	125
312	302	303	560	6	125	390	353	369	680	6	125
313	303	304	400	6	125	391	144	365	140	6	125
314	303	269	450	6	125	392	365	367	640	6	125
315	269	304	830	6	125	393	365	366	260	6	125
316	304	305	380	6	125	394	366	367	370	6	125
317	305	306	780	6	125	395	366	368	260	6	125
318	112	307	200	8	125	396	367	703	450	6	125
319	307	308	500	8	125	397	143	368	140	6	125
320	306	310	520	6	125	398	153	370	1800	6	125
321	310	309	300	6	125	399	369	370	380	6	125
322	309	116	570	6	125	400	221	371	570	8	125
323	121	311	520	6	125	401	371	372	1000	8	125
324	311	312	670	6	125	402	372	373	1620	8	125
325	312	122	200	6	125	403	373	374	280	8	125
326	123	313	300	6	125	404	374	375	310	8	125
327	313	314	630	6	125	405	375	376	650	8	125
328	126	314	540	6	125	406	374	377	650	8	125
329	127	315	590	6	125	407	376	377	230	8	125
330	131	315	340	6	125	408	376	339	800	6	125
331	315	316	160	6	125	409	339	141	1240	6	125
332	316	317	675	6	125	410	155	380	850	6	125
333	316	320	760	6	125	411	220	380	390	6	125
334	317	320	180	6	125	412	380	381	940	6	125
335	320	133	398	6	125	413	381	157	760	6	125
336	320	301	500	6	125	414	381	203	750	6	125
337	135	321	560	6	125	415	381	382	640	6	125
338	321	322	160	6	125	416	382	158	770	6	125
339	322	323	150	6	125	417	382	383	370	6	125
340	323	324	260	8	125	418	383	204	380	6	125
341	324	326	430	8	125	419	383	206	780	6	125
342	323	325	440	8	125	420	163	384	450	6	125
343	325	326	260	8	125	421	384	385	320	6	125
344	325	327	210	8	125	422	385	386	600	6	125
345	327	132	930	8	125	423	386	208	170	6	125
346	327	130	980	8	125	424	165	378	590	6	125
347	322	328	470	6	125	425	378	387	210	8	125
348	328	329	360	6	125	426	387	388	600	8	125
349	329	330	360	6	125	427	388	210	350	8	125
350	330	331	1020	8	125	428	170	389	180	8	125
351	331	332	360	8	125	429	389	390	430	8	125
352	332	333	210	8	125	430	390	391	590	8	125
353	332	318	800	6	125	431	391	212	310	8	125
354	318	116	550	6	125	432	160	392	720	6	125
355	333	319	200	6	125	433	163	393	780	8	125
356	319	114	900	6	125	434	165	394	620	8	125
357	138	342	660	8	125	435	394	395	550	8	125
358	342	343	330	8	125	436	209	397	1210	6	125
359	343	344	1220	8	125	437	397	400	600	8	125
360	344	345	820	8	125	438	400	207	980	6	125
361	345	346	890	8	125	439	400	401	910	8	125
362	346	347	900	6	125	440	401	205	980	6	125
363	346	338	420	8	125	441	401	201	510	10	125
364	338	347	600	8	125	442	397	402	420	10	125
365	347	330	1970	8	125	443	402	217	470	8	125
366	152	348	520	6	125	444	402	200	1660	10	125
367	348	349	170	6	125	445	190	403	2530	8	125
368	349	350	270	6	125	446	403	404	1230	8	125
369	349	351	600	6	125	447	404	407	2150	8	125
370	350	351	410	6	125	448	404	405	1020	8	125
371	351	352	560	6	125	449	405	406	390	8	125
372	350	352	220	6	125	450	406	407	1270	8	125
373	352	151	130	6	125	451	406	408	1100	8	125
374	348	353	860	6	125	452	405	410	3700	8	125
375	353	354	200	6	125	453	408	704	500	8	125
376	354	357	950	6	125	454	192	411	1630	8	125
377	354	355	150	6	125	455	411	410	80	8	125
378	355	356	600	6	125	456	410	409	1600	8	125
379	355	360	260	6	125	457	411	412	950	8	125
380	360	361	400	6	125	458	412	413	350	8	125

459	412	430	1030	8	125
460	414	193	1730	8	125
461	191	421	1120	8	125
462	403	422	560	8	125
463	407	423	670	8	125
464	408	424	1000	8	125
465	414	425	480	8	125
466	147	420	590	6	125
467	420	419	380	6	125
468	419	139	570	6	125
469	146	416	640	6	125
470	416	417	40	6	125
471	417	418	330	6	125
472	418	419	300	6	125
473	417	415	220	6	125
474	415	343	470	6	125
475	418	342	690	8	125
476	125	334	180	6	125
477	334	335	440	6	125
478	334	336	250	6	125
479	336	337	700	6	125
480	124	335	150	6	125
481	335	427	290	6	125
482	427	337	230	6	125
483	337	426	440	6	125
484	427	428	440	6	125
485	426	428	220	6	125
486	428	122	400	6	125
487	426	340	240	6	125
488	340	120	570	6	125
489	340	341	580	6	125
490	341	117	290	6	125
491	399	398	348	8	125
492	398	385	200	8	125
493	169	174	332.6	8	125
500	700	133	230	10	125
501	133	132	400	10	125
502	702	137	200	10	125
503	703	368	190	6	125
504	704	409	2760	8	125
505	168	156	700	10	125
506	156	168	750	6	125
507	194	198	2084	12	125
508	198	199	2049	16	125
509	159	392	1642	6	125
510	104	226	410	8	125
511	103	227	410	6	125
512	106	224	410	6	125
513	409	430	1100	8	125
514	430	710	2570	8	125
575	710	414	1890	8	125

* DALE AVE
 * FRISCO WAY
 * SUMMIT STATION RD

NODES

101	0	523.8	0	0	0
102	0	360	0	0	0
103	0	342	0	0	0
104	0	336	0	0	0
105	0	329	0	0	0
106	0	324	0	0	0
107	0	316	0	0	0
108	0	320	0	0	0
109	0	328	0	0	0
110	0	334	0	0	0
111	0	331	0	0	0
112	0	310	0	0	0
113	0	333	0	0	0
114	0	343	0	0	0
115	0	350	0	0	0
116	0	351	0	0	0
117	0	357	0	0	0
118	0	329	0	0	0
120	0	356	0	0	0
121	0	355	0	0	0
122	0	343	0	0	0
123	0	337	0	0	0
124	0	337	0	0	0
125	0	333	0	0	0
126	0	333	0	0	0
127	0	327	0	0	0

130	0	326	0	0	0	
131	0	326	0	0	0	
132	0	343	0	0	0	
133	0	338	0	0	0	
134	0	349	0	0	0	
135	0	368	0	0	0	
136	0	389	0	0	0	
137	0	395	0	0	0	
138	0	362	0	0	0	
139	0	358	0	0	0	
140	0	365	0	0	0	
141	0	346	0	0	0	
142	0	357	0	0	0	
143	0	370	0	0	0	
144	0	367	0	0	0	
145	0	372	0	0	0	
146	0	373	0	0	0	
147	0	356	0	0	0	
150	0	353	0	0	0	
151	0	360	0	0	0	
152	0	374	0	0	0	
153	0	347	0	0	0	
154	0	365	0	0	0	
155	0	361	0	0	0	
156	0	343	0	0	0	
157	0	322	0	0	0	
158	0	330	0	0	0	
159	0	330	0	0	0	
160	0	340	0	0	0	
161	0	340	0	0	0	
162	0	340	0	0	0	
163	0	340	0	0	0	
164	0	340	0	0	0	
165	0	335	0	0	0	
166	0	330	0	0	0	
167	0	315	0	0	0	
168	0	340	0	0	0	
169	0	-65.6	0	0	0	* VIA CONCHA WELL
170	0	306.4	0	0	0	
171	0	305	0	0	0	
172	0	225	0	0	0	
173	0	254	0	0	0	
174	0	267	0	0	0	* VIA CONCHA WELL DISCHARGE
175	0	283	0	0	0	
176	0	283	0	0	0	
177	0	183	0	0	0	* EUREKA WELL DISCHARGE
178	0	-15	0	0	0	* EUREKA WELL
179	0	322	0	0	0	
180	0	325	0	0	0	* BEVINGTON WELL DISCHARGE
181	0	-10.2	0	0	0	* BEVINGTON WELL
182	0	394	0	0	0	
183	0	394	0	0	0	
184	0	380	0	0	0	* OMIYA WELL DISCHARGE
185	0	23	0	0	0	* OMIYA WELL
186	0	362	0	0	0	
187	0	362	0	0	0	
190	0	410	0	0	0	
191	0	410	0	0	0	
192	0	430	0	0	0	
193	0	428	0	0	0	
194	0	404	0	0	0	
195	0	410	0	0	0	
196	0	380	0	0	0	
197	0	367	0	0	0	
198	0	400	0	0	0	
199	0	459.63	0	0	0	* STANDPIPE TANK
200	0	370	0	0	0	
201	0	357	0	0	0	
202	0	357	0	0	0	
203	0	343	0	0	0	
204	0	340	0	0	0	
205	0	347	0	0	0	
206	0	347	0	0	0	
207	0	345	0	0	0	
208	0	345	0	0	0	
209	0	330	0	0	0	
210	0	328	0	0	0	
211	0	327	0	0	0	

212	0	325	0	0	0	294	0	318	0	0	0
213	0	336	0	0	0	295	0	320	0	0	0
214	0	361	0	0	0	296	0	320	0	0	0
215	0	370	0	0	0	297	0	320	0	0	0
216	0	359	0	0	0	298	0	319	0	0	0
217	0	359	0	0	0	299	0	319	0	0	0
218	0	313	0	0	0	300	0	318	0	0	0
219	0	350	0	0	0	301	0	319	0	0	0
220	0	360	0	0	0	302	0	310	0	0	0
221	0	368	0	0	0	303	0	302	0	0	0
222	0	317	0	0	0	304	0	305	0	0	0
223	0	317	0	0	0	305	0	304	0	0	0
224	0	317	0	0	0	306	0	306	0	0	0
225	0	319	0	0	0	307	0	318	0	0	0
226	0	325	0	0	0	308	0	322	0	0	0
227	0	331	0	0	0	309	0	314	0	0	0
228	0	337	0	0	0	310	0	309	0	0	0
229	0	347	0	0	0	311	0	328	0	0	0
230	0	307	0	0	0	312	0	335	0	0	0
231	0	311	0	0	0	313	0	324	0	0	0
232	0	315	0	0	0	314	0	306	0	0	0
233	0	321	0	0	0	315	0	312	0	0	0
234	0	321	0	0	0	316	0	312	0	0	0
235	0	327	0	0	0	317	0	314	0	0	0
236	0	337	0	0	0	318	0	359	0	0	0
237	0	338	0	0	0	319	0	348	0	0	0
240	0	361	0	0	0	320	0	310	0	0	0
241	0	308	0	0	0	321	0	397	0	0	0
242	0	313	0	0	0	322	0	398	0	0	0
243	0	311	0	0	0	323	0	404	0	0	0
244	0	222	0	0	0	324	0	397	0	0	0
245	0	316	0	0	0	325	0	398	0	0	0
246	0	318	0	0	0	326	0	399	0	0	0
247	0	318	0	0	0	327	0	362	0	0	0
248	0	315	0	0	0	328	0	397	0	0	0
249	0	320	0	0	0	329	0	358	0	0	0
250	0	379	0	0	0	330	0	354	0	0	0
251	0	316	0	0	0	331	0	344	0	0	0
252	0	323	0	0	0	332	0	340	0	0	0
253	0	335	0	0	0	333	0	337	0	0	0
254	0	370	0	0	0	334	0	337	0	0	0
255	0	361	0	0	0	335	0	340	0	0	0
256	0	338	0	0	0	336	0	347	0	0	0
257	0	361	0	0	0	337	0	350	0	0	0
258	0	377	0	0	0	338	0	342	0	0	0
259	0	336	0	0	0	339	0	360	0	0	0
260	0	331	0	0	0	340	0	374	0	0	0
261	0	329	0	0	0	341	0	364	0	0	0
262	0	328	0	0	0	342	0	326	0	0	0
263	0	324	0	0	0	343	0	320	0	0	0
264	0	321	0	0	0	344	0	350	0	0	0
265	0	353	0	0	0	345	0	360	0	0	0
266	0	362	0	0	0	346	0	360	0	0	0
267	0	345	0	0	0	347	0	353	0	0	0
268	0	313	0	0	0	348	0	372	0	0	0
269	0	285	0	0	0	349	0	371	0	0	0
270	0	334	0	0	0	350	0	362	0	0	0
271	0	328	0	0	0	351	0	342	0	0	0
272	0	320	0	0	0	352	0	361	0	0	0
273	0	336	0	0	0	353	0	361	0	0	0
274	0	330	0	0	0	354	0	370	0	0	0
275	0	323	0	0	0	355	0	387	0	0	0
276	0	338	0	0	0	356	0	360	0	0	0
277	0	332	0	0	0	357	0	360	0	0	0
278	0	325	0	0	0	360	0	401	0	0	0
279	0	337	0	0	0	361	0	374	0	0	0
280	0	335	0	0	0	362	0	408	0	0	0
281	0	330	0	0	0	363	0	372	0	0	0
282	0	339	0	0	0	364	0	370	0	0	0
283	0	346	0	0	0	365	0	370	0	0	0
284	0	316	0	0	0	366	0	370	0	0	0
285	0	313	0	0	0	367	0	400	0	0	0
286	0	313	0	0	0	368	0	381	0	0	0
287	0	312	0	0	0	369	0	348	0	0	0
290	0	317	0	0	0	370	0	358	0	0	0
291	0	319	0	0	0	371	0	380	0	0	0
292	0	319	0	0	0	372	0	389	0	0	0
293	0	320	0	0	0	373	0	360	0	0	0

* CHURCH WELL DISCHARGE
* CHURCH WELL

374	0	360	0	0	0	120	-1.58	
375	0	360	0	0	0	121	-1.81	
376	0	360	0	0	0	122	-2.48	
377	0	360	0	0	0	123	-1.81	
378	0	380	0	0	0	124	-1.58	
380	0	380	0	0	0	125	-36.68	
381	0	360	0	0	0	126	-1.81	
382	0	369	0	0	0	127	-2.26	
383	0	360	0	0	0	130	-3.38	
384	0	340	0	0	0	131	-1.35	
385	0	359	0	0	0	132	-1.5	
386	0	320	0	0	0	133	-5.36	
387	0	342	0	0	0	134	-3.91	
388	0	317	0	0	0	136	-2.63	
389	0	317	0	0	0	137	-0.75	
390	0	339	0	0	0	138	-1.5	
391	0	316	0	0	0	139	-26.14	
392	0	317	0	0	0	141	-24.75	
393	0	311	0	0	0	142	-9.78	
394	0	322	0	0	0	143	-7.7	
395	0	303	0	0	0	144	-1.58	
397	0	347	0	0	0	145	-0.9	
398	0	362	0	0	0	146	-2.25	
399	0	14	0	0	0	147	-1.35	
400	0	343	0	0	0	150	-36.23	
401	0	350	0	0	0	151	-1.5	
402	0	370	0	0	0	152	-37.21	
403	0	372	0	0	0	153	-4.88	
404	0	357	0	0	0	154	-1.13	
405	0	398	0	0	0	155	-2.63	
406	0	390	0	0	0	156	-2.63	
407	0	350	0	0	0	158	-0.38	
408	0	424.7	0	0	0	159	-1.5	
409	0	360	0	0	0	160	-0.75	
410	0	445	0	0	0	161	-3.75	
411	0	444	0	0	0	163	-4.13	
412	0	420	0	0	0	165	-2.63	
413	0	440	0	0	0	167	-1.5	
414	0	447	0	0	0	170	-1.5	
415	0	350	0	0	0	187	-1.88	
416	0	358	0	0	0	190	-0.75	
417	0	358	0	0	0	192	-0.75	
418	0	356	0	0	0	193	-1.88	
419	0	356	0	0	0	196	-1.13	
420	0	357	0	0	0	200	-2.63	
421	0	407	0	0	0	201	-2.63	
422	0	380	0	0	0	202	-1.13	
423	0	320	0	0	0	203	-3.75	
424	0	452	0	0	0	204	-2.25	
425	0	455	0	0	0	205	-4.13	
426	0	377	0	0	0	206	-1.13	
427	0	354	0	0	0	207	-2.25	
428	0	360	0	0	0	208	-38.33	
430	0	340	0	0	0	209	-1.13	
700	0	332.2	0	0	0	210	-2.63	
701	0	330.4	0	0	0	211	-3	
702	0	396.4	0	0	0	212	-1.13	
703	0	380	0	0	0	214	-1.5	
704	0	432.3	0	0	0	215	-1.5	
710	0	360	0	0	0	217	-1.5	
DEMANDS							219	-3.75
102		-0.45				221	-2.25	
103		-2.26				222	-1.43	
104		-42.28				223	-1.43	
105		-2.6				224	-1.43	
106		-4.67				225	-1.43	
107		-6.42				226	-2.29	
108		-20.47				227	-6.27	
109		-19.87				228	-4.51	
110		-11.78				229	-2.26	
111		-34.27				230	-1.58	
112		-1.5				231	-1.81	
113		-9.64				232	-1.58	
114		-6.62				233	-4.11	
115		-5.87				234	-2.29	
116		-2.03				235	-3.16	
117		-2.48				236	-1.35	
118		-2.98				237	-2.26	

* OLYMPIC WELL DISCHARGE
* OLYMPIC WELL

240	-2.26	327	-3.08
241	-1.58	329	-3.75
242	-1.58	330	-45.12
245	-1.58	331	-5.6
246	-1.81	332	-5.6
247	-1.81	333	-8
248	-1.81	334	-1.58
249	-2.26	335	-2.03
250	-2.26	336	-5.87
251	-0.9	337	-3.39
252	-2.26	338	-8.63
253	-2.26	339	-14.19
254	-1.13	340	-3.39
255	-3.53	341	-4.51
256	-3.53	342	-2.63
257	-3.53	343	-6.48
258	-2.26	344	-19.53
259	-2.26	345	-30.34
260	-4.29	346	-12.76
261	-1.58	347	-3.02
262	-3.79	348	-1.5
263	-2.29	349	-1.81
264	-1.34	350	-1.81
265	-1.57	351	-2.93
266	-1.13	352	-2.48
267	-1.58	353	-3.38
270	-2.29	354	-2.48
271	-1.81	355	-2.48
272	-1.81	356	-2.93
273	-0.45	357	-3.16
274	-2.48	360	-2.03
275	-1.13	361	-2.48
276	-1.13	362	-3.39
277	-2.03	363	-2.48
278	-1.35	364	-2.26
279	-0.45	365	-1.58
280	-2.26	366	-1.81
281	-1.13	367	-4.74
282	-2.26	368	-1.81
283	-0.68	369	-8.25
284	-2.93	370	-7.13
285	-2.93	371	-2.63
286	-1.13	372	-9
287	-3.23	373	-5.63
290	-5.85	374	-2.33
291	-3	375	-11.09
292	-3	376	-5.26
293	-4.88	377	-5.26
295	-7.13	380	-3
296	-1.5	381	-2.63
297	-1.5	382	-1.13
299	-0.38	383	-1.88
300	-1.5	385	-3
301	-3.29	387	-1.88
302	-4.5	390	-4.13
303	-4.88	391	-3.38
304	-1.13	392	-1.5
305	-4.5	393	-1.13
306	-5.03	394	-0.75
307	-1.13	395	-1.13
308	-1.5	397	-2.63
309	-2.03	400	-2.63
310	-2.03	401	-3.38
311	-3.16	402	-3.38
312	-2.26	406	-0.75
313	-5.42	407	-0.75
314	-6.77	408	-1.88
315	-5.54	409	-1.5
316	-3.29	410	-36.83
317	-3.29	412	-2.25
318	-7.59	414	-4.13
319	-5.6	415	-2.48
320	-3.29	416	-1.35
321	-2.25	417	-1.13
323	-2.71	418	-2.48
324	-3.84	419	-0.75
325	-2.71	420	-2.26
326	-3.16	421	-0.75

425 -1.13
 426 -1.35
 427 -2.71
 428 -2.48

FIXED DEMANDS

139 -44.88
 330 -11.93
 318 -3.84
 333 -1.85

399 145 * OLYMPIC WELL
 425 -1000

AREA DEMANDS

MODIFY

PIPES

* THESE ARE UPGRADES TO MEET EXISTING SYSTEM DEFICIENCIES

ID	ARE	UPGRADES	TO MEET	EXISTING	SYSTEM	DEFICIENCIES
409	339	141	1240	10	135	* UPGRADE ON FRONTAGE RD
515	275	141	1760	10	135	* CREEK & HWY 101 XING
516	251	307	3660	10	135	* CREEK XING SOUTH OF KNOTTS ST.
264	104	262	370	10	135	* UPGRADE TO SUPPORT 101 XING (THOMPSON AVE)
265	262	270	370	10	135	* UPGRADE TO SUPPORT 101 XING (THOMPSON AVE)
273	270	273	480	10	135	* UPGRADE TO SUPPORT 101 XING (THOMPSON AVE)
279	273	274	450	10	135	* UPGRADE TO SUPPORT 101 XING (BEE ST.)
281	274	275	430	10	135	* UPGRADE TO SUPPORT 101 XING (BEE ST.)
318	307	112	200	12	135	* NEW 12" ACROSS 101
510	104	226	410	10	135	* UPGRADE TO SUPPORT 101 XING (THOMPSON AVE)
221	226	234	370	10	135	* UPGRADE TO SUPPORT 101 XING (THOMPSON AVE)
232	234	233	70	10	135	* " " " "
231	233	247	290	10	135	* " " " "
247	247	246	80	10	135	* " " " "
249	246	248	280	10	135	* " " " "
254	248	251	360	10	135	* " " " "
517	109	345	700	12	135	* TEFFT ST. HWY 101 CROSSING
337	135	321	560	8	135	* GRANDE AVE UPGRADE
338	321	322	160	8	135	* " " " "
347	322	328	470	8	135	* " " " "
348	328	329	360	8	135	* " " " "
349	329	330	360	8	135	* " " " "
355	333	319	200	8	135	* CONCEPCION ST. UPGRADE
356	319	114	900	8	135	* " " " "
519	101	102	5610	12	135	* TWIN TANK TEFFT ST. PARALLEL
520	102	103	1560	12	135	* " " " "
521	103	104	510	12	135	* " " " "
339	323	322	150	8	135	* UPGRADE ON BLACK HAWK WAY
527	187	190	5300	10	135	* LOOP ALONG POMEROY
361	345	346	890	10	135	* UPGRADE ALONG HILL ST.
528	247	256	700	8	135	* LOOP TO INCLUDE NIPOMO EL. SCHOOL
529	326	134	800	8	135	* LOOP-BONITA HOMES TO ORCHARD
464	408	424	1000	10	135	* POPPEY LANE UPGRADE
801	199	800	2500	10	135	* TIE FROM STANDPIPE TANK TO FRONTAGE RD
713	710	800	3650	10	135	* FRONTAGE RD SO OF SUMMIT STATION

NODES

800 0 381

run

keep EXISTWTR.KEP

endfile

```

NEW c:\engr\net\fbklake.wrk
OUTPUT c:\engr\net\fbklake.out
TITLE
NIPOMO WATER MASTER PLAN VTN0410001 JAL 8/16/95 Black Lake
* FBKLAKE.DTA
* MODELED WITH WELLS TURNED OFF AND THE HYDROPNUEMATIC TANK SET AT AN
* HGL OF 40 PSI PLUS 384 FT. WHICH IS THE HIGHEST NODE ELEVATION.
* THIS FILE HAS A TOTAL OF 167 GPM DEMAND WITH 51 GPM IRRIGATION
* AND 116 GPM RESIDENTIAL DEMAND TO REPRESENT FUTURE BUILDOUT.
BASE MODEL
UNITS 0 0 0 0 0 0 0
FACTORS 1.00 1
LIMITS 50 1 0.5 5.00 0.0 15.0 40.0 125.0 1918.0 50
LINES 80
UNKNOWNNS
650 476.4
CHECK VALVES
BOOSTER PUMPS
PRV
PUMP CURVE
PIPES
601 601 602 355 8 125 * BLACK LAKE #4
602 602 603 250 8 125
603 604 605 330 8 125 * BLACK LAKE #3
604 605 603 50 8 125
605 603 606 90 10 125
606 606 607 1030 8 125
607 607 608 770 8 125
608 608 609 350 8 125
609 608 613 620 8 125
610 607 610 340 8 125
611 610 611 400 8 125
612 610 611 840 8 125
613 611 612 220 8 125
614 612 613 220 8 125
615 612 614 730 8 125
616 613 614 980 8 125
617 614 615 180 8 125
618 616 617 80 8 125
619 616 619 1080 8 125
620 620 621 60 8 125
621 621 622 280 8 125
622 621 623 950 8 125
623 623 624 60 8 125
624 624 625 50 8 125
625 625 626 270 8 125
626 616 627 800 8 125
627 627 626 320 8 125
628 626 628 600 8 125
629 627 629 330 8 125
630 628 629 530 8 125
631 628 630 360 8 125
632 629 618 250 8 125
633 618 631 610 8 125
634 606 618 3340 8 125
635 631 632 200 8 125
636 630 631 650 8 125
637 630 633 570 8 125
638 633 634 400 8 125
639 633 635 450 8 125
640 633 636 350 8 125
641 625 637 1180 8 125
642 637 640 1380 8 125
643 640 641 1040 8 125
644 640 642 830 8 125
645 642 643 245 8 125
646 642 644 720 8 125
647 641 644 930 8 125
648 606 651 2600 8 125
649 650 651 170 8 125 * TANK
650 651 652 170 8 125
651 652 618 710 8 125
652 652 631 600 8 125
653 619 620 1100 8 125
654 509 519 450 8 125
NODES
601 0 -38 0 0 0

```

602	0	317	0	0	0
603	0	321	0	0	0
604	0	-10	0	0	0
605	0	320	0	0	0
606	0	322	0	0	0
607	0	322	0	0	0
608	0	330	0	0	0
609	0	328	0	0	0
610	0	330	0	0	0
611	0	311	0	0	0
612	0	317	0	0	0
613	0	322	0	0	0
614	0	335	0	0	0
615	0	350	0	0	0
616	0	360	0	0	0
617	0	360	0	0	0
618	0	345	0	0	0
620	0	360	0	0	0
621	0	361	0	0	0
622	0	362	0	0	0
623	0	369	0	0	0
624	0	370	0	0	0
625	0	374	0	0	0
626	0	362	0	0	0
627	0	345	0	0	0
628	0	363	0	0	0
629	0	350	0	0	0
630	0	365	0	0	0
631	0	353	0	0	0
632	0	361	0	0	0
633	0	362	0	0	0
634	0	381	0	0	0
635	0	341	0	0	0
636	0	352	0	0	0
637	0	384	0	0	0
640	0	380	0	0	0
641	0	359	0	0	0
642	0	373	0	0	0
643	0	381	0	0	0
644	0	376	0	0	0
650	0	320	0	0	0
651	0	330	0	0	0
652	0	360	0	0	0

DEMANDS

606	-3.82
607	-7.65
608	-7.65
609	-1.91
610	-4.78
611	-4.14
612	-4.46
613	-6.69
614	-10.84
616	-2.87
625	-3.19
626	-1.91
627	-4.46
628	-6.05
629	-5.42
630	-4.46
631	-5.74
633	-3.06
634	-2.29
635	-2.29
637	-8.60
640	-4.78
641	-2.87
642	-1.91
643	-4.14

FIXED DEMANDS

606	-1.65
607	-0.58
608	-1.65
609	-0.89
614	-0.34
615	-1.88
616	-10.67
618	-1.90

621 -3.76
 626 -1.02
 629 -4.08
 630 -12.19
 631 -6.82
 633 -3.57
 *601 400
 *604 350

AREA DEMANDS

MODIFY

PIPES

750	606	750	80	8	135	* TIE IN ON WILLOW RD NEAR BEVINGTON WELL
652	652	751	450	8	125	* TIE NEAR HYDRO TANK
751	631	751	150	8	125	* TIE FROM BARBERRY WAY
752	751	752	80	8	135	* TIE BARBERRY WAY TO WILLOW RD
753	650	652	250	8	135	* HYDROTANK BYPASS
173	175	750	640	10	125	* WILLOW RD TIE IN
754	750	179	490	10	125	* WILLOW RD TIE IN
176	179	752	2700	10	125	* WILLOW RD/BARBERRY WAY TIE IN
527	752	182	2410	10	125	* " " " "
755	187	754	1700	10	135	* POMEROY TIE IN
756	754	753	850	10	135	* " "
757	753	190	2750	10	135	* " "
758	641	753	60	8	135	* "K" ST. TIE IN
759	644	754	60	8	135	* "N" ST. TIE IN

NODES

750	0	322	0	0	0
751	0	353	0	0	0
752	0	353	0	0	0
753	0	359	0	0	0
754	0	376	0	0	0

run
 endfile

* JNIPMLN.DTA 9-10-95 CMF. THIS FILE IS THE ONE USED TO MODEL THE NIPOMO CSD WATER SYSTEM FOR
 * MASTER PLANNED IMPROVEMENTS. PUMP CURVES WERE AVAILABLE FOR THE WELLS SHOWN
 * UNDER UNKNOWNNS, THE OLYMPIC WELL WAS ENTERED AS FIXED SOURCE OF SUPPLY.
 * IMPROVEMENTS WERE INPUT IN THE MODIFICATIONS SECTION OF FILE.
 * DEMANDS ARE FUTURE AVERAGE ANNUAL DEMANDS.
 * THIS FILE HAS BLACK LAKE TIED INTO THE MAIN SYSTEM

NEW C:\ENGR\NET\JNIPMLN.WRK
 OUTPUT C:\enr\net\FIRUN.OUT

TITLE
 NIPOMO WATER MASTER PLAN VT-N04-100-01 CMF 9-10-95 MASTER PLAN RUNS

BASE MODEL
 UNITS 0 0 0 0 0 0 0
 FACTORS 2.5 1.000
 LIMITS 50 1.000 0.00 5.00 0.0 15.0 30.0 125.0 550.0 50
 LINES 80

UNKNOWNNS
 101 542.00 * TWIN TANKS
 199 542.00 * STANDPIPE
 178 -15 1 * EUREKA WELL PUMP
 181 -10.2 2 * BEVINGTON WELL PUMP
 * 185 23 3 * OMIYA WELL PUMP
 169 -65 5 * VIA CONCHA WELL PUMP
 * 244 222 4 * CHURCH WELL PUMP

CHECK VALVES
 BOOSTER PUMPS

PRV
 PUMP CURVE
 1 0 990 400 910 650 840 850 740 1020 680 * EUREKA
 2 0 875 200 875 300 830 416 677 450 600 * BEVINGTON
 3 0 952 40 924 80 826 100 749 120 630 * OMIYA
 4 0 774 100 608 200 440 225 391 250 340 * CHURCH
 5 0 936 200 888 400 856 700 696 800 576 * VIA CONCHA

PIPES
 101 101 102 5610 10 125
 102 102 103 1560 10 125
 103 103 104 510 10 125
 104 104 105 520 10 125
 105 105 106 350 10 125
 106 106 107 430 10 125
 107 107 108 500 10 125
 108 108 109 830 10 125
 109 109 110 860 10 125
 110 110 111 1080 10 125
 111 111 112 1030 10 125
 112 112 113 830 10 125
 113 113 114 320 10 125
 114 114 115 200 10 125
 115 115 116 60 10 125
 116 116 117 250 10 125
 117 117 120 360 10 125
 118 120 121 30 10 125
 119 121 122 260 10 125
 120 122 123 340 10 125
 121 123 124 25 10 125
 122 124 125 440 10 125
 123 125 126 10 10 125
 124 126 127 320 10 125
 125 127 130 190 10 125
 126 130 131 30 10 125
 127 131 132 450 10 125
 128 118 133 430 10 125
 130 118 134 700 10 125
 131 134 135 1150 10 125
 132 135 136 870 10 125
 133 136 137 620 10 125
 134 137 138 800 10 125
 135 138 139 710 10 125
 136 139 140 710 10 125
 137 109 141 1340 10 125
 138 141 142 490 10 125
 139 142 143 620 10 125
 140 143 144 530 10 125
 141 144 145 270 10 125
 142 145 146 510 10 125
 143 146 147 340 10 125
 144 147 150 250 10 125
 145 150 151 470 10 125

146	151	140	440	10	125	224	228	229	370	6	125
147	140	152	760	10	125	225	229	240	370	6	125
148	152	153	700	10	125	226	230	231	430	6	125
149	153	154	540	10	125	227	231	241	270	6	125
150	154	155	160	10	125	228	231	232	430	6	125
151	155	168	700	10	125	229	232	242	270	6	125
152	156	157	650	10	125	230	232	233	450	6	125
153	157	158	630	10	125	231	233	247	290	6	125
154	158	159	25	10	125	232	233	234	70	6	125
155	159	160	650	10	125	233	234	235	520	6	125
156	160	161	40	10	125	234	235	236	550	6	125
157	161	162	510	10	125	235	236	237	70	6	125
158	162	163	80	10	125	236	237	255	200	6	125
159	163	164	370	10	125	237	255	256	600	6	125
160	164	165	240	10	125	238	255	257	150	6	125
161	165	166	150	10	125	239	257	258	520	8	125
162	166	167	510	10	125	240	240	258	370	8	125
163	167	170	370	10	125	241	258	250	370	8	125
164	170	171	2160	16	125	242	241	242	420	6	125
165	171	172	3650	16	125	243	242	218	150	6	125
166	172	173	1800	16	125	244	244	243	89	8	125
167	173	174	1700	12	125	245	243	218	750	8	125
168	174	175	900	10	125	246	242	245	380	6	125
169	174	176	900	10	125	247	246	247	80	8	125
170	178	177	198	10	125	248	247	249	880	8	125
171	177	176	5974	10	125	249	246	248	280	8	125
172	176	175	10	10	125	250	248	249	520	8	125
173	175	179	1130	10	125	251	249	219	650	8	125
174	181	180	335.2	8	125	252	219	250	500	8	125
175	180	179	200	10	125	253	250	254	350	8	125
176	179	182	5110	10	125	254	248	251	430	8	125
177	185	184	357	8	125	255	251	252	490	8	125
178	184	183	250	8	125	256	252	253	590	8	125
179	183	182	10	8	125	257	253	254	460	8	125
180	183	187	1260	8	125	258	102	259	1320	8	125
181	183	186	1260	8	125	259	259	265	370	6	125
182	393	395	1350	8	125	260	259	265	370	6	125
183	190	191	40	8	125	261	260	103	370	6	125
184	191	192	870	8	125	262	260	261	300	6	125
185	192	193	1130	10	125	263	261	262	200	6	125
186	193	198	3516	10	125	264	262	104	370	8	125
187	194	195	3480	8	125	265	262	270	370	8	125
188	194	196	950	10	125	266	262	263	450	6	125
189	196	197	500	10	125	267	263	271	370	6	125
190	200	201	500	10	125	268	263	264	430	6	125
191	201	203	1800	10	125	269	264	272	370	6	125
192	202	203	540	10	125	270	265	266	520	6	125
193	203	204	650	10	125	271	265	267	480	6	125
194	204	205	330	8	125	272	267	270	620	6	125
195	205	206	60	8	125	273	270	273	480	8	125
196	206	207	900	8	125	274	270	271	450	6	125
197	207	208	20	8	125	275	271	274	480	6	125
198	208	209	810	8	125	276	271	272	430	6	125
199	209	210	80	8	125	277	272	275	480	6	125
200	210	211	370	8	125	278	273	276	470	6	125
201	211	212	330	8	125	279	273	274	450	6	125
202	212	213	1470	8	125	280	274	277	470	6	125
203	213	214	1450	8	125	281	274	275	430	6	125
204	214	215	1070	8	125	282	275	278	470	6	125
205	215	216	960	8	125	283	276	279	480	8	125
206	216	217	130	8	125	284	276	277	450	6	125
207	217	196	1400	8	125	285	277	278	430	6	125
208	202	220	150	10	125	286	278	281	480	6	125
209	220	221	910	10	125	287	279	283	450	8	125
210	221	154	100	10	125	288	279	280	450	6	125
211	107	222	440	8	125	289	280	282	480	6	125
212	222	223	20	6	125	290	280	281	430	6	125
213	222	230	830	6	125	291	281	282	910	6	125
214	223	230	430	6	125	292	113	284	780	6	125
215	223	224	430	6	125	293	284	285	580	6	125
216	224	225	430	6	125	294	284	268	340	6	125
217	224	231	440	6	125	295	268	285	240	6	125
218	225	226	450	6	125	296	285	286	300	6	125
219	225	232	440	6	125	297	286	287	110	6	125
220	226	227	520	6	125	298	287	290	1980	6	125
221	226	234	370	6	125	299	290	291	250	6	125
222	227	228	520	6	125	300	291	292	530	6	125
223	227	235	370	6	125	301	292	293	360	6	125

302	293	294	200	6	125	380	360	361	400	6	125
303	294	295	510	6	125	381	360	362	260	6	125
304	295	296	530	6	125	382	362	363	400	6	125
305	296	297	860	6	125	383	362	364	660	6	125
306	297	298	1000	6	125	384	357	356	260	6	125
307	298	299	200	6	125	385	356	361	280	6	125
308	299	300	300	8	125	386	361	363	260	6	125
309	300	301	540	8	125	387	363	364	260	6	125
310	301	118	480	8	125	388	150	357	150	6	125
311	299	302	770	6	125	389	145	364	150	6	125
312	302	303	560	6	125	390	353	369	680	6	125
313	303	304	400	6	125	391	144	365	140	6	125
314	303	269	450	6	125	392	365	367	640	6	125
315	269	304	830	6	125	393	365	366	260	6	125
316	304	305	380	6	125	394	366	367	370	6	125
317	305	306	780	6	125	395	366	368	260	6	125
318	112	307	200	8	125	396	367	368	640	6	125
319	307	308	500	8	125	397	143	368	140	6	125
320	306	310	520	6	125	398	153	370	1800	6	125
321	310	309	300	6	125	399	369	370	380	6	125
322	309	116	570	6	125	400	221	371	570	8	125
323	121	311	520	6	125	401	371	372	1000	8	125
324	311	312	670	6	125	402	372	373	1620	8	125
325	312	122	200	6	125	403	373	374	280	8	125
326	123	313	300	6	125	404	374	375	310	8	125
327	313	314	630	6	125	405	375	376	650	8	125
328	126	314	540	6	125	406	374	377	650	8	125
329	127	315	590	6	125	407	376	377	230	8	125
330	131	315	340	6	125	408	376	339	800	6	125
331	315	316	160	6	125	409	339	141	1240	6	125
332	316	317	675	6	125	410	155	380	850	6	125
333	316	320	760	6	125	411	220	380	390	6	125
334	317	320	180	6	125	412	380	381	940	6	125
335	320	133	398	6	125	413	381	157	760	6	125
336	320	301	500	6	125	414	381	203	750	6	125
337	135	321	560	6	125	415	381	382	640	6	125
338	321	322	160	6	125	416	382	158	770	6	125
339	322	323	150	6	125	417	382	383	370	6	125
340	323	324	260	8	125	418	383	204	380	6	125
341	324	326	430	8	125	419	383	206	780	6	125
342	323	325	440	8	125	420	163	384	450	6	125
343	325	326	260	8	125	421	384	385	320	6	125
344	325	327	210	8	125	422	385	386	600	6	125
345	327	132	930	8	125	423	386	208	170	6	125
346	327	130	980	8	125	424	165	378	590	6	125
347	322	328	470	6	125	425	378	387	210	8	125
348	328	329	360	6	125	426	387	388	600	8	125
349	329	330	360	6	125	427	388	210	350	8	125
350	330	331	1020	8	125	428	170	389	180	8	125
351	331	332	360	8	125	429	389	390	430	8	125
352	332	333	210	8	125	430	390	391	590	8	125
353	332	318	800	6	125	431	391	212	310	8	125
354	318	116	550	6	125	432	160	392	720	6	125
355	333	319	200	6	125	433	163	393	780	8	125
356	319	114	900	6	125	434	165	394	620	8	125
357	138	342	660	8	125	435	394	395	550	8	125
358	342	343	330	8	125	436	209	397	1210	6	125
359	343	344	1220	8	125	437	397	400	600	8	125
360	344	345	820	8	125	438	400	207	980	6	125
361	345	346	890	8	125	439	400	401	910	8	125
362	346	347	900	6	125	440	401	205	980	6	125
363	346	338	420	8	125	441	401	201	510	10	125
364	338	347	600	8	125	442	397	402	420	10	125
365	347	330	1970	8	125	443	402	217	470	8	125
366	152	348	520	6	125	444	402	200	1660	10	125
367	348	349	170	6	125	445	190	403	2530	8	125
368	349	350	270	6	125	446	403	404	1230	8	125
369	349	351	600	6	125	447	404	407	2150	8	125
370	350	351	410	6	125	448	404	405	1020	8	125
371	351	352	560	6	125	449	405	406	390	8	125
372	350	352	220	6	125	450	406	407	1270	8	125
373	352	151	130	6	125	451	406	408	1100	8	125
374	348	353	860	6	125	452	405	410	3700	8	125
375	353	354	200	6	125	453	408	409	3260	8	125
376	354	357	950	6	125	454	192	411	1630	8	125
377	354	355	150	6	125	455	411	410	80	8	125
378	355	356	600	6	125	456	410	409	1600	8	125
379	355	360	260	6	125	457	411	412	950	8	125

458	412	413	350	8	125
459	412	430	1030	8	125
460	414	193	1730	8	125
461	191	421	1120	8	125
462	403	422	560	8	125
463	407	423	670	8	125
464	408	424	1000	8	125
465	414	425	480	8	125
466	147	420	590	6	125
467	420	419	380	6	125
468	419	139	570	6	125
469	146	416	640	6	125
470	416	417	40	6	125
471	417	418	330	6	125
472	418	419	300	6	125
473	417	415	220	6	125
474	415	343	470	6	125
475	418	342	690	8	125
476	125	334	180	6	125
477	334	335	440	6	125
478	334	336	250	6	125
479	336	337	700	6	125
480	124	335	150	6	125
481	335	427	290	6	125
482	427	337	230	6	125
483	337	426	440	6	125
484	427	428	440	6	125
485	426	428	220	6	125
486	428	122	400	6	125
487	426	340	240	6	125
488	340	120	570	6	125
489	340	341	580	6	125
490	341	117	290	6	125
491	399	398	348	8	125
492	398	385	200	8	125
493	169	174	332	8	125
501	133	132	400	10	125
505	168	156	700	10	125
506	156	168	750	6	125
507	194	198	2084	12	125
508	198	199	2049	16	125
509	159	392	1642	6	125
510	104	226	410	8	125
511	103	227	410	6	125
512	106	224	410	6	125
513	409	430	1100	8	125
514	430	414	4460	8	125

* THIS IS THE BLAKE LAKE SYSTEM

* DALE AVE
* FRISCO WAY

* BLACK LAKE #4

* BLACK LAKE #3

601	601	602	355	8	125
602	602	603	250	8	125
603	604	605	330	8	125
604	605	603	50	8	125
605	603	606	90	10	125
606	606	607	1030	8	125
607	607	608	770	8	125
608	608	609	350	8	125
609	608	613	620	8	125
610	607	610	340	8	125
611	610	611	400	8	125
612	610	611	840	8	125
613	611	612	220	8	125
614	612	613	220	8	125
615	612	614	730	8	125
616	613	614	980	8	125
617	614	615	180	8	125
618	616	617	80	8	125
619	616	619	1080	8	125
620	620	621	60	8	125
621	621	622	280	8	125
622	621	623	950	8	125
623	623	624	60	8	125
624	624	625	50	8	125
625	625	626	270	8	125
626	616	627	800	8	125
627	627	626	320	8	125
628	626	628	600	8	125
629	627	629	330	8	125
630	628	629	530	8	125

631	628	630	360	8	125
632	629	618	250	8	125
633	618	631	610	8	125
634	606	618	3340	8	125
635	631	632	200	8	125
636	630	631	650	8	125
637	630	633	570	8	125
638	633	634	400	8	125
639	633	635	450	8	125
640	633	636	350	8	125
641	625	637	1180	8	125
642	637	640	1380	8	125
643	640	641	1040	8	125
644	640	642	830	8	125
645	642	643	245	8	125
646	642	644	720	8	125
647	641	644	930	8	125
648	606	651	2600	8	125
649	650	651	170	8	125
650	651	652	170	8	125
651	652	618	710	8	125
652	652	631	600	8	125
653	619	620	1100	8	125
654	609	619	450	8	125

*OLD DEDICATED WELL LINE

* OLD HYDRO TANK

NODES

101	0	523.8	0	0	0
102	0	360	0	0	0
103	0	342	0	0	0
104	0	336	0	0	0
105	0	329	0	0	0
106	0	324	0	0	0
107	0	316	0	0	0
108	0	320	0	0	0
109	0	328	0	0	0
110	0	334	0	0	0
111	0	331	0	0	0
112	0	310	0	0	0
113	0	333	0	0	0
114	0	343	0	0	0
115	0	350	0	0	0
116	0	351	0	0	0
117	0	357	0	0	0
118	0	329	0	0	0
120	0	356	0	0	0
121	0	355	0	0	0
122	0	343	0	0	0
123	0	337	0	0	0
124	0	337	0	0	0
125	0	333	0	0	0
126	0	333	0	0	0
127	0	327	0	0	0
130	0	326	0	0	0
131	0	326	0	0	0
132	0	343	0	0	0
133	0	338	0	0	0
134	0	349	0	0	0
135	0	368	0	0	0
136	0	389	0	0	0
137	0	395	0	0	0
138	0	362	0	0	0
139	0	358	0	0	0
140	0	365	0	0	0
141	0	346	0	0	0
142	0	357	0	0	0
143	0	370	0	0	0
144	0	367	0	0	0
145	0	372	0	0	0
146	0	373	0	0	0
147	0	356	0	0	0
150	0	353	0	0	0
151	0	360	0	0	0
152	0	374	0	0	0
153	0	347	0	0	0
154	0	365	0	0	0
155	0	361	0	0	0
156	0	343	0	0	0
157	0	322	0	0	0
158	0	330	0	0	0

159	0	330	0	0	0	
160	0	340	0	0	0	
161	0	340	0	0	0	
162	0	340	0	0	0	
163	0	340	0	0	0	
164	0	340	0	0	0	
165	0	335	0	0	0	
166	0	330	0	0	0	
167	0	315	0	0	0	
168	0	340	0	0	0	
169	0	-65.6	0	0	0	* VIA CONCHA WELL
170	0	306.4	0	0	0	
171	0	305	0	0	0	
172	0	225	0	0	0	
173	0	254	0	0	0	
174	0	267	0	0	0	* VIA CONCHA WELL DISCHARGE
175	0	283	0	0	0	
176	0	283	0	0	0	
177	0	183	0	0	0	* EUREKA WELL DISCHARGE
178	0	-15	0	0	0	* EUREKA WELL
179	0	322	0	0	0	
180	0	325	0	0	0	* BEVINGTON WELL DISCHARGE
181	0	-10.2	0	0	0	* BEVINGTON WELL
182	0	394	0	0	0	
183	0	394	0	0	0	
184	0	380	0	0	0	* OMIYA WELL DISCHARGE
185	0	23	0	0	0	* OMIYA WELL
186	0	362	0	0	0	
187	0	362	0	0	0	
190	0	410	0	0	0	
191	0	410	0	0	0	
192	0	430	0	0	0	
193	0	428	0	0	0	
194	0	404	0	0	0	
195	0	410	0	0	0	
196	0	380	0	0	0	
197	0	367	0	0	0	
198	0	400	0	0	0	
199	0	459.63	0	0	0	* STANDPIPE TANK
200	0	370	0	0	0	
201	0	357	0	0	0	
202	0	357	0	0	0	
203	0	343	0	0	0	
204	0	340	0	0	0	
205	0	347	0	0	0	
206	0	347	0	0	0	
207	0	345	0	0	0	
208	0	345	0	0	0	
209	0	330	0	0	0	
210	0	328	0	0	0	
211	0	327	0	0	0	
212	0	325	0	0	0	
213	0	336	0	0	0	
214	0	361	0	0	0	
215	0	370	0	0	0	
216	0	359	0	0	0	
217	0	359	0	0	0	
218	0	313	0	0	0	
219	0	350	0	0	0	
220	0	360	0	0	0	
221	0	368	0	0	0	
222	0	317	0	0	0	
223	0	317	0	0	0	
224	0	317	0	0	0	
225	0	319	0	0	0	
226	0	325	0	0	0	
227	0	331	0	0	0	
228	0	337	0	0	0	
229	0	347	0	0	0	
230	0	307	0	0	0	
231	0	311	0	0	0	
232	0	315	0	0	0	
233	0	321	0	0	0	
234	0	321	0	0	0	
235	0	327	0	0	0	
236	0	337	0	0	0	
237	0	338	0	0	0	
240	0	361	0	0	0	

241	0	308	0	0	0
242	0	313	0	0	0
243	0	311	0	0	0
244	0	222	0	0	0
245	0	316	0	0	0
246	0	318	0	0	0
247	0	318	0	0	0
248	0	315	0	0	0
249	0	320	0	0	0
250	0	379	0	0	0
251	0	316	0	0	0
252	0	323	0	0	0
253	0	335	0	0	0
254	0	370	0	0	0
255	0	361	0	0	0
256	0	338	0	0	0
257	0	361	0	0	0
258	0	377	0	0	0
259	0	336	0	0	0
260	0	331	0	0	0
261	0	329	0	0	0
262	0	328	0	0	0
263	0	324	0	0	0
264	0	321	0	0	0
265	0	353	0	0	0
266	0	362	0	0	0
267	0	345	0	0	0
268	0	313	0	0	0
269	0	285	0	0	0
270	0	334	0	0	0
271	0	328	0	0	0
272	0	320	0	0	0
273	0	336	0	0	0
274	0	330	0	0	0
275	0	323	0	0	0
276	0	338	0	0	0
277	0	332	0	0	0
278	0	325	0	0	0
279	0	337	0	0	0
280	0	335	0	0	0
281	0	330	0	0	0
282	0	339	0	0	0
283	0	346	0	0	0
284	0	316	0	0	0
285	0	313	0	0	0
286	0	313	0	0	0
287	0	312	0	0	0
290	0	317	0	0	0
291	0	319	0	0	0
292	0	319	0	0	0
293	0	320	0	0	0
294	0	318	0	0	0
295	0	320	0	0	0
296	0	320	0	0	0
297	0	320	0	0	0
298	0	319	0	0	0
299	0	319	0	0	0
300	0	318	0	0	0
301	0	319	0	0	0
302	0	310	0	0	0
303	0	302	0	0	0
304	0	305	0	0	0
305	0	304	0	0	0
306	0	306	0	0	0
307	0	318	0	0	0
308	0	322	0	0	0
309	0	314	0	0	0
310	0	309	0	0	0
311	0	328	0	0	0
312	0	335	0	0	0
313	0	324	0	0	0
314	0	306	0	0	0
315	0	312	0	0	0
316	0	312	0	0	0
317	0	314	0	0	0
318	0	359	0	0	0
319	0	348	0	0	0
320	0	310	0	0	0

* CHURCH WELL DISCHARGE
* CHURCH WELL

321	0	397	0	0	0
322	0	398	0	0	0
323	0	404	0	0	0
324	0	397	0	0	0
325	0	398	0	0	0
326	0	399	0	0	0
327	0	362	0	0	0
328	0	397	0	0	0
329	0	358	0	0	0
330	0	354	0	0	0
331	0	344	0	0	0
332	0	340	0	0	0
333	0	337	0	0	0
334	0	337	0	0	0
335	0	340	0	0	0
336	0	347	0	0	0
337	0	350	0	0	0
338	0	342	0	0	0
339	0	360	0	0	0
340	0	374	0	0	0
341	0	364	0	0	0
342	0	326	0	0	0
343	0	320	0	0	0
344	0	350	0	0	0
345	0	360	0	0	0
346	0	360	0	0	0
347	0	353	0	0	0
348	0	372	0	0	0
349	0	371	0	0	0
350	0	362	0	0	0
351	0	342	0	0	0
352	0	361	0	0	0
353	0	361	0	0	0
354	0	370	0	0	0
355	0	387	0	0	0
356	0	360	0	0	0
357	0	360	0	0	0
360	0	401	0	0	0
361	0	374	0	0	0
362	0	408	0	0	0
363	0	372	0	0	0
364	0	370	0	0	0
365	0	370	0	0	0
366	0	370	0	0	0
367	0	400	0	0	0
368	0	381	0	0	0
369	0	348	0	0	0
370	0	358	0	0	0
371	0	380	0	0	0
372	0	389	0	0	0
373	0	360	0	0	0
374	0	360	0	0	0
375	0	360	0	0	0
376	0	360	0	0	0
377	0	360	0	0	0
378	0	380	0	0	0
380	0	380	0	0	0
381	0	360	0	0	0
382	0	369	0	0	0
383	0	360	0	0	0
384	0	340	0	0	0
385	0	359	0	0	0
386	0	320	0	0	0
387	0	342	0	0	0
388	0	317	0	0	0
389	0	317	0	0	0
390	0	339	0	0	0
391	0	316	0	0	0
392	0	317	0	0	0
393	0	311	0	0	0
394	0	322	0	0	0
395	0	303	0	0	0
397	0	347	0	0	0
398	0	362	0	0	0
399	0	14	0	0	0
400	0	343	0	0	0
401	0	350	0	0	0
402	0	370	0	0	0

403	0	372	0	0	0
404	0	357	0	0	0
405	0	398	0	0	0
406	0	390	0	0	0
407	0	350	0	0	0
408	0	424.7	0	0	0
409	0	360	0	0	0
410	0	445	0	0	0
411	0	444	0	0	0
412	0	420	0	0	0
413	0	440	0	0	0
414	0	447	0	0	0
415	0	350	0	0	0
416	0	358	0	0	0
417	0	358	0	0	0
418	0	356	0	0	0
419	0	356	0	0	0
420	0	357	0	0	0
421	0	407	0	0	0
422	0	380	0	0	0
423	0	320	0	0	0
424	0	452	0	0	0
425	0	455	0	0	0
426	0	377	0	0	0
427	0	354	0	0	0
428	0	360	0	0	0
430	0	340	0	0	0

* THIS IS THE BLACK LAKE SYSTEM

601	0	-38	0	0	0
602	0	317	0	0	0
603	0	321	0	0	0
604	0	-10	0	0	0
605	0	320	0	0	0
606	0	322	0	0	0
607	0	322	0	0	0
608	0	330	0	0	0
609	0	328	0	0	0
610	0	330	0	0	0
611	0	311	0	0	0
612	0	317	0	0	0
613	0	322	0	0	0
614	0	335	0	0	0
615	0	350	0	0	0
616	0	360	0	0	0
617	0	360	0	0	0
618	0	345	0	0	0
619	0	328	0	0	0
620	0	360	0	0	0
621	0	361	0	0	0
622	0	362	0	0	0
623	0	369	0	0	0
624	0	370	0	0	0
625	0	374	0	0	0
626	0	362	0	0	0
627	0	345	0	0	0
628	0	363	0	0	0
629	0	350	0	0	0
630	0	365	0	0	0
631	0	353	0	0	0
632	0	361	0	0	0
633	0	362	0	0	0
634	0	381	0	0	0
635	0	341	0	0	0
636	0	352	0	0	0
637	0	384	0	0	0
640	0	380	0	0	0
641	0	359	0	0	0
642	0	373	0	0	0
643	0	381	0	0	0
644	0	376	0	0	0
650	0	320	0	0	0
651	0	330	0	0	0
652	0	360	0	0	0

* OLYMPIC WELL DISCHARGE
 * OLYMPIC WELL

DEMANDS				
102	-2.48			
103	-2.71			
104	-5.93	* INCS	JOCKOS	
105	-3.02			

106	-5.08		211	-3.75	
107	-10.85		212	-1.13	
108	-23.6	* INCS LAUNDROMAT	213	-10.13	
109	-28.62	* INCS BUENA VISTA MHP	214	-1.5	
110	-23.47		215	-1.5	
111	-26.64	*INCS BAR K MHP USAGE AND CHURCH	217	-1.5	
112	-3.0		219	-3.75	
113	-7.12	* INCS APTS ON AMADO	221	-2.25	
114	-8.43		222	-1.55	
115	-5.87		223	-1.43	
116	-2.03		224	-1.43	
117	-2.48		225	-1.93	
118	-2.98		226	-2.29	
120	-1.58		227	-6.27	
121	-1.81		228	-4.74	
122	-2.48		229	-2.26	
123	-1.81		230	-1.58	
124	-1.58		231	-2.03	
125	-1.35		232	-1.58	
126	-1.81		233	-2.37	* INCS ST. JOSEPHS CHURCH
127	-2.26		234	-2.29	
130	-3.38		235	-3.16	
131	-1.35		236	-1.35	
132	-1.5		237	-2.26	
133	-5.36		240	-2.26	
134	-8.41		241	-1.58	
135	-6.75		242	-3.38	
136	-7.13		245	-1.58	
137	-4.58	* NEED TO ADD DANA ELEM SCHOOL DEMAND	246	-3.84	
138	-1.95		247	-1.81	
139	-2.25		248	-4.06	
141	-35.98	* INCS SWAP MEET	249	-5.26	* +3 GPM IRRIG
142	-11.37		250	-2.26	
143	-7.7		251	-4.06	
144	-1.58		252	-9.03	
145	-0.9		253	-9.03	
146	-2.63		254	-4.29	
147	-1.35		255	-4.43	
150	-0.9		256	-3.53	
151	-1.5		257	-3.53	
152	-1.88		258	-2.26	
153	-4.88		259	-2.26	
154	-4.13	* +3 GPM IRRIG	260	-4.29	
155	-2.63		261	-1.58	
156	-4.16		262	-5.37	
157	-2.33		263	-5.00	
158	-1.33		264	-3.35	
159	-3.04		265	-3.15	
160	-2.25		266	-1.13	
161	-3.75		267	-3.61	
163	-4.88		270	-3.19	
165	-2.63		271	-2.03	
166	-1.33		272	-1.81	
167	-4.88		273	-1.35	
170	-6.0		274	-3.16	
171	-16.13		275	-2.63	
172	-10.88		276	-2.03	
173	-10.13		277	-3.84	
175	-13.13		278	-4.88	
183	-10.13		279	-0.45	
187	-4.69		280	-2.26	
190	-7.65		281	-2.63	
192	-2.25		282	-2.26	
193	-6.94		283	-0.68	
194	-7.99		284	-2.93	
195	-23.4		285	-2.93	
196	-1.13		286	-2.40	
200	-7.58		287	-6.74	
201	-7.50		290	-9.17	
202	-6.00		291	-3	
203	-3.75		292	-5.26	
204	-2.25		293	-7.81	
205	-4.13		295	-8.70	
206	-1.13		296	-4.43	
207	-2.25		297	-3.68	
208	-3.00		298	-0.75	
209	-1.13		299	-1.50	
210	-2.63		300	-1.5	

301	-3.29		387	-1.88	
302	-5.10		390	-4.13	
303	-6.91		391	-3.38	
304	-1.13		392	-6.38	
305	-5.25		393	-3.38	
306	-5.03		394	-4.50	*+3 GPM IRRIG
307	-1.13		395	-1.50	
308	-14.14		397	-2.63	
309	-2.03		399	0	*OLYMPIC WELL DISCHARGE
310	-2.03		400	-2.63	
311	-3.53		401	-4.88	
312	-2.26		402	-3.38	
313	-5.42		403	-5.44	
314	-6.77		405	-2.63	
315	-5.54		404	-2.06	
316	-3.29		406	-1.13	
317	-3.29		407	-1.95	
318	-7.59		408	-5.63	
319	-7.54		409	-6.00	
320	-3.29		410	-2.25	
321	-3.25	* +3 GPM IRRIG	411	-1.88	
323	-2.71		413	-3.75	* +3 GPM IRRIG
324	-3.84		412	-2.25	
325	-2.71		414	-6.38	
326	-3.16		415	-2.48	
327	-3.08		416	-1.35	
329	-3.75		417	-1.13	
330	-39.86		418	-2.48	
331	-6.9		419	-0.75	
332	-10.06		420	-2.26	
333	-6.73		421	-0.75	
334	-1.58		422	-1.13	
335	-2.03		423	-1.2	
336	-5.87		424	-1.61	
337	-3.39		425	-1.13	
338	-12.80		426	-1.35	
339	-33.71		427	-2.71	
340	-3.39		428	-2.48	
341	-4.51				* THIS IS THE BLAKE LAKE SYSTEM
342	-3.75		606	-3.82	
343	-6.48		607	-7.65	
344	-23.44		608	-7.65	
345	-21.87	* INCS VONS AND BANK	609	-1.91	
346	-6.59	* INCS RECREATION USAGE	610	-4.78	
347	-3.02		611	-4.14	
348	-1.88		612	-4.46	
349	-1.81		613	-6.69	
350	-2.18		614	-10.84	
351	-2.93		616	-2.87	
352	-2.48		625	-3.19	
353	-3.38		626	-1.91	
354	-2.48		627	-4.46	
355	-2.48		628	-6.05	
356	-2.93		629	-5.42	
357	-3.16		630	-4.46	
360	-2.03		631	-5.74	
361	-2.48		633	-3.06	
362	-3.39		634	-2.29	
363	-2.48		635	-2.29	
364	-2.26		637	-8.60	
365	-1.58		640	-4.78	
366	-1.81		641	-2.87	
367	-4.74		642	-1.91	
368	-1.81		643	-4.14	
369	-9.00				FIXED DEMANDS
370	-7.13		139	-23.88	* NIPOMO REGIONAL PARK
371	-2.63		330	-9.19	* NURSERY ON GRANDE
372	-13.95		318	-2.47	* LANDSCAPE METER
373	-5.63		333	-1.27	* GRANDE APTS LANDSCAPE METER
374	-2.33		604	350	* BLACK LAKE WELL #3
375	-8.48	* INCS COMMERCIAL USAGE			* THIS IS THE BLACK LAKE IRRIGATION DEMANDS
376	-5.26		606	-1.65	
377	-5.26		607	-0.58	
380	-3		608	-1.65	
381	-2.63		609	-0.89	
382	-2.63		614	-0.34	
383	-1.88		615	-1.88	
385	-3		616	-10.67	

618 -1.90
 621 -3.76
 626 -1.02
 629 -4.08
 630 -12.19
 631 -6.82
 633 -3.57

*99 145 * OLYMPIC WELL
 237 -3000 * FIRE FLOW

AREA DEMANDS
 MODIFY
 PIPES

* THESE UPGRADES NEEDED TO MEET EXISTING SYSTEM DEFICIENCIES.

409	339	141	1240	10	135	* UPGRADE ON FRONTAGE RD
515	275	141	1760	10	135	* CREEK & HWY 101 XING
516	251	703	2660	10	135	* CREEK XING SOUTH OF KNOTTS ST.
264	104	262	370	10	135	* NEW 10" ACROSS 101
265	262	270	370	10	135	* NEW 10" ACROSS 101
273	270	273	480	10	135	* NEW 10" ACROSS 101
279	273	274	450	10	135	* NEW 10" ACROSS 101
281	274	275	430	10	135	* NEW 10" ACROSS 101
318	307	112	200	12	135	* NEW 12" ACROSS 101
510	104	226	410	10	135	* NEW 10" ACROSS 101
221	226	234	370	10	135	* NEW 101 10"
232	234	233	70	10	135	* NEW 101 10" " " "
231	233	247	290	10	135	* NEW 101 10" " " "
247	247	246	80	10	135	* NEW 101 10" " " "
249	246	248	280	10	135	* NEW 101 10" " " "
254	248	251	360	10	135	* NEW 101 10" " " "
517	109	345	700	10	135	* TEFFT ST. HWY 101 CROSSING
337	135	321	560	8	135	* GRANDE AVE UPGRADE
338	321	322	160	8	135	* GRANDE AVE UPGRADE
347	322	328	470	8	135	* GRANDE AVE UPGRADE
348	328	329	360	8	135	* GRANDE AVE UPGRADE
349	329	330	360	8	135	* GRANDE AVE UPGRADE
355	333	319	200	8	135	* CONCEPCION ST. UPGRADE
356	319	114	900	8	135	* CONCEPCION ST UPGRADE
519	101	102	5610	12	135	* TWIN TANK TEFFT ST. PARALLEL
520	102	702	400	12	135	* NEW TANK LINE
521	103	104	510	12	135	* NEW TANK LINE
339	323	322	150	8	135	* UPGRADE ON BLACK HAWK WAY
527	187	190	5300	10	135	* LOOP ALONG POMEROY
361	345	346	890	10	135	* UPGRADE ALONG HILL ST.
528	247	256	700	8	135	* LOOP TO INCLUDE NIPOMO EL. SCHOOL
529	326	134	800	8	135	* LOOP-BONITA HOMES TO ORCHARD
464	408	424	1000	10	135	* POPPEY LANE UPGRADE
801	199	800	2500	10	135	* TIE FROM STANDPIPE TANK TO FRONTAGE RD
713	710	800	3650	10	135	* FRONTAGE RD SO OF SUMMIT STATION

*THESE UPGRADES ARE TO MEET FUTURE SYSTEM DEMANDS

700	141	345	1400	8	135	*FRONTAGE RD JUNIPER TO TEFFT
701	273	700	1750	8	135	*LEAF ST THOMPSON TO CEDARWOOD
702	700	266	730	8	135	*CEDARWOOD
703	266	701	370	8	135	*CEDARWOOD
704	701	702	370	8	135	*CEDARWOOD
705	241	703	1700	8	135	*BENNETT ST TO NEW 10"
706	303	295	1600	8	135	*EXTEND HONEY GROVE TO SOUTHLAND
707	291	705	1260	6	125	*EXIST ASHLAND LANE
708	705	704	650	8	135	*TWILIGHT LANE
709	321	707	730	6	125	*EXIST BET GRANDE AND HILL
710	370	377	1700	8	135	*INGA LANE
711	369	708	1100	6	125	*EXIST CAMINO CABALLO
712	708	339	700	8	135	*CAMINO CABALLO
713	710	712	6650	10	135	*FRONTAGE RD SO OF SUMMIT STATION
714	712	375	3000	10	135	*FRONTAGE RD
715	711	713	3500	8	125	*EXIST 8 INCH
716	713	712	1000	8	135	*CONNECT TO NEW FRONTAGE RD 10 INCH
102	102	702	400	10	125	*
717	702	103	1160	10	125	*
718	702	103	1160	12	125	*PARALLEL LINE
258	102	701	800	8	125	*
719	701	259	520	8	125	*
720	703	307	1000	10	135	*
317	305	704	390	6	125	*
721	704	306	398	6	125	*
365	330	706	990	8	125	*
722	706	347	980	8	125	*
514	430	710	2570	8	125	*
723	710	414	1890	8	125	*

740	197	200	200	10	135	* EXIST 10"
741	707	706	1200	8	135	* NEW HILL ST 8"
* THIS IS THE BLACK LAKE TIE IN						
750	606	750	80	8	135	* TIE IN ON WILLOW RD NEAR BEVINGTON WELL
652	652	751	450	8	125	* TIE NEAR HYDRO TANK
751	631	751	150	8	125	* TIE FROM BARBERRY WAY
752	636	752	800	8	135	* TIE MISTY RIDGE TO WILLOW RD
753	650	652	250	8	135	* HYDROTANK BYPASS
173	175	750	640	10	125	* WILLOW RD TIE IN
754	750	179	490	10	125	* WILLOW RD TIE IN
176	179	752	3750	10	125	* WILLOW RD/BARBERRY WAY TIE IN
527	752	182	1200	10	125	* " " " "
755	187	754	1700	10	135	* POMEROY TIE IN
756	754	753	850	10	135	* "
757	753	190	2750	10	135	* "
758	641	753	60	8	135	* "K" ST. TIE IN
*759	644	754	60	8	135	* "N" ST. TIE IN

NODES

700	0	365	*LEAF AND CEDARWOOD		
701	0	360	*CEDARWOOD AND BRANCH		
702	0	363	*CEDARWOOD AND TEFFT		
703	0	290	*ALONG NEW 10" AT AMADO ST		
704	0	320	*STORY ST AT TWILIGHT		
705	0	320	*TWILIGHT		
706	0	390	*HILL ST		
707	0	403	*HILL ST		
708	0	360	*CAMINO CABALLO		
710	0	400	*SUMMIT STA RD AT FRISCO WAY		
711	0	360			
712	0	362			
713	0	370			
800	0	381	*FRONTAGE RD LINE TO STANDPIPE TANK		

* THIS IS THE BLACK LAKE TIE IN NODES

750	0	322	0	0	0
751	0	353	0	0	0
752	0	353	0	0	0
753	0	359	0	0	0
754	0	376	0	0	0

DEMANDS

700	-3.74
701	-2.48
710	-5.63
712	-20.25

run
KEEP MPLANWTR.KEP
endfile

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM - MAIN ZONE TO WWTP

*WWTP1.DTA

PAGESIZE 84

DESIGN CRITERIA 0.9 15 0.9 21 0.9 999

ANALYSIS CRITERIA 0.9 15 0.9 21 0.9 999

PEAKING 2.0 0.9

OUTPUT runrit.CUT

UNITS 0 0 1 0 0 0

GEOMETRY

*1068	349.5	100	500	325.26	0.011	4
*1066	348.5	1190	400	311	0.011	4
1005	289.57	50	1006	290.54	0.011	15
1006	290.54	290	1007	291.41	0.011	15
1007	291.41	400	1008	292.81	0.011	15
1008	292.81	420	1009	294.03	0.011	15
1009	294.03	1300	1010	302.14	0.011	15
1010	302.14	360	1011	305.1	0.011	15
1011	305.1	370	1012	313.33	0.011	12
1012	313.33	950	1013	315.72	0.011	12
1013	315.72	1060	1014	318.64	0.011	12
1014	318.64	1130	1015	336.22	0.011	10
1015	336.22	850	1016	338.61	0.011	10
1016	338.61	250	1017	339.09	0.011	10
1017	339.09	350	1020	339.99	0.011	10
1020	339.99	370	1021	340.88	0.011	10
1021	340.88	340	1022	341.79	0.011	10
1022	341.79	280	1023	342.96	0.011	8
1023	342.96	280	1024	344.14	0.011	8
1024	344.14	280	1025	351.13	0.011	8
1025	351.13	280	1026	357.33	0.011	8
1026	357.33	220	1027	359.83	0.011	8
1027	359.83	500	1028	368.47	0.011	8
1011	305.1	460	1029	306.16	0.011	12
1029	306.16	420	1030	307.19	0.011	12
1030	307.19	1320	1031	309.97	0.011	12
1031	309.97	340	1032	314.36	0.011	8
1032	314.36	300	1033	315.71	0.011	8
1031	309.97	25	1035	329.68	0.011	8
1035	329.68	130	1036	331.34	0.011	8
1035	329.68	520	1037	331.6	0.011	8
1034	312.86	1040	1038	315.29	0.011	10
1031	309.97	784	1034	312.86	0.011	12
1034	312.86	304	1038	315.29	0.011	10
1038	315.29	400	1039	319.12	0.011	8
1038	315.29	750	1040	320.58	0.011	10
1040	320.58	330	1041	324.85	0.011	10
1041	324.85	252	1042	327.28	0.011	8
1041	324.85	585	1045	329.44	0.011	10
1045	329.44	309	1043	339.98	0.011	8
1043	339.98	227	1044	341.32	0.011	8
1044	341.32	380	1046	352.06	0.011	8
1011	305.1	380	1047	306.02	0.011	12
1047	306.02	110	1048	306.35	0.011	12
1047	306.02	300	1049	311.83	0.011	8
1049	311.83	320	1050	314.99	0.011	8
1049	311.83	240	1051	312.98	0.011	8
1051	312.98	310	1052	314.8	0.011	8
1013	316.21	350	1053	331.75	0.011	8
1053	331.75	190	1054	333.34	0.011	8
1054	333.34	600	1055	334.99	0.011	8
1054	334.99	260	1056	335.51	0.011	8
1056	335.51	50	513	337.83	0.011	8
513	337.84	50	1057	340.16	0.011	8
1057	340.16	250	1060	342.55	0.011	8
1060	342.55	50	1061	342.69	0.011	8
1061	342.69	280	1062	346.8	0.011	8
1062	346.8	270	1063	364	0.011	8
1063	364	100	1064	366.86	0.011	8
1063	364	100	1065	364.5	0.011	8
1061	342.69	630	1066	348.5	0.011	8
1066	348.5	50	1067	349	0.011	8
1067	349	50	1068	349.5	0.011	8
1016	347.08	50	1069	347.42	0.011	8
1069	347.42	360	1070	348.89	0.011	8
1070	348.89	280	1071	351	0.011	8
1071	351	400	1072	356.67	0.011	8
1072	356.67	400	1073	359.5	0.011	8

*1066	348.5	530	1058	353.8	0.011	6
SANITARY LOADING						
1014	1		1.431672			
1015	1		4.820112			
1016	1		1.39128			
1028	1		0.991848			
1028	0	0	175.0000#			*LOADING FROM BLACK LAKE MH PARK LS
1028	0	0	110.0000#			*LOADING FROM BRACKEN LS
1033	1		0.300000			
1034	1		0.318648			
1035	1		0.660432			
1036	1		0.300000			
1037	1		0.660432			
1038	1		1.588752			
1039	1		1.588752			
1041	1		0.937992			
1042	1		0.498168			
1043	1		0.911064			
1043	0	0	315.0000#			*LOADING FROM TEFFT LS
1044	1		1.068144			
1045	1		0.911064			
1046	1		0.318648			
1046	0	0	175.0000#			*LOADING FROM N. OAKGLEN LS
1047	1		0.74052			
1048	1		0.74052			
1049	1		0.619344			
1050	1		0.991848			
1051	1		0.870672			
1052	1		0.74052			
1053	1		1.808664			
1054	1		2.450448			
1055	1		3.550008			
1056	1		0.251328			
1057	1		0.870672			
1061	1		0.498168			
1062	1		0.870672			
1063	1		0.870672			
1064	1		0.251328			
1065	1		1.238688			
1066	0	0	175.0000#			*LOADING FROM NIPOMO PALMS LS
*1066	0	0	310.0000#			*LOADING FROM CSA 1
1068	0	0	190.0000#			*LOADING FROM LA MIRADA LS
1069	1		1.39128			
1070	1		1.39128			
1071	1		1.39128			
1072	1		1.377816			
1073	0	0	111.0000#			*LOADING FROM GARDENIA LS
1057	1		0.870672			
1061	1		0.498168			
1062	1		0.870672			
1063	1		0.870672			
1064	1		0.251328			
1065	1		1.238688			
1069	1		1.39128			
1070	1		1.39128			
1071	1		1.39128			
1072	1		1.377816			
ENDFILE						

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM - TEFFT ST LS AREA

*TEFFY.DTA

PAGESIZE 84

DESIGN CRITERIA 0.90 15 0.90 21 0.90 999

ANALYSIS CRITERIA 0.90 15 0.90 21 0.90 999

PEAKING 3.0 0.9

OUTPUT TEFFT3.OUT

UNITS 0 0 1 0 0 0 0

GEOMETRY

100	293.7	300	101	300.58	0.011	8
555	291.41	100	100	293.7	0.011	8
100	293.7	60	156	294.02	0.011	8
101	300.58	450	102	303.6	0.011	8
102	303.6	400	103	305.26	0.011	8
103	305.26	360	104	306.78	0.011	8
104	306.78	250	105	307.87	0.011	8
105	307.87	240	106	308.98	0.011	8
106	308.98	470	107	311.19	0.011	8
107	311.19	220	118	312.32	0.011	8
118	312.32	260	108	314.73	0.011	8
108	314.73	270	150	317.86	0.011	8
108	314.73	430	151	319.54	0.011	8
151	319.54	400	152	330	0.011	8
151	319.54	200	153	320.35	0.011	8
153	320.35	260	154	325.62	0.011	8
154	325.62	460	155	335.08	0.011	8
102	303.6	400	109	309.41	0.011	8
109	309.41	160	110	310.81	0.011	8
110	310.81	310	111	321.09	0.011	8
111	321.09	280	112	322.39	0.011	8
111	321.09	250	113	322.11	0.011	8
111	321.09	175	114	322.96	0.011	8
114	322.96	320	115	325.06	0.011	8
115	325.06	260	116	326.44	0.011	8
115	325.06	375	117	331.99	0.011	8
117	331.99	300	120	338.48	0.011	8
120	338.48	230	121	339.97	0.011	8
121	339.97	175	122	344.11	0.011	8
122	344.11	410	123	362.87	0.011	8
103	305.26	220	140	309.84	0.011	8
140	309.84	200	141	312.89	0.011	8
141	312.89	260	142	316.24	0.011	8
103	305.26	430	124	316.44	0.011	8
124	316.44	460	125	319.18	0.011	8
125	319.18	400	126	327.42	0.011	8
126	327.42	410	127	332.43	0.011	8
127	332.43	400	128	338.23	0.011	8
128	338.23	370	129	342.43	0.011	8
125	319.18	370	130	320.72	0.011	8
130	320.72	250	131	322.09	0.011	8
131	322.09	230	132	334.82	0.011	8
132	334.82	350	133	344.1	0.011	8
133	344.1	260	134	345.18	0.011	8
134	345.18	330	135	346.64	0.011	8
135	346.64	250	136	357.1	0.011	8
136	357.1	330	137	367.96	0.011	8
106	308.98	430	143	311.76	0.011	8
143	311.76	190	144	314.93	0.011	8
143	311.76	460	145	314.33	0.011	8
145	318.37	110	146	319.36	0.011	8
107	311.19	420	147	315.62	0.011	8
147	315.62	370	148	319.95	0.011	8
147	315.62	340	149	319.21	0.011	8
100	293.7	70	156	294.02	0.011	8
156	294.2	370	157	305.66	0.011	8
157	305.66	180	160	311.11	0.011	8
160	311.11	80	161	311.67	0.011	8
161	311.67	180	162	325.4	0.011	8
100	293.7	330	200	299.4	0.011	8
200	299.4	470	201	301.31	0.011	8
201	301.31	190	202	302.5	0.011	8
202	302.5	220	203	309.42	0.011	8
202	302.5	430	204	305.2	0.011	8
204	305.2	230	205	319.92	0.011	8
204	305.2	270	206	306.59	0.011	8
206	306.59	260	207	307.43	0.011	8
206	306.59	420	208	317.78	0.011	8

*TO TEFFT LS

208	317.78	250	209	320	0.011	8
204	305.2	430	210	316.63	0.011	8
210	316.63	330	211	319	0.011	8
210	316.63	380	212	319.9	0.011	8
212	319.9	110	213	320.41	0.011	8
213	320.41	440	214	325.67	0.011	8
214	325.67	780	215	332.26	0.011	8
215	332.26	390	216	343.45	0.011	8
216	343.45	400	217	355.58	0.011	8
200	299.4	250	220	306.55	0.011	8
220	306.55	430	221	309.67	0.011	8
221	309.67	430	222	314.72	0.011	8
222	314.72	460	223	321.86	0.011	8
223	321.86	420	224	323.79	0.011	8
224	323.79	410	225	330.54	0.011	8
225	330.54	400	226	336.66	0.011	8
226	336.66	380	227	343.49	0.011	8
213	320.41	360	230	321.02	0.011	8
230	321.02	430	231	327	0.011	8
230	321.02	580	232	322.97	0.011	8
232	322.97	360	233	323.85	0.011	8
233	323.85	400	234	326.56	0.011	8
234	326.56	400	235	334.49	0.011	8
235	334.49	400	236	341.76	0.011	8
236	341.76	170	237	370.9	0.011	8
232	322.97	400	238	325.61	0.011	8
238	325.61	400	239	333.14	0.011	8
239	333.14	400	240	355.65	0.011	8
240	355.65	170	241	379.43	0.011	8
240	355.65	370	242	358.93	0.011	8
242	358.93	430	243	383.5	0.011	8

SANITARY LOADING

101	1	1.36884
102	1	0.228888
103	1	0.368016
104	1	0.869344
105	1	0.251328
106	1	0.498168
107	1	0.619344
108	1	0.498168
110	1	0.251328
111	1	0.251328
112	1	0.350064
113	1	0.15
114	1	0.978384
115	1	1.198296
116	1	0.498168
117	1	0.870672
120	1	0.870672
121	1	0.870672
122	1	0.121176
123	1	0.2
124	1	0.498168
126	1	0.959104
127	1	0.991848
128	1	0.991848
129	1	0.498168
131	1	0.457776
135	1	0.619344
136	1	0.368016
137	1	0.251328
140	1	0.498168
141	1	0.498168
142	1	0.368016
143	1	0.251328
144	1	0.3
146	1	0.3
147	1	0.74052
148	1	0.870672
149	1	0.251328
150	1	0.251328
151	1	0.74052
152	1	0.870672
153	1	0.368016
155	1	0.498168
160	1	0.309672
162	1	0.5
161	1	0.5

200	1	6.458232
201	1	3.020424
202	1	0.929016
203	1	0.691152
204	1	2.297856
205	1	0.520608
206	1	0.991848
207	1	0.619344
208	1	0.870672
209	1	0.251328
210	1	3.271752
211	1	0.08976
212	1	0.601392
213	1	1.148232
214	1	4.06164
215	1	3.689136
216	1	4.191792
217	1	0.991848
220	1	0.552024
221	1	0.170544
222	1	0.08976
224	1	2.890272
225	1	1.490016
226	1	1.122
227	1	0.74052
230	1	0.991848
231	1	0.991848
232	1	1.238688
233	1	0.870672
234	1	0.870672
235	1	1.122
236	1	0.74052
237	1	0.5
238	1	2.230536
239	1	2.230536
241	1	1.490016
242	1	1.238688
243	1	1.238688

ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM - NIPOMO PALMS LS AREA

*NIPPALMS.DTA

*CSA-1 SANITARY LOADING ADDED 10/18/95

PAGESIZE 84

DESIGN CRITERIA 0.9 15 0.9 21 0.9 999

ANALYSIS CRITERIA 0.9 15 0.9 21 0.9 999

PEAKING 3.0 0.9

OUTPUT PALM1.OUT

UNITS 0 0 1 0 0 0 0

GEOMETRY

400	311	50	401	311.1	0.011	8
401	311.10	50	402	312.49	0.011	8
402	312.49	240	403	321.7	0.011	8
403	321.7	200	404	325.8	0.011	8
403	321.7	220	405	328.01	0.011	8
405	328.01	90	406	330.36	0.011	8
406	330.36	110	407	331.32	0.011	8
407	331.32	240	408	332.8	0.011	8
405	328.01	150	409	329.05	0.011	8
409	329.05	130	410	329.55	0.011	8
410	329.55	450	411	334.1	0.011	6
411	334.1	400	412	352.43	0.011	6
412	352.43	200	413	353.72	0.011	6
400	311.00	140	430	311.25	0.011	8
430	311.25	30	431	314	0.011	6
431	314	200	432	332	0.011	6
432	332	220	433	339.7	0.011	6
431	314	430	434	322.46	0.011	6
434	322.46	200	435	326.4	0.011	6
435	326.4	260	436	342	0.011	6
435	326.4	260	437	340.35	0.011	6
437	340.35	370	438	340.52	0.011	6
402	312.49	370	414	313.55	0.011	8
414	313.55	110	415	314.09	0.011	8
415	314.09	130	416	333	0.011	8
415	314.09	70	417	314.48	0.011	8
417	314.78	380	420	315.95	0.011	8
420	315.95	120	421	316.74	0.011	8
421	316.74	240	422	317.52	0.011	8
422	317.52	220	423	322.7	0.011	8
423	322.7	180	424	331	0.011	8
423	322.7	220	425	331	0.011	8
422	317.52	200	426	318.53	0.011	8
426	318.53	140	427	319.39	0.011	8
422	317.52	180	428	318.7	0.011	8
428	318.7	120	429	330	0.011	8

SANITARY LOADING

402	1	0.619344				
403	1	0.498168				
404	1	0.74052		435	1	0.74052
405	1	1.602216		436	1	1.122
406	1	0.848232		437	1	0.870672
407	1	0.848232		438	1	0.368016
408	1	0.848232				ENDFILE
409	1	0.74052				
410	1	0.251328				
410	1	310.0000# * CSA-1				
412	1	0.457776				
413	1	0.457776				
414	1	0.848232				
414	1	0.74052 *PREVIU	SLY W	AS AT NODE 439		
415	1	0.848232				
416	1	0.848232				
417	1	0.848232				
420	1	0.848232				
421	1	0.848232				
422	1	0.848232				
423	1	0.848232				
424	1	0.457776				
425	1	0.848232				
426	1	1.041216				
427	1	1.041216				
429	1	0.457776				
430	1	0.619344				
432	1	0.74052				
433	1	0.991848				
434	1	1.611192				

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM - BRACKEN LS AREA

*BRACKEN.DTA

PAGESIZE 84

DESIGN CRITERIA 0.9 15 0.9 21 0.9 999

ANALYSIS CRITERIA 0.9 15 0.9 21 0.9 999

PEAKING 3.0 1

OUTPUT BRACKEN3.OUT

UNITS 0 0 1 0 0 0 0

GEOMETRY

330	333.8	150	331	336.51	0.011	8
331	336.51	60	332	337.6	0.011	8
332	337.6	230	333	339.46	0.011	8
332	337.6	80	334	339.24	0.011	8

SANITARY LOADING

331	1	0.368016
331	1	0.368016
332	1	0.251328
333	1	0.74052
334	1	0.251328

ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM - NORTH OAK GLEN LS AREA

*NOAKGLEN.DTA

PAGESIZE 84

DESIGN CRITERIA 0.9 15 0.9 21 0.9 999

ANALYSIS CRITERIA 0.9 15 0.9 21 0.9 999

PEAKING 3.0 1

OUTPUT NOAK3.OUT

UNITS 0 0 1 0 0 0 0

GEOMETRY

163	332.85	140	164	341.3	0.011	8
163	332.85	230	165	333.76	0.011	8
222	326.81	100	163	332.85	0.011	8
165	333.76	380	166	335.4	0.011	8
166	335.4	310	167	336.95	0.011	8
167	336.95	600	168	346.48	0.011	8

SANITARY LOADING

164	1	0.251328
164	1	0.318648
165	1	0.498168
166	1	0.498168
167	1	2.31132
168	1	0.991848

ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM - BLACK LAKE MHP LS AREA

*MHPBLAK.DTA

PAGESIZE 84

DESIGN CRITERIA 0.9 15 0.90 21 0.90 999

ANALYSIS CRITERIA 0.9 15 0.90 21 0.90 999

PEAKING 3.0 0.9

OUTPUT MHPBL3.OUT

UNITS 0 0 1 0 0 0 0

GEOMETRY

300	343.73	60	301	349.01	0.011	8	
999	334.93	100	300	343.73	0.011	8	*TO BLACK LAKE LS @ MHP
301	349.01	400	302	350.58	0.011	8	
302	350.58	130	303	351.22	0.011	8	
303	351.22	300	304	352.72	0.011	8	
304	352.72	140	305	353.55	0.011	8	
305	353.55	120	306	354.05	0.011	8	
306	354.05	230	307	356.37	0.011	8	
307	356.37	300	308	378.7	0.011	8	
306	354.05	190	309	355.22	0.011	8	
309	355.22	100	310	362	0.011	8	
300	343.73	90	250	345.09	0.011	8	
250	345.09	150	311	350.46	0.011	8	
*250	345.09	342	251	348	0.011	8	*NO SAN. LOADING
311	350.46	10	312	351.08	0.011	8	
312	351.08	280	313	367.02	0.011	6	
313	367.02	280	314	369.17	0.011	6	
*315	357.02	380	314	369.17	0.011	6	*REDUNDANT
315	357.02	120	316	357.26	0.011	6	
312	351.08	260	317	352.18	0.011	6	
317	352.18	100	329	354.98	0.011	8	
329	354.98	330	327	356.22	0.011	8	
327	356.22	150	315	357.02	0.011	6	
327	356.22	470	328	367.22	0.011	6	
317	352.18	280	320	361.13	0.011	6	
320	361.13	280	321	375.33	0.011	6	
320	361.13	260	322	377.75	0.011	6	
322	377.75	260	323	390.93	0.011	6	
322	377.75	280	324	379.05	0.011	6	
324	379.05	380	325	398.32	0.011	6	
325	398.32	200	326	403	0.011	6	

SANITARY LOADING

303	1	0.619344
304	1	0.74052
305	1	0.368016
306	1	3.044344
307	1	0.870672
308	1	0.74052
309	1	0.498168
310	1	0.498168
311	1	0.619344
313	1	1.611192
314	1	0.991848
315	1	0.870672
316	1	0.251328
317	1	0.870672
320	1	0.870672
321	1	0.870672
322	1	0.870672
323	1	0.74052
324	1	1.238688
325	1	1.238688
326	1	0.619344
327	1	0.870672
328	1	1.238688

ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM - LA MIRADA LS AREA

*LAMIRADA.DTA

PAGESIZE 84

DESIGN CRITERIA 0.90 15 0.90 21 0.95 999

ANALYSIS CRITERIA 0.90 15 0.90 21 0.95 999

PEAKING 3.0 0.9

OUTPUT LAMIRAD3.OUT

UNITS 0 0 1 0 0 0 0

GEOMETRY

500	325.26	440	501	327.13	0.011	8
501	327.13	100	502	332	0.011	6
501	327.13	250	503	329.1	0.011	8
503	329.1	200	504	334.5	0.011	8
503	329.1	470	505	348.7	0.011	8
505	348.7	170	506	349.8	0.011	8
500	325.26	280	507	336	0.011	8
507	336	290	508	350.86	0.011	8
507	336	230	509	338.62	0.011	8
509	338.62	120	510	339.99	0.011	8
555	326.70	100	500	327.13	0.011	8 *INTO LA MIRADA LS

SANITARY LOADING

500	1	0.77	
501	1	1.122	* PREVIOUSLY AT NODE 500
501	1	2.13884	
502	1	0.251328	
503	1	1.611192	
504	1	0.870672	
505	1	0.991848	
506	1	0.619344	
507	1	1.122	
508	1	0.498168	
509	1	0.991848	
510	1	0.251328	
*511	1	1.238688	* TO WWTP DIRECTLY
*512	1	1.36884	* "
*513	1	0.251328	* "
*514	1	0.870672	* "
*515	1	0.74052	* "

ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM-BLACK LAKE DEVELOPMENT

*WOODGRN.DTA

PAGESIZE 84

DESIGN CRITERIA 0.5 15

ANALYSIS CRITERIA 0.5 15

PEAKING 2.0 1

OUTPUT BLACKLKE.OUT

GEOMETRY

601		100	602	314	.011	8
602	314	570	603	332	.011	8
602	314	320	616	312	.011	8
616	312	300	317	322	.011	8
616	312	400	604	308	.011	8
604	308	315	607	319	.011	8
607	319	170	605	322	.011	8
604	308	220	606	310	.011	8
606	310	240	608	315	.011	8
608	315	580	609	333	.011	8
609	333	320	610	341	.011	8
609	333	100	611	334	.011	8
608	315	970	612	330	.011	8
612	330	130	613	335	.011	8
606	310	630	614	330	.011	8
614	330	230	615	340	.011	8

SANITARY LOADING

ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM - GARDENIA LS AREA

*GARDENIA.DTA

PAGESIZE 84

DESIGN CRITERIA 0.9 15 0.90 21 0.90 999

ANALYSIS CRITERIA 0.9 15 0.90 21 0.90 999

PEAKING 3.0 0.9

OUTPUT GARDEN3.OUT

UNITS 0 0 1 0 0 0 0

GEOMETRY

169	338.6	430	170	361.5	0.11	8
170	361.5	180	171	375.52	0.11	8
170	361.5	220	172	362.76	0.11	8
172	362.76	270	173	363.44	0.11	8
172	362.76	280	174	363.48	0.11	8

SANITARY LOADING

170	1	0.498168
170	1	0.619344
171	1	0.74052
172	1	0.498168
173	1	0.2
174	1	0.251328

ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM, FUTURE FLOWS 9/8/95

*FWWTP1.DTA

PAGESIZE 84

MAIN ZONE TO WWTP

DESIGN CRITERIA 0.90 15 0.90 21 0.90 999

ANALYSIS CRITERIA 0.90 15 0.90 21 0.90 999

PEAKING 3.0 0.9

OUTPUT FWWTP.OUT

UNITS 0 0 1 0 0 0 0

GEOMETRY

*1068	349.5	100	500	325.26	0.011	4
*1066	348.5	1190	400	311	0.011	4
1005	289.57	50	1006	290.54	0.011	15
1006	290.54	290	1007	291.41	0.011	15
1007	291.41	400	1008	292.81	0.011	15
1008	292.81	420	1009	294.03	0.011	15
1009	294.03	1300	1010	302.14	0.011	15
1010	302.14	360	1011	305.1	0.011	15
1011	305.1	370	1012	313.33	0.011	12
1012	313.33	950	1013	315.72	0.011	12
1013	315.72	1060	1014	318.64	0.011	12
1014	318.64	1130	1015	336.22	0.011	10
1015	336.22	850	1016	338.61	0.011	10
1016	338.61	250	1017	339.09	0.011	10
1017	339.09	350	1020	339.99	0.011	10
1020	339.99	370	1021	340.88	0.011	10
1021	340.88	340	1022	341.79	0.011	10
1022	341.79	280	1023	342.96	0.011	8
1023	342.96	280	1024	344.14	0.011	8
1024	344.14	280	1025	351.13	0.011	8
1025	351.13	280	1026	357.33	0.011	8
1026	357.33	220	1027	359.83	0.011	8
1027	359.83	500	1028	368.47	0.011	8
1011	305.1	460	1029	306.16	0.011	12
1029	306.16	420	1030	307.19	0.011	12
1030	307.19	1320	1031	309.97	0.011	12
1031	309.97	340	1032	314.36	0.011	8
1032	314.36	300	1033	315.71	0.011	8
1031	309.97	25	1035	329.68	0.011	8
1035	329.68	130	1036	331.34	0.011	8
1035	329.68	520	1037	331.6	0.011	8
1034	312.86	1040	1038	315.29	0.011	10
1031	309.97	784	1034	312.86	0.011	12
1034	312.86	304	1038	315.29	0.011	10
1038	315.29	400	1039	319.12	0.011	8
1038	315.29	750	1040	320.58	0.011	10
1040	320.58	330	1041	324.85	0.011	10
1041	324.85	252	1042	327.28	0.011	8
1041	324.85	585	1045	329.44	0.011	10
1045	329.44	309	1043	339.98	0.011	8
1043	339.98	227	1044	341.32	0.011	8
1044	341.32	380	1046	352.06	0.011	8
1011	305.1	380	1047	306.02	0.011	12
1047	306.02	110	1048	306.35	0.011	12
1047	306.02	300	1049	311.83	0.011	8
1049	311.83	320	1050	314.99	0.011	8
1049	311.83	240	1051	312.98	0.011	8
1051	312.98	310	1052	314.8	0.011	8
1013	316.21	350	1053	331.75	0.011	8
1053	331.75	190	1054	333.34	0.011	8
1054	333.34	600	1055	334.99	0.011	8
1054	334.99	260	1056	335.51	0.011	8
1056	335.51	50	513	337.83	0.011	8
513	337.84	50	1057	340.16	0.011	8
1057	340.16	250	1060	342.55	0.011	8
1060	342.55	50	1061	342.69	0.011	8
1061	342.69	280	1062	346.8	0.011	8
1062	346.8	270	1063	364	0.011	8
1063	364	100	1064	366.86	0.011	8
1063	364	100	1065	364.5	0.011	8
1061	342.69	630	1066	348.5	0.011	8
1066	348.5	50	1067	349	0.011	8
1067	349	50	1068	349.5	0.011	8
1016	347.08	50	1069	347.42	0.011	8
1069	347.42	360	1070	348.89	0.011	8
1070	348.89	280	1071	351	0.011	8
1071	351	400	1072	356.67	0.011	8
1072	356.67	400	1073	359.5	0.011	8

1080	325.49	2200	1081	358.69	0.011	8	*GRANDE AVE
1014	318.64	800	1080	325.49	0.011	8	
*1066	348.5	530	1058	353.8	0.011	6	
* NIPOMO PALMS LS ELIMINATION PIPELINE							
*1100	310.75	150	400	311.0	.011	8	
*1101	310.04	470	1100	310.75	.011	8	
*1102	309.2	560	1101	310.04	.011	8	
1103	308.51	360	1102	309.20	.011	8	
1104	307.95	350	1103	308.51	.011	8	
1105	307.10	500	1104	307.95	.011	8	
1048	306.35	500	1105	307.10	.011	8	
SANITARY LOADING							
1009	1		36.96				*Added-new: Southland Street
1011	1		14.81				*Added-new: Story Street
1012	1		7.84				*Added-new
1013	1		10.74				*Added-new: Division Street
1014	1		49.411672				*Grand Ave
1015	1		53.380112				
1016	1		5.07128				
1017	1		3.68				*Added-new
1020	1		3.68				*Added-new
1021	1		4.71				*Added-new
1022	1		31.93				*Added-new
1023	1		1.55				*Added-new
1024	1		12.50				*Added-new:Tie in Pradera Septic
1025	1		1.55				*Added-new
1026	1		0.0				*Added-new
1028	1		0.991848				
1028	0	0	175.0000#				*LOADING FROM BLACK LAKE MH PARK LS
1028	0	0	110.0000#				*LOADING FROM BRACKEN LS
1030	1		10.31				*Added-new
1031	1		0.41				*Added-new
1032	1		0.21				*Added-new
1033	1		0.710000				
1034	1		11.828648				
1035	1		1.070432				
1036	1		0.300000				
1036	1		100.000000#				*PROPOSED AMADO ST LS
1037	1		0.660432				
1038	1		1.588752				
1039	1		1.998752				
1040	1		6.22				*Added-new
1041	1		6.067992				
1042	1		0.708168				
1043	1		4.851064				
1043	0	0	600.0000#				*LOADING FROM UPGRADED TEFFT LS
1044	1		1.068144				
1045	1		0.911064				
1046	1		0.318648				
1046	0	0	175.0000#				*LOADING FROM N. OAKGLEN LS
1047	1		0.74052				
1048	1		0.74052				
1048	1		5.0				*LOADING FROM MONTECITO VERDE I
1049	1		0.619344				
1050	1		0.991848				
1051	1		0.870672				
1052	1		0.74052				
1053	1		1.808664				
1054	1		3.400448				
1055	1		3.550008				
1056	1		1.061328				
1057	1		0.870672				
1061	1		0.498168				
1062	1		0.870672				
1063	1		0.870672				
1064	1		0.251328				
1065	1		1.238688				
*1066	0	0	175.0000#				*LOADING FROM NIPOMO PALMS LS
*1066	0	0	310.0000#				*LOADING FROM CSA 1
1066	0	0	190.0000#				*PROPOSED MERCURY COURT LS
1068	0	0	190.0000#				*LOADING FROM LA MIRADA LS
1069	1		5.07128				
1070	1		1.39128				
1071	1		1.39128				
1072	1		1.377816				
1073	1		1.72				
1073	0	0	111.0000#				*LOADING FROM GARDENIA LS
1081	1		12.94				*Added-new

1057	1	0.870672
1061	1	0.498168
1062	1	0.870672
1063	1	0.870672
1064	1	0.251328
1065	1	1.238688
1069	1	1.39128
1070	1	1.39128
1071	1	1.39128
1072	1	1.377816
1102	1	5.2
1104	1	11.13

ENDFILE

*LOADING FROM MONTECITO VERDE II

*LOADING FROM EAST OF CRYSTAL WAY BOTH SIDES OF STORY ST.

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM, FUTURE FLOWS
 *FTEFFT.DTA
 PAGESIZE 84
 DESIGN CRITERIA 0.90 15 0.90 21 0.90 999
 ANALYSIS CRITERIA 0.90 15 0.90 21 0.90 999
 PEAKING 3.0 0.9
 OUTPUT FTEFFT.OUT
 UNITS 0 0 1 0 0 0 0
 GEOMETRY

TEFFT	ST	LS	AREA
100	293.7	300	101 300.58 0.011 8
555	291.41	100	100 293.7 0.011 8 *TO TEFFT LS
100	293.7	60	156 294.02 0.011 8
101	300.58	450	102 303.6 0.011 8
102	303.6	400	103 305.26 0.011 8
103	305.26	360	104 306.78 0.011 8
104	306.78	250	105 307.87 0.011 8
105	307.87	240	106 308.98 0.011 8
106	308.98	470	107 311.19 0.011 8
107	311.19	220	118 312.32 0.011 8
118	312.32	260	108 314.73 0.011 8
108	314.73	270	150 317.86 0.011 8
108	314.73	430	151 319.54 0.011 8
151	319.54	400	152 330 0.011 8
151	319.54	200	153 320.35 0.011 8
153	320.35	260	154 325.62 0.011 8
154	325.62	460	155 335.08 0.011 8
102	303.6	400	109 309.41 0.011 8
109	309.41	160	110 310.81 0.011 8
110	310.81	310	111 321.09 0.011 8
111	321.09	280	112 322.39 0.011 8
111	321.09	250	113 322.11 0.011 8
111	321.09	175	114 322.96 0.011 8
114	322.96	320	115 325.06 0.011 8
115	325.06	260	116 326.44 0.011 8
115	325.06	375	117 331.99 0.011 8
117	331.99	300	120 338.48 0.011 8
120	338.48	230	121 339.97 0.011 8
121	339.97	175	122 344.11 0.011 8
122	344.11	410	123 362.87 0.011 8
103	305.26	220	140 309.84 0.011 8
140	309.84	200	141 312.89 0.011 8
141	312.89	260	142 316.24 0.011 8
103	305.26	430	124 316.44 0.011 8
124	316.44	460	125 319.18 0.011 8
125	319.18	400	126 327.42 0.011 8
126	327.42	410	127 332.43 0.011 8
127	332.43	400	128 338.23 0.011 8
128	338.23	370	129 342.43 0.011 8
125	319.18	370	130 320.72 0.011 8
130	320.72	250	131 322.09 0.011 8
131	322.09	230	132 334.82 0.011 8
132	334.82	350	133 344.1 0.011 8
133	344.1	260	134 345.18 0.011 8
134	345.18	330	135 346.64 0.011 8
135	346.64	250	136 357.1 0.011 8
136	357.1	330	137 367.96 0.011 8
106	308.98	430	143 311.76 0.011 8
143	311.76	190	144 314.93 0.011 8
143	311.76	460	145 314.33 0.011 8
145	318.37	110	146 319.36 0.011 8
107	311.19	420	147 315.62 0.011 8
147	315.62	370	148 319.95 0.011 8
147	315.62	340	149 319.21 0.011 8
100	293.7	70	156 294.02 0.011 8
156	294.2	370	157 305.66 0.011 8
157	305.66	180	160 311.11 0.011 8
160	311.11	80	161 311.67 0.011 8
161	311.67	180	162 325.4 0.011 8
100	293.7	330	200 299.4 0.011 8
200	299.4	470	201 301.31 0.011 8
201	301.31	190	202 302.5 0.011 8
202	302.5	220	203 309.42 0.011 8
202	302.5	430	204 305.2 0.011 8
204	305.2	230	205 319.92 0.011 8
204	305.2	270	206 306.59 0.011 8
206	306.59	260	207 307.43 0.011 8
206	306.59	420	208 317.78 0.011 8

208	317.78	250	209	320	0.011	8				
204	305.2	430	210	316.63	0.011	8	148	1	0.870672	*No new flow
210	316.63	330	211	319	0.011	8	149	1	1.201328	
210	316.63	380	212	319.9	0.011	8	150	1	0.521328	
212	319.9	110	213	320.41	0.011	8	151	1	1.01052	
213	320.41	440	214	325.67	0.011	8	152	1	0.870672	*No new flow
214	325.67	780	215	332.26	0.011	8	153	1	0.368016	*No new flow
215	332.26	390	216	343.45	0.011	8	154	1	0.27	*Added-new
216	343.45	400	217	355.58	0.011	8	155	1	0.498168	
200	299.4	250	220	306.55	0.011	8	156	1	3.43	*Added-new
220	306.55	430	221	309.67	0.011	8	157	1	2.43	*Added-new
221	309.67	430	222	314.72	0.011	8	160	1	4.239672	
222	314.72	460	223	321.86	0.011	8	161	1	2.01	
223	321.86	420	224	323.79	0.011	8	162	1	2.01	
224	323.79	410	225	330.54	0.011	8	200	1	9.888232	
225	330.54	400	226	336.66	0.011	8	201	1	3.630424	
226	336.66	380	227	343.49	0.011	8	202	1	2.149016	
213	320.41	360	230	321.02	0.011	8	203	1	0.691152	*No new flow
230	321.02	430	231	327	0.011	8	204	1	2.907856	
230	321.02	580	232	322.97	0.011	8	205	1	0.520608	*No new flow
232	322.97	360	233	323.85	0.011	8	206	1	1.131848	
233	323.85	400	234	326.56	0.011	8	207	1	0.759344	
234	326.56	400	235	334.49	0.011	8	208	1	1.280672	
235	334.49	400	236	341.76	0.011	8	209	1	0.391328	
236	341.76	170	237	370.9	0.011	8	210	1	3.271752	
232	322.97	400	238	325.61	0.011	8	211	1	0.94976	
238	325.61	400	239	333.14	0.011	8	212	1	0.601392	
239	333.14	400	240	355.65	0.011	8	213	1	1.148232	
240	355.65	170	241	379.43	0.011	8	214	1	4.33164	
240	355.65	370	242	358.93	0.011	8	215	1	3.829136	
242	358.93	430	243	383.5	0.011	8	216	1	4.331792	

SANITARY LOADING

100	1	13.54	*Added-new	221	1	2.010544	
101	1	5.16884		222	1	0.94976	
102	1	3.168888		223	1	2.51	*Added-new
103	1	2.448016		224	1	3.180272	
104	1	0.869344		225	1	2.300016	
105	1	0.251328		226	1	1.532	
106	1	0.638168		227	1	0.88052	
107	1	0.759344		230	1	0.991848	
108	1	0.498168		231	1	0.991848	
109	1	1.81	*Added-new	232	1	1.238688	
110	1	1.141328		233	1	0.870672	
111	1	1.141328		234	1	0.870672	
112	1	1.220064		235	1	1.122	
113	1	1.33		236	1	0.74052	
114	1	2.468384		237	1	0.5	
115	1	2.068296		238	1	2.230536	
116	1	1.838168		239	1	2.230536	
117	1	1.950672		241	1	1.490016	
118	1	0.14	*Added-new	242	1	1.238688	
120	1	1.140672		243	1	1.238688	
121	1	0.870672		251	1	0.41	*Added-new
122	1	0.661176					
123	1	1.01					
124	1	3.018168					
125	1	0.87	*Added-new				
126	1	2.569104					
127	1	1.801848					
128	1	1.531848					
129	1	2.938168					
130	1	0.75	*Added-new				
131	1	1.417776					
132	1	1.16	*Added-new				
133	1	1.02	*Added-new				
134	1	0.68	*Added-new				
135	1	0.829344					
136	1	0.708016					
137	1	0.731328					
140	1	0.498168					
141	1	1.308168					
142	1	0.908016					
143	1	0.791328					
144	1	0.84					
145	1	1.86	*Added-new				
146	1	1.73					
147	1	3.58052					

ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM, FUTURE FLOWS
 *FBRACKEN.DTA BRACKEN LS AREA
 PAGESIZE 84
 DESIGN CRITERIA 0.9 15 0.9 21 0.9 999
 ANALYSIS CRITERIA 0.9 15 0.9 21 0.9 999
 PEAKING 3.0 1
 OUTPUT FBRACKEN.OUT
 UNITS 0 0 1 0 0 0 0
 GEOMETRY
 330 333.8 150 331 336.51 0.011 8
 331 336.51 60 332 337.6 0.011 8
 332 337.6 230 333 339.46 0.011 8
 332 337.6 80 334 339.24 0.011 8
 SANITARY LOADING
 331 1 4.926
 332 1 0.251328
 333 1 0.74052
 334 1 0.251328
 ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM, FUTURE FLOWS
 *FNOAKGLN.DTA N. OAKGLEN LS AREA
 PAGESIZE 84
 DESIGN CRITERIA 0.9 15 0.9 21 0.9 999
 ANALYSIS CRITERIA 0.9 15 0.9 21 0.9 999
 PEAKING 3.0 0.9
 OUTPUT FNOAK.OUT
 UNITS 0 0 1 0 0 0 0
 GEOMETRY
 163 332.85 140 164 341.3 0.011 8
 163 332.85 230 165 333.76 0.011 8
 222 326.81 100 163 332.85 0.011 8
 165 333.76 380 166 335.4 0.011 8
 166 335.4 310 167 336.95 0.011 8
 167 336.95 600 168 346.48 0.011 8
 SANITARY LOADING
 164 1 0.251328
 164 1 0.318648
 165 1 0.498168
 166 1 22.968168
 167 1 3.94132
 168 1 1.261848
 ENDFILE

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM, FUTURE FLOWS
 *FMHPBLAK.DTA BLACK LAKE MHP LS AREA

PAGESIZE 84

DESIGN CRITERIA 0.9 15 0.90 21 0.90 999

ANALYSIS CRITERIA 0.9 15 0.90 21 0.90 999

PEAKING 3.0 0.9

OUTPUT FMHPBL.OUT

UNITS 0 0 1 0 0 0 0

GOMETRY

300	343.73	60	301	349.01	0.011	8	
999	334.93	100	300	343.73	0.011	8	*TO BLACK LAKE LS @ MHP
301	349.01	400	302	350.58	0.011	8	
302	350.58	130	303	351.22	0.011	8	
303	351.22	300	304	352.72	0.011	8	
304	352.72	140	305	353.55	0.011	8	
305	353.55	120	306	354.05	0.011	8	
306	354.05	230	307	356.37	0.011	8	
307	356.37	300	308	378.7	0.011	8	
306	354.05	190	309	355.22	0.011	8	
309	355.22	100	310	362	0.011	8	
300	343.73	90	250	345.09	0.011	8	
250	345.09	150	311	350.46	0.011	8	
*250	345.09	342	251	348	0.011	8	*NO SAN. LOADING
311	350.46	10	312	351.08	0.011	8	
312	351.08	280	313	367.02	0.011	6	
313	367.02	280	314	369.17	0.011	6	
*315	357.02	380	314	369.17	0.011	6	*REDUNDANT
315	357.02	120	316	357.26	0.011	6	
312	351.08	260	317	352.18	0.011	6	
317	352.18	100	329	354.98	0.011	8	
329	354.98	330	327	356.22	0.011	8	
327	356.22	150	315	357.02	0.011	6	
327	356.22	470	328	367.22	0.011	6	
317	352.18	280	320	361.13	0.011	6	
320	361.13	280	321	375.33	0.011	6	
320	361.13	260	322	377.75	0.011	6	
322	377.75	260	323	390.93	0.011	6	
322	377.75	280	324	379.05	0.011	6	
324	379.05	380	325	398.32	0.011	6	
325	398.32	200	326	403	0.011	6	

SANITARY LOADING

301	1	0.41	
303	1	1.029344	
304	1	0.74052	*No new flow
305	1	0.368016	*No new flow
306	1	3.044344	*No new flow
307	1	0.870672	*No new flow
308	1	0.74052	*No new flow
309	1	0.498168	*No new flow
310	1	0.498168	*No new flow
311	1	0.619344	*No new flow
313	1	1.611192	*No new flow
314	1	0.991848	*No new flow
315	1	0.870672	*No new flow
316	1	0.251328	*No new flow
317	1	0.870672	*No new flow
320	1	0.870672	*No new flow
321	1	0.870672	*No new flow
322	1	0.870672	*No new flow
323	1	0.74052	*No new flow
324	1	1.238688	*No new flow
325	1	1.648688	
326	1	0.829344	
327	1	1.280672	
328	1	1.448688	
329	1	0.41	*Added-new

ENDFILE

```

*NIPOMO CSD SEWER MODEL OF EXISTING SYSTEM, FUTURE FLOWS
*FGARDENA.DTA          GARDENIA LS AREA
PAGESIZE 84
DESIGN CRITERIA 0.9 15 0.90 21 0.90 999
ANALYSIS CRITERIA 0.9 15 0.90 21 0.90 999
PEAKING 3.0 0.9
OUTPUT FGARDEN.OUT
UNITS 0 0 1 0 0 0 0
GEOMETRY
169  338.6  430          170  361.5  0.11  8
170  361.5  180          171  375.52 0.11  8
170  361.5  220          172  362.76 0.11  8
172  362.76 270          173  363.44 0.11  8
172  362.76 280          174  363.48 0.11  8
SANITARY LOADING
170  1          4.877
171  1          0.74052  *No new flow
172  1          1.328168
173  1          2.06
174  1          1.491328
ENDFILE

```


APPENDIX C
Hydrant Tests/Calibration Results


NIPOMO CSD
Nipomo CSD Water and Sewer Master Plan
 VT-N04-100-01, jal/cmf 7-18-95 firedata.xls
 Hydrant Flow Test Results Used to Calibrate the Existing Water Model

TEST LOCATION			FIELD MEASUREMENTS			MODELED RESULTS		DIFFERENCE		COMMENT
Map	Node No. at Flowing Hydrant	Node No. at Resid.	Static (psi)	Flow (gpm)	Residual (psi)	Static (psi)	Residual (psi)	Static (psi)	Residual (psi)	
Initial Runs:										
1	(1)	(1)	72	1,330	62	(1)	(1)			Request re-test
2	(1)	(1)	95	1,560	70	(1)	(1)			Request re-test
3	(1)	(1)	88	1,430	58	(1)	(1)			Request re-test
4	(1)	(1)	76	1,150	38	(1)	(1)			Request re-test
5	(1)	(1)	90	1,088	34	(1)	(1)			Request re-test
6	700	701	85	1,088	60	88	73	3	13	Request re-test
7	137	702	65	1,150	40	60	46	-5	6	Request re-test
8	322	323	68	1,180	47	56	39	-12	-8	Request re-test
9	143	703	70	1,180	53	67	55	-3	2	Good run
10	362	361	82	1,055	60	70	58	-12	-2	Modeled static low; concurs with measured hydrant flow
11	203	204	93	1,430	74	87	76	-6	2	Modeled static slightly low
12	167	166	105	1,460	83	93	81	-12	-2	Modeled static low; concurs with measured hydrant flow
13	215	216	90	1,360	70	79	69	-11	-1	Modeled static low; concurs with measured hydrant flow
14	410	410	50	932	32	43	31	-7	-1	Modeled static low; concurs with measured hydrant flow
15	408	704	56	834	32	48	34	-8	2	Modeled static low; concurs with measured hydrant flow
Hydrant Re-Tests:										
1	236	228	80	1,237	67	87	51	7	-16	Checked modeling input. No evident modeling problems.
2	108	274	91	1,500	76	94	78	3	2	Good run
3	277	108	88	1,320	69	91	70	3	1	Good run
4	329	330	80	1,180	56	80	60	0	4	Good run
5	295	293	92	1,022	44	94	47	2	3	Good run
6	132	701	85	1,237	55	90	71	5	16	Checked modeling input. No evident modeling problems.
7	137	321	60	1,150	40	62	47	2	7	Adjust "C" values of pipes in vicinity
8	329	702	70	1,022	40	61	48	-9	8	Adjust "C" values of pipes in vicinity
(1) - Hydrants tested with residual taken at same hydrant as flow recorded, disregard.										

Copy of document found at www.NoNewWpTax.com

**FIRE HYDRANT
TEST LOCATIONS**





TWIN TANKS
0.5 MG EACH

BLACK LAKE
DEVELOPMENT

STANDPIPE
TANK-1.0 MG

HERMRECK WELL

SAVAGE WELL

BLACK LAKE
WELLS #3 & #4

OMIYA WELL

CHURCH
WELL

EUREKA
WELL

BELLINGTON
WELL

OLYMPIC
WELL

VIA
CONCHA
WELL

DANA WELLS
#1 & #2

FUTURE WATER SYSTEM
SERVICE BOUNDARY

LEGEND

- NIPOMO CSD WELLS
- NIPOMO CSD WELLS (STANDBY)
- NIPOMO CSD TANKS

NIPOMO COMMUNITY SERVICES DISTRICT
1995 WATER AND SEWER MASTER PLAN
EXISTING WATER SYSTEM SCHEMATIC
<i>BOYLE ENGINEERING CORPORATION</i>
VT-N04-100-01 NOV. 1995 FIGURE 5

N.T.S.